Addendum No. 2

For Construction of

City of Port Townsend Water Supply Metering Improvements

Prepared by:

City of Port Townsend Department of Public Works 250 Madison Street, Suite 2R Port Townsend, WA 98368



Exp. 12/26/23

ADDENDUM NO. 2 TO THE CONTRACT PROVISIONS AND PLANS

FOR CONSTRUCTION OF

Water Supply Metering Improvements

ISSUED: July 20, 2023

BID OPENING: 2:00 PM July 28, 2023

Please include this Addendum No. 1 with your Bid Proposal and acknowledge receipt of the same on the Bid Proposal.

TO PROSPECTIVE BIDDERS:

The attention of all prospective bidders on the above project is directed to the following modifications and additions to the Contract Documents, which are hereby made a part of the Contract Provisions and Plans.

PLANS

General Notes

Add the following to item 3B of Construction Sequencing:

Bacteria testing is not required for this work. The City/Mill will recharge and flush the main following the construction of the proposed improvements.

Add the following to the paragraph following Construction Sequencing:

The major mechanical/structural pipeline components are located at the City's Water Treatment Facility (2807 20th Street, Port Townsend, WA 98368) on a concrete slab. The contractor will need to provide equipment for loading City provided materials.

Remove the following from the list of items to be installed by the contractor:

Electric Meter Load Center and SCADA Control Panel

Sheet M01

Change the callout for the two 14-inch Butterfly valves to the following:

Install 14-inch Butterfly Valve (MJ x MJ with Megalug Bolt Kits) Typ. Of 2

Sheet M02, Detail 2-6 (Valve Box Extension)

Remove the note requiring a minimum 3' of cover and replace with the following:

Valve box shall be modified as necessary to accommodate field conditions/pipeline depth.

Sheet E03, Industrial Flow Meter Electrical Plan

Add the following to this sheet:

The approximate distance of the conduit between the proposed flow meter structures is 300-feet.