

City of Port Townsend – Mill Road Pump Station and Force Main

Prepared for
City of Port Townsend Department of Public Works

September, 2012

CH2MHILL®


1100 112th Ave. NE, Suite 400
Bellevue, WA. 98004
425-453-5000

CERTIFICATION PAGE

CITY OF PORT TOWNSEND
MILL ROAD PUMP STATION AND FORCE MAIN

CITY OF PORT TOWNSEND DEPARTMENT OF PUBLIC WORKS

The engineering material and data contained in this Predesign Report were prepared under the supervision and direction of the undersigned, whose seal as registered professional engineer is affixed below.



CH2M HILL

Handwritten signature of Jack Burnam in cursive script.

Jack Burnam, P.E. Project Manager

Handwritten date "10/11/12" in cursive script.

Date of Issue

Contents

| | |
|--|--|
| Acronyms and Abbreviations | v |
| 1. Introduction | 1 |
| 2. Influent Flow | 1 |
| 3. Gravity Collection Mains | 2 |
| 4. Pump Station Design Criteria | 4 |
| 4.1 Pump Station Structure..... | 5 |
| 4.1.1 Wet Well Sizing..... | 5 |
| 4.2 Pump Station Mechanical Components..... | 7 |
| 4.2.1 Pumps..... | 7 |
| 4.2.2 Station Operation..... | 8 |
| 4.2.3 Pump Station Design Criteria..... | 9 |
| 4.3 Pump Station Electrical Components..... | 10 |
| 4.3.1 Electrical Service..... | 10 |
| 4.3.2 Configuration..... | 10 |
| 4.3.3 Size of Main Electrical Components..... | 10 |
| 4.3.4 Pump Motor Starters and Standby Generator..... | 10 |
| 4.3.5 Storage versus Standby Generator..... | 11 |
| 4.4 Pump Station Control System..... | 11 |
| 5. Force Main Sizing and Alignment | 13 |
| 5.1 Force Main Sizing..... | 13 |
| 5.2 Force Main Alignment..... | 14 |
| 6. Cost Estimate | 14 |
| 6.1 Methodology..... | 14 |
| 6.1.1 Markups..... | 15 |
| 6.1.2 Assumptions..... | 15 |
| And I 7. Summary and Recommendations | 16 |
| 7.1 Recommendations..... | 18 |
| Appendixes | |
| A | City of Port Townsend Mill Road Pump Station Hydraulic Modeling Review |
| B | Pump Curves for Submersible and Suction Lift Pumps |
| C | Pump Station Force Main Alignment |
| D | Cost Estimate |
| E | Calculations |
| Tables | |
| 1 | Calculated Influent Wastewater Loading at Build Out |
| 2 | Wet Well Storage Times |
| 3 | Advantages and Disadvantages of Submersible and Suction Lift Pumps |
| 4 | Pump Station Design Criteria |
| 5 | Pumped Flow versus Force Main Velocities |
| 6 | Gravity Collection Main Alternatives |

Figures

- 1 Gravity Sewer Alignment
- 2 Cycle Time (T) Minutes vs. % of Influent Flow
- 3 Generic Wet Well Layout
- 4 Preliminary One-Line Power Diagram Mill Road Pump Station

Acronyms and Abbreviations

| | |
|-----|-------------------------|
| Cfs | cubic feet per second |
| Ft | feet |
| Fps | feet per second |
| Gpd | gallons per day |
| Gpm | gallons per minute |
| Hp | horsepower |
| Hrs | hours |
| Mgd | million gallons per day |
| MH | maintenance hole |
| Min | minutes |
| Rpm | revolutions per minute |

1. Introduction

The intent of this Predesign Report is to further define the pump station identified as Alternative 7 in the December 2009 *Southwest Sewer Basin Study (Basin Study)*, by Gray & Osborne, Inc. The Basin Study evaluated the City's sewer basins and presented a series of alternatives for future development within and adjacent to the existing City limits. The data presented in the Basin Study was used to develop a peak hourly flow rate to use in development of the predesign of the new Mill Road Pump Station.

It should be noted that the intent of the Mill Road Pump Station is to collect domestic sewage from Basins 1, 2 and 3 (as identified in the Basin Study) through the use of a yet to be constructed gravity collection system consisting of 8 inch through 12 inch gravity mains. The collected sewage would then be lifted (pumped) approximately 200 (vertical) feet using a new force main to the existing gravity system serving the southwest portion of the City. The following material is presented and discussed in this Predesign Report:

1. Evaluation of anticipated influent flow (Section 2).
2. Backbone Gravity Collection System Alignment (Section 3)
3. New Pump Station design criteria (Section 4), including:
 - a. The pump station (physical) structure.
 - b. Mechanical components
 - c. Electrical Components
 - d. Control System
4. Force Main Sizing and Alignment (Section 5), including:
 - a. Force Main Sizing
 - b. Force Main Alignment
5. Cost Estimate(Section 6)
6. Summary and Recommendations (Section 7)

2. Influent Flow

The Basin Study had previously established an anticipated peak hourly influent flow (at build out) of 1,185 gpm. CH2M HILL reviewed the hydraulic modeling data from the City of Port Townsend's (City's) wastewater collection system as presented in the Basin Study. The summary evaluation Technical Memorandum entitled *City of Port Townsend Mill Road Pump Station Hydraulic Modeling Review*, February, 2012 is included herein as Appendix A and summarized in the following.

As shown in Table 1 the anticipated peak hourly loading based on the results of the Basin Study was compared to that developed using the Washington State Department of Ecology *Criteria for Sewage Works Design* (October, 2006, commonly called the Orange Book).

The peak hourly flow will be used for sizing and design of the Mill Road Pump Station. As shown in Table 1 (above) the comparison of the various calculation methods to determine the peak hourly flow for design results in a difference of only plus 6 gpm or minus 126 gpm (from less than 0.5% to roughly 10% on the minus side). Based on these results it was decided to utilize the Basin Study anticipated flow of 1,185 gpm for the predesign of the new pump station and force main.

The peak hourly flow above represents the ultimate flow for the pump station or the peak hourly flow it is expected to experience in year 2046. The near term flows will actually be significantly lower than this until the area becomes more developed and each of the 3 basins are connected to the pump station. Because of this variation, the pump station shall be designed to accommodate a wide range of flows.

TABLE 1
Calculated Influent Wastewater Loading at Build Out

| Influent Flow | Row | Basin Study Calculation | Orange Book Calculation |
|---|------------------------|-------------------------|-------------------------|
| Average Dry Weather Flow (gpd) | (1) | 588,400 | 588,400 |
| Peak Day Flow (gpd) | (2) | 1,008,600 | 1,008,600 |
| Calculated Peak Day to Average Day Peaking Factor | (3) = (2)/(1) | 1.71 | NA ¹ |
| Peak Hour to Peak Day Factor | (4) | 1.70 | NA ¹ |
| Calculated Peak Hour to Average Day Factor | (5) = (4) x (3) | 2.91 | 2.59 ² |
| Peak Hour Flow (gpd) | (6) = (1) x (5) | 1,714,620 | 1,524,935 |
| Calculated Peak Hourly Flow (gpm) | (7) = (6)/1440 min/day | 1,191 | 1,059 |
| <p>¹ Not applicable for this comparison. Only comparing the Peak Hour to Average Day Factor (Row (5))</p> <p>² Calculation of Peak Hour to Average Day Factor from the Orange Book = $(18 + \sqrt{23,000})/4 + \sqrt{23,000}$, where 23,000 is the population in 2046.</p> | | | |


The following section describes the gravity system that will be needed to provide flow to the Mill Road Pump Station. The different alternatives are presented to give the City options when deciding which basin areas to connect first. These gravity lines (or a portion of them) will need to be constructed and individual users connected to this system before the Mill Road Pump Station can become operational.

3. Gravity Collection Mains

Transporting wastewater flows from Basins 1, 2, and 3 to the new Mill Road Pump Station requires the installation of a backbone collection main system. The backbone system described herein will just deliver flow from the individual basin areas to the new pump station. This backbone system **does not** include the required collection system within each basin to connect to the backbone line. The backbone collection system can be divided into four different alternatives, however, it should be realized that several alternatives may have to be installed (combined) to actually reach from the Basin indicated to the new pump station. The alternatives are shown graphically in Figure 1 and described in Table 2 (below).

It is very important to note here that the designation of the new backbone gravity line alignments and diameters are based on a cursory examination of Lidar survey elevations and resultant slopes. It is also important to note that road slopes on both Mill Road and Thomas Street have steep sections approaching 12 percent. In these sections installing the new gravity mains following the street profiles will result in flows running at supercritical velocities. It will be necessary to carefully design these reaches of sewer mains to eliminate (if possible) the supercritical flow reaches. Hydraulic jumps in the flow regime occur when flows transition from supercritical to subcritical velocities (the hydraulic jump dissipates the excess energy created in the supercritical flow). This jump can cause damage to the MHs as well as the immediately adjacent influent and effluent piping. In addition, the turbulence created by the hydraulic jump can release sulfides naturally occurring in sewage that can combine with the water and oxygen to form sulfide gasses (the rotten egg smell) or sulfuric acid which besides resulting in odor complaints could also affect the longevity of the pipe and MH at that location. The installation of new gravity sewers through such reaches is commonly accomplished by “stepping” the new sewer from MH to MH with either inside or outside drops at the downstream MH. This allows the gravity line to be installed at lesser slopes

Figure 1
Gravity Sewer Alignment



(avoiding supercritical flow velocities). By “stepping” the installation a balance between the required depth of the new gravity sewer to eliminate steep slopes and the cost of installation is also achieved.

TABLE 2
Gravity Collection Main Alternatives

| Alternative | Description | Diameter (in) | Length (ft) |
|--------------------------|---|---------------|-------------|
| 1 | Allows flow collected in Basin 3 to extend south and east to a common collection point on Discovery Road. | 8 | 1,690 |
| 2 | Extends from the intersection of Discovery Road and 8 th Street to the southwest to an intersection with Alternative 1 on Discovery Road. | 8 | 2,200 |
| Common Alternative 1,2 | Extends from the common collection point on Discovery Road southwest to a cross over intersection with Mill Road, then southeast down Mill Road to an intersection with Alternative 3 (described below). | 10 | 2,520 |
| 3 | Extends from an unimproved road easement north from Glen Cove Road to a power line easement; then north and east in the power line easement (paralleling an existing water line) to a connection on Mill Road with Common Alternative 1,2. | 8 | 1,870 |
| Common Alternative 1,2,3 | Extends east on Mill Road to the junction with Alternative 4 (below). | 12 | 187 |
| 4 | Parallels the new force main from the pump station – allows the City to pick up existing lots below (south) of the connection point of the new force main into the City’s gravity collection system. This gravity line would begin on the lower reaches of Thomas Street and proceed south to Mill Road and then east on Mill Road to the connection with Common Alternative 1,2,3 and into the new pump station. | 8 | 3,500 |

Anticipated gravity line diameters are based on assumed flows. The information contained herein is for planning level purposes only. A more detailed design survey would be required to confirm actual slopes, lengths and diameters of this gravity collection backbone system.

4. Pump Station Design Criteria

The design of the new pump station has to take into account the near term and long term uses that it will likely experience. In the near term, influent flows are not expected to be at or near the anticipated build out flows of 1,185 gpm. Accepted life span estimates for structures are commonly in the 50 to 100 year range assuming that standard operation and maintenance practices are performed. Accepted life span estimates for electrical equipment (pumps, controls, power, etc.) are in the 15 to 25 year span again assuming standard operation and maintenance practices.

There are three generic types of pump stations, each based on the type of pumps used to convey the flow from the station to its destination. These are:

1. Wet Pit/Dry Pit pump stations – these have a standalone wet well with a suction pipe extending from the wet well to the dry pit where the pumps are located at the same elevation as the wet well. These pump stations can come as a package however, when this does occur they are very tight quartered. This type of pump station is more expensive to design and construct. It is commonly considered for pump stations that would exceed 3 mgd (2,083 gpm). This is when the installation of the additional structures for separate or contiguous wet wells and dry pump pits can become more cost effective. This type of pump station will not be considered further herein.

2. Submersible pump stations – in this type of station the pumps actually sit down in the wet well. The footprint of the station is much reduced over wet pit/dry pit stations with an associated reduction in cost for design and construction. This is common for pump stations that are to accommodate influent flows of 3 mgd (2,083 gpm) or less.
3. Suction Lift pump stations – similar to the submersible pump station described above, but have the suction lift pumps sitting on top of the wet well out of the actual influent flow. Because of the additional components outside the wet well, this type of station is commonly more expensive than a submersible station due to the need for additional structures to protect the pumps, etc. from the elements but is still less expensive than the wet pit/dry pit pump stations. As above, this is also common for pump stations that are to accommodate influent flows of 3 mgd (2,083 gpm) or less.

4.1 Pump Station Structure

Current best practices for structures are to build the structure that is needed for the long term (up to build out) for the following reasons:


1. A properly constructed and maintained structure will last well past the anticipated planning horizon of 2046 (34 years into the future).
2. The construction of a wet well structure that would have to be expanded in the future is difficult and would require that the (then) existing structure be shut down to allow for the installation of additional storage.
3. This would require the excavation of the wet well which in this case is likely below the existing ground water level.
4. The new pump station is to be constructed on a limited site so the construction of an expansion to the existing wet well would likely also require the removal of much of the above grade equipment to make room for the construction. This would exacerbate the length of the shut down and would likely require additional property outside the station easement to stage and complete construction.
5. It should be recalled that at the time of the potential expansion, influent flows will have built up close to that of ultimate build out. Shutting down the station to accommodate the new construction on the structure would likely require the installation of a significant by-pass pumping operation so that those in the stations service area would not be adversely affected. The cost for a by-passing operation of this magnitude (approximately 1.7 mgd) can be as much as the cost for the excavation and installation of the additional wet well walls.
6. Any by-pass pumping operation increases the risk of a surface spill of raw wastewater. This can result in fines from controlling agencies as well as impact the public and businesses nearby the station.

For these reasons, the predesign is based on the construction of the physical features required to accommodate the ultimate build out influent flows.

4.1.1 Wet Well Sizing

Three criteria were used to determine the size of the required wet well:

1. Maintenance of an active storage volume that will require a single pump to go through one complete cycle from pump on to pump off and back to pump on in no less than 10 minutes (maintaining a maximum number of cycles to six (6) per hour). For a two pump redundant system this would mean that the number of cycles per hour would be twelve (2 X 6) per hour. Note that the worse case cycle time always occurs when influent flow is equal to one half (1/2) the pumping rate. This is shown graphically in Figure 2.



2. Providing a minimum of 60 minutes of storage between the high, high water alarm and the invert of the influent line to the station at anticipated build out influent flows of 1,185 gpm. Meeting this criterion while still allowing for the use of suction lift pumps (maximum lift of 17.5 feet) requires a wet well diameter of 45 feet. This allows for greater storage when the pump station is first brought on line and influent flows have not yet reached the peak hour rate anticipated at build out (1,185 gpm). The available storage times based on varying influent flows are shown in Table 3 (below).

TABLE 3
Wet Well Storage Times

| Influent Flow (gpm) | Wet Well Diameter (ft) ¹ | Storage Depth (ft) | Storage Time (min) | Storage Time (hrs) |
|---------------------|-------------------------------------|--------------------|--------------------|--------------------|
| 200 | 45 | 5.98 | 355.5 | 5.93 |
| 400 | 45 | 5.98 | 177.8 | 2.96 |
| 600 | 45 | 5.98 | 118.5 | 1.98 |
| 800 | 45 | 5.98 | 88.9 | 1.48 |
| 1,000 | 45 | 5.98 | 71.1 | 1.19 |
| 1,185 ² | 45 | 5.98 | 60.0 | 1.00 |

¹ The wet well diameter can vary while still maintaining the required 60 minutes of retention at peak hour flow by varying the storage depth. It should be noted that the depth of the wet well may be limited by the type of pump selected for use. Suction Lift pumps have a limit to the lift that they can accommodate.

² Peak Hour influent flows at build out (planning horizon)

3. For preliminary design purposes, set the wet well depth so that it will work for both submersible and suction lift pumps. Suction lift pumps will limit the depth of the wet well between pump volute and Pump Off elevation to approximately 17.5 feet. The diameter of the new wet well has to be balanced against the depth to insure that the required active storage volume is achieved. The other limit on this is the sensitivity of the controls for pump on and off – for the purposes of this preliminary design it was assumed that the minimum depth between pump on and pump off could be no less than six (6) inches. This allows for variations in instrument sensitivity and wet well diameter while still meeting the requirements for the use of suction lift pumps. A decision to use submersible pumps only would allow for a reduction in wet well diameter and deepening of the active storage volume.

It should be noted that accommodating influent flows that will be significantly less than those anticipated at build out will be accomplished through the control system and set levels on the pump operation. This is discussed further in the following.

4.2 Pump Station Mechanical Components

4.2.1 Pumps

As stated above, the use of a wet pit/dry pit pump station is not recommended for an application that is this far out in the service area and that experiences this type of low flow. Limiting the new pump station to a single wet well limits the types of pumps that may be used to either submersible pumps that are installed in the wet well or suction lift pumps that are installed on top of, or adjacent to, the wet well with suction piping that extends into the wet well. The advantages and disadvantages of submersible and suction lift pumps are presented in Table 4.

TABLE 4
Advantages and Disadvantages of Submersible and Suction Lift Pumps

| Pump Type | Advantages | Disadvantages |
|--------------------|---|--|
| Submersible Pumps | Smaller footprint than other pump types. Maintains surface construction to a minimum | Pulling pumps for maintenance or repairs is messy. Requires a wash down area at the wet well so that pumps can be cleaned off prior to loading on trucks, etc. |
| | Can accommodate deeper wet wells, suction lift limitations do not apply. | Requires the maintenance of a “dead” storage volume in the wet well that acts to cool the pump motors during operation |
| | Can accommodate a wide range of TDH and flow conditions. | Access to motors and impellers requires pulling the pumps from the wet well. |
| | Less costly because most mechanical equipment is below ground, does not require an above surface structure to house the equipment | Does require the wet well to have 2 to 3 feet of dead storage (depending on the pump) to act as cooling during pump operation. |
| | Simple Mechanical System | Pulling the pumps to perform maintenance operations will require a cleaning area. |
| Suction Lift Pumps | Motors, volutes, etc. are at ground surface and more accessible for operation and maintenance activities. | Requires more surface construction or installation of a package pump station on top of or adjacent to the wet well |
| | Pump wash down area is not required when taking pumps down for maintenance. | Limits depth of the wet well to the depth of maximum suction lift, available lift will vary based on suction pipe diameter, motor Hp and impellers. |
| | Commonly supplied as a “package” lift station such that all the associated station piping, priming pumps, controls, etc., come in one package contained in a steel container that is set on the new wet well. | More Costly when compared to a submersible system because more equipment is above grade and needs to be housed in a structure to protect it. |
| | Pulling the pumps for maintenance will not require a cleaning area. | More complex mechanical system including additional equipment (primer pump) |
| | | Once maximum depth is reached the only way to create additional volume is by increasing the diameter. |

It should be noted that there are additional expenses associated with the construction/installation of a suction lift package pump station that make it the more expensive option. As stated in Table 3, suction lift pumps are commonly supplied as part of a “package” lift station that includes all the ancillary equipment required to operate the station. This can include priming pumps, discharge piping, check valves and controls connected to an in station control system. This control system can then be connected to a PLC for operating the station and annunciating alarms via either the City’s SCADA system or via telephone lines. Whether or not the advantages of the suction lift station outweigh the associated costs are a judgment call that the City will have to make.

The pump station shall include a minimum of two pumps, each capable of accommodating the anticipated peak hour influent flow of 1,185 gpm (providing full redundancy). It is further recommended that a third pump be purchased at the time of construction and provided to the City for storage as a replacement for one of the installed pumps should a failure occur. Supplier lead times for replacement pumps or even parts have been increasing and the relatively remote location of the City would support this recommendation.


4.2.2 Station Operation

Pump station controls will operate the pumps/station in the following manner:

1. Pumps will operate in a lag/lead manner that automatically switches the lead pump to come on after every pumping cycle (one pump cycle is from pump on – to pump off and back to pump on again). This will equal out the hours that each pump operates over time.
2. Controls will include (starting from the bottom of the wet well):
 - a. Dead storage – this extends from the bottom of the wet well to the height required to cover the pump motor and provide cooling as recommended by the manufacturer of the submersible pump. NOTE THAT THIS IS ONLY REQUIRED FOR SUBMERSIBLE PUMPS.
 - b. Low, low level alarm/redundant pump off – this control elevation is approximately 6” below the Pump Off elevation. In a submersible pump station this level would also represent the top of the dead storage required to cool the pump motors. It actuates an alarm indicating that the pumps are not shutting off at the control point specified and are pumping down the wet well to an elevation where suction could be lost or the pump motor could overheat.
 - c. Pump Off elevation – pump off set point for one pump operating or both pumps operating.
 - d. Pump On elevation – the difference between this elevation and the pump off elevation represents the “Active Storage” volume of the wet well. At this elevation the lead pump is called into service to pump the “active storage” volume down to Pump Off elevation.
 - e. High Water Alarm/Redundant Pump On elevation – this occurs if the lead pump is called to operate and either fails or cannot keep up with the influent flow and the level in the wet well continues to rise. Once it reaches this elevation the second pump (lag pump) is called to operate and an alarm is sent indicating that for whatever reason the lead pump could not keep up with influent flow (potential reasons for lead pump failure could include ragging, motor failure, power failure, impeller wear, etc.).
 - f. High, High Water Alarm Elevation – is sent once both pumps have been called to operate and the level in the wet well continues to rise. The high, high water alarm elevation also represents the bottom elevation of storage included in the wet well design for situations such as this.
 - g. Influent Sewer Invert Elevation – this is commonly the top of the storage volume included in the wet well design. The intent is to contain all storage within the wet well rather than depending on possible storage within the collection system.

Figure 3 below shows a representation of the wet well and control elevations. In order to size the wet well the operation of the station must be determined. These criteria should be used for design of the wet well in addition to the controls system.

Figure 3
Generic Wet Well Elevation Layout



4.2.3 Pump Station Design Criteria

The design criteria in Table 5 were used to develop the preliminary design for the Mill Road Pump Station.

TABLE 5
Pump Station Design Criteria

| Peak Hour Influent Flow | 1,185 gpm |
|-------------------------|---|
| No. of Pumps | 2 (minimum) – each able to accommodate peak hourly influent flow (completely redundant) Whether or not to provide a third pump as a standby for replacement of the two operating pumps should be evaluated during final design. The speed of each operating pump shall be controlled by a adjustable frequency drive (AFD). |
| Storage Capacity | 60 minutes at Build Out without utilizing the influent line for storage. |
| Standby Generator | Install as part of the initial construction sized to provide the ability to start both pumps (with a lag time in between starts) and run both pumps and the station lighting, controls and SCADA. |
| Pump Cycle Time | No more than 6 complete cycles per hour (Minimum 10 minute cycle time from pump on to pump on again assuming one pump in operation) |
| Active Storage Volume | Based on Equation $T = V/i + V/(q-i)$ Where: T = time (min); V = volume (gallons); i = influent flow (gpm); q = pumping rate (gpm) NOTE: Minimum cycle time occurs when influent flow equals one-half of the pumping capacity. |
| Wet Well Construction | Wet well shall be designed and constructed to accommodate anticipated peak flow at build out (1,185 gpm). Design and construct bottom of wet well to be self cleaning – slope sides to a center channel that will direct solids to the pump suction and create velocities to the suction that will enhance lifting the solids into the pumps. |

| Peak Hour Influent Flow | 1,185 gpm |
|---|--|
| Wet Well Construction | Pre-design is based on the installation of a concrete caisson for the new wet well due to high groundwater concerns. Other installation methods may be possible but will require significant shoring and dewatering efforts. |
| Submersible Pump | Flygt NP 3315 HT 3 ~ 456 – 1760 RPM – 160 Hp (used for comparison purposes in pre-design) Pump curves included herein in Appendix B – Pumps should be installed AFD's to limit inrush current during start up. |
| Suction Lift Pump | Smith & Loveless 8D4V – 1760 RPM – Maximum Suction Lift = 17.5 feet (conservative) – 150 Hp (used for comparison purposes in pre-design) Pump curves included herein in Appendix B – Pumps should be installed with AFD's to limit inrush current during start up. |
| Station Operation | As described above (Section 4.2.2) Alarm modes and actual elevations to be confirmed in final design. Additional alarm sequences to be confirmed with the City if needed. |
| Required Generator to run Station during extended outage events | Required Standby Generator Power: either 150kW or 350kW. The 150 kW generator will run the station and one pump. The 350 kW generator will run the station and two pumps. |

4.3 Pump Station Electrical Components

As previously stated, electrical components for a pump station of this nature commonly are assumed to have an average life span of 20 years. This is less than the planning horizon of 2046 (34 years into the future), however, logic would dictate that savings generated by putting in lower Hp pumps and electrical equipment for today would not exceed the cost required to install the higher Hp pumps and associated electrical equipment 20 years into the future. In addition, there is no way to truly tie down the rate at which flows would increase to the pump station over time. More recent experience would indicate that it would take longer to reach predicted peak influent flows rather than less time. But this cannot be guaranteed. For the purposes of this preliminary design it has been assumed that the electrical components will be designed for complete build out flows.

4.3.1 Electrical Service

Given the size range of the pumps, 160 hp to 150 hp, the electrical service from the local utility will need to be 480 volts, 3-phase. Assume 600 amperes for initial planning purposes.

4.3.2 Configuration

The electrical service will include a utility power meter with current transformer enclosure, main breaker, automatic transfer switch, and an installed standby generator. A preliminary one line diagram of this configuration is shown in Figure 4. Other components will depend upon the type of pumps selected

4.3.3 Size of Main Electrical Components

The above ground electrical equipment will need to be protected from the weather and securable. This can be accomplished using a shelter and lockable enclosures or a single lockable enclosure with components mounted inside. The footprint will vary depending again on the type of pumps selected but assume a shelter will be larger and allow a space 16ft long by 8ft wide. The other main component is the standby generator. Allow a space 7ft wide by 20ft long by 10ft high for a permanently installed generator capable of powering two 160hp pumps at the same time. (This assumes that the two pumps will start in a lead/lag configuration and that they will be controlled by AFD's or have solid state soft starts on them.)

4.3.4 Pump Motor Starters and Standby Generator

The pump motors are large enough to require means to reduce the motor starting current which is often six or more times the motor running current. There are several means to control the starting current, but the two to be

considered here are solid-state “softstarters” and adjustable frequency drives (AFDs). While AFDs are not “needed” for the operation of the pump station, they can be used to reduce the size of the mobile generator needed to operate the station during a utility power outage. A single pump operated on an AFD requires only a 150kW standby generator while a pump operated on a softstarter requires a 250kW standby generator. AFDs are generally twice as expensive as softstarters but AFDs have better power factor and reduce the starting current more. If both pumps are required to operate on a standby generator then the size of the generator will be the same for both types of starters, i.e. about 350kW.

4.3.5 Storage versus Standby Generator

The City has stated that they want to have the standby power generator installed at the time of initial construction. However, if desired, the large change anticipated between initial influent flows and those that would occur at build out can be used to delay the installation of a standby generator. By constructing the new structure so that it will have a minimum of 60 minutes of storage capacity following an alarm for a power outage or pump failure at ultimate peak hour conditions (1,185 gpm, build out) will mean that up to several hours of storage are available during the time from initial construction until build out flows are reached. As shown in Table 3 in the near term when influent flows will be less than those anticipated for build out the new system will exhibit larger retention times.

If delaying the installation of the standby mobile generator is chosen the design for the new station would include a connection point for a portable generator to plug in so that during an extended power outage the station could be brought back on line using the generator. The City would monitor flows at the pump station in order to decide when a permanent standby generator would be installed in the future.

4.4 Pump Station Control System

The control system design for the pump station will be customized to meet current City standards for equipment and functionality. In addition to matching existing City technical standards, the control system will be designed to integrate the features and equipment associated with the selected pump station configuration.

Although specifics of the control system cannot be defined at this point, the following outlines the general elements of the control system that will be incorporated into the pump station design.

1. Programmable Logic Controller (PLC): A PLC will be used as the central controller for the pump station. For the submersible pump option, the PLC will control all functions of the pump station. For the suction lift pump option, the package controls for the pumps will be integrated with the pump station PLC to provide facility control. The PLC manufacturer and model will be selected to match City standards.
2. Local Operator Interface (OI): An operator interface device will be included to allow operations staff to locally monitor equipment operation, control equipment and adjust pump station operations setpoints. The OI manufacturer and model will be selected to match City standards.
3. SCADA System Communications Interface: The pump station PLC system will be integrated into the City’s existing SCADA system. The communications interface will allow pump station operation, status and alarm signals to be viewed and controlled remotely. The communications system will be designed to match the communications systems currently in service.
4. Wet Well Level Sensor: A wet well level sensor will be installed to provide continuous measurement of the wet well level. Operator adjustable level setpoints for pumps off, lead pump start and lag pump start will be compared against the level signal for pump control.
5. Wet Well Float Switches: Float switches for low-low and high-high level detection will be installed (if applicable to City standards) for detection of the low-low water level/redundant pump off and high-high water level alarms. These float switches can also be used as a backup control to start and stop the pumps in the event of a wet well level sensor failure.

FIGURE 4
Preliminary One-Line Diagram Mill Road Pump Station




FIGURE 4 -
PRELIMINARY ONE-LINE DIAGRAM MILL ROAD PUMP STATION

CH2MHILL

- Intrusion Detection: Sensing devices will be installed within the pump station to detect intrusion into the facility. The types of devices used will be based upon the selected pump station configuration and City standards.

Support Systems Integration: The control system design will include PLC interfaces to pump station support systems such as the backup power generator and combustible gas monitors.

5. Force Main Sizing and Alignment

5.1 Force Main Sizing

Force mains should be sized to maintain a minimum flow velocity of 2.0 fps to prevent solids from settling in the line between each pumping cycle (in many cases a minimum velocity of 2.5 fps is preferred to insure movement of solids during each pumping cycle). Maximum force main velocities should not exceed 7.0 fps to prevent the creation of significant headlosses that would increase the pump power required, cost of operating the pumps and the required size of the standby generator. A breakdown of pumped flow versus velocity in force main diameters from 6 inches to 10 inches is shown in Table 6.

TABLE 6
Pumped Flow versus Force Main Velocities

| Pumped Flow (gpm) | Pumped Flow (cfs) | Velocity (fps) ¹ | | |
|-------------------|-------------------|-----------------------------|-------------------|--------------------|
| | | 6 inch Force Main | 8 inch Force Main | 10 inch Force Main |
| 200 | 0.45 | 2.27 | 1.28 | 0.82 |
| 400 | 0.89 | 4.54 | 2.55 | 1.63 |
| 500 | 1.11 | 5.67 | 3.19 | 2.04 |
| 600 | 1.34 | 6.81 | 3.83 | 2.45 |
| 800 | 1.78 | 9.08 | 5.11 | 3.27 |
| 1000 | 2.23 | 11.35 | 6.38 | 4.09 |
| 1185 | 2.64 | 13.45 | 7.56 | 4.84 |

¹ Flow velocities within the acceptable range of 2.0 fps to 7.0 fps are highlighted

Based on the peak hourly flow of 1,185 gpm, a 10 inch diameter force main should be installed for this application for the following reasons:

- It would not be cost effective to install a smaller force main and then replace it with a larger force main in the future. This would also require additional work at the pump station to revise the piping and increase easement widths required for the force main to allow installation of a second line while keeping the first line in service (to limit any required shutdowns of the pump station).
- The installation of an 8 inch force main or 6 inch force main would result in increasing the TDH for the pump station by 82 feet and 324 feet, respectively, at the build out flow of 1,185 gpm. Both would increase required pump horsepower and electrical system design and installation costs.
- During final design the City can look at reducing the flow rate from the recommended pumps by installing a trimmed impeller. This would also reduce the motor Hp required. However, if this is considered, it should be realized that the pump impellers and motors could require switching out before the end of their useful life.

The flow from the pumps will need to be at least 500 gpm to provide the needed minimum velocity in the forcemain.

5.2 Force Main Alignment

The alignment of the new force main from the pump station is shown on plan and profile sheets included herein Appendix C. Generally, the new force main will exit the pump station site on Mill Road (north side), then proceed east on Mill Road (remaining on the north side of the road) to the intersection with Thomas Street; north on Thomas Street (remaining on the west side) to a location just above Workman Street. As shown on the included plan and profile sheets the new forcemain would then proceed east again following an undeveloped road easement to an existing MH connected to the City's gravity collection system on the southern end of Logan Street. The force main would discharge into this MH. Alternatively, the new force main could continue north on Thomas Street to 4th Street and discharge into a MH at this location. Some resloping of the existing sewer on 4th Street would likely be required to make this alternative work. For planning purposes, the cost for either alignment would be roughly the same. The approximate length of the new force main is 4, 278 feet.

6. Cost Estimate

Table 7 is a summary of the estimate costs. The base construction cost shown includes mobilization, bonds, contingency and escalation. It does not include project costs such as design, administrative, legal, or services during construction. See Appendix D for a complete breakdown of the costs included in each category.

TABLE 7
Cost Estimate Summary

| | Low Range | Estimate Range | High Range |
|--|-------------|--------------------|-------------|
| | -20% | Base Cost | +30% |
| Submersible Pump Station & Force Main (yard piping) | \$1,633,000 | \$2,041,000 | \$2,653,000 |
| Suction Lift Pump Station & Force Main (yard piping) | \$1,702,000 | \$2,127,000 | \$2,765,000 |
| Force Main | \$882,000 | \$1,102,000 | \$1,433,000 |
| Gravity Pipe Alt 1 | \$306,000 | \$383,000 | \$498,000 |
| Gravity Pipe Alt 2 | \$394,000 | \$492,000 | \$640,000 |
| Gravity Pipe Common Alt 1 & 2 | \$542,000 | \$678,000 | \$881,000 |
| Gravity Pipe Alt 3 | \$170,000 | \$213,000 | \$277,000 |
| Gravity Pipe Common Alt 1, 2 & 3 | \$43,000 | \$54,000 | \$70,000 |
| Gravity Pipe Alt 4 | \$674,000 | \$843,000 | \$1,096,000 |

6.1 Methodology

This cost estimate is considered a Schematic Design Estimate (Class 3) construction cost estimate. It is based upon the 15 percent design drawings and specification dated May 2012, and design information provided by the engineer at the time of the estimate.

Where possible, a quantity takeoff was developed for all elements shown in sufficient detail in the design drawings or described in the report. For an item known to exist but not defined in the project drawings, the cost estimator applied an allowance based on estimator experience and consultation with the project engineer.

The final costs of the project will depend on actual labor and material costs at the time of bid, actual site conditions, productivity, competitive market conditions, final project scope, final schedule and other variable factors. As a result, the final project costs will vary from those presented herein. Because of these factors, funding needs must be carefully reviewed prior to making specific financial decisions or establishing final budgets.

6.1.1 Markups

Table 8 summarizes various markups applied to the cost estimate to develop the overall construction cost. Unit costs include contractor overhead and profit. Mobilization, contingency, sales tax, market factor and escalation are also applied to the bottom line totals.

TABLE 8
Markup Summary

| Markup | Percentage |
|--|------------|
| Contractor Overhead & Profit (In unit costs) | 18% |
| General Conditions | 7% |
| Mobilization/Bonds/Insurance | 5.16% |
| Construction Cost Estimate Contingency | 40% |
| Escalation (Aug 2013) | 3.58% |
| Sales Tax (Port Townsend) | 9% |
| Market Conditions | 0% |

6.1.2 Assumptions

The following assumptions were used to develop the construction cost estimate:

General Assumptions:

1. Labor rates are based on the RS Means National Average Rate and adjusted for local wage rates using the RS Means regional adjustment factor.
2. The estimate currently includes escalation to mid-point of construction to August 2013.
3. Costs assume that the work is done during a regular 40 hour work week and does not include any overtime cost markups.
4. Costs do not include purchase of easements or right-of-way, engineering, administration or owner costs beyond the capital construction costs. The cost estimate is intended to represent the total contractor bid price as shown on the bid price schedule at the time of the bid opening.
5. Site access for the contractor and contractor staging areas are assumed to be adequate for the contractors needs.
6. The estimate is based on aggregates, drain sand, and clay materials being available locally to the contractor.
7. Temporary erosion and sediment control are expected to be minor. No wetland impacts are known at this time.
8. Pipe trenching is based on 5' of cover to the top of the pipe.
9. It is assumed that dewatering for pipe trenching can be controlled with sump pumps in trench.
10. Roadway patching is based on 6" of asphalt over 6" of crushed surface base course.
11. The pump station wet well construction is based on a dropped caisson construction.
12. Due to the pump cooling requirements the submersible pump station wet well is 30" deeper than the suction lift pump station.

13. The pipe alternatives costs with the exception of Alternative 3 are based on the pipeline being placed in the roadway and include ACP demo and patching. Alternative 3 is outside of the roadway and travels cross country.
14. The estimate includes a 350 KW standby generator at the pump station and VFD's controlling the pumps.

7. Summary and Recommendations

The following (Table 9) summarizes the previous discussions and presents recommendations for taking the new Mill Road Pump Station and Force Main into design.

TABLE 9
Summary

| Item | Description | Recommendation |
|--------------------------|---|--|
| Pump Station | | |
| Wet Well | Several methods of construction of the wet well were considered, however, due to the existence of high groundwater it appears that a circular wet well installed as a caisson would work best in this situation. It would limit the need for dewatering and for shoring which would be an advantage. | Install the new wet well as a caisson. This would be a concrete structure and would include a corrosion resistant lining (once completed and the bottom sealed) |
| Wet Well Diameter | For the purpose of this planning level evaluation, it was decided to make the wet well compatible with the use of either submersible or suction lift pumps. If submersible pumps are chosen for final design it may be possible to reduce the diameter and deepen the wet well creating a somewhat smaller footprint. | Anticipated ID of the wet well is 45 feet to obtain a standby storage capacity of 1 hour at buildout and keeping the wet well shallow enough to use suction lift pumps. Wall thickness is 2 feet. Anticipated OD of the wet well is 49 feet. |
| Wet Well Depth | Depth in this case is based on the anticipated elevation of the suction pump volute which has been estimated as 18" above the top cap of the wet well. From this point down the depth to the established pump off elevation can be no more than 17.5 feet. | Assuming surface elevation = 23.0 feet Suction Lift Station – depth from surface elevation to pump off elevation = 15.98 feet Submersible Pump Station - depth from surface elevation to bottom of dead storage = 17.98 to 18.98 feet (depending on depth of dead storage required to cool pump motors) |
| Pumps | System head curves for both the use of submersible pumps and suction lift pumps were developed. These were graphed against pumps curves for both types of pumps to identify pumps that could be used under this scenario. It was also noted that if suction lift pumps were used they would be supplied as a package that included the priming pumps, controls, station piping, etc. within a epoxy coated steel container. | Submersible pump recommendation: Flygt – Model NP 3315 HT3-456; 160 Hp; station piping diameter = 6"; Impeller diameter = 15 7/8" Suction Lift Pump recommendation: S&L – Model 8D4V, 150 Hp, Suction pipe Diameter = 12"; Station piping diameter = 8"; Impeller diameter = 14 5/8" – Included in a package suction lift station. <i>System head curves vs. pump curves are included in the appendix.</i> |
| Station Operation | See Section 4.2.2 and Table 5 | See Section 4.2.2 and Table 5 |
| Alarms and Communication | This would have to be in keeping with the City requirements and should be vetted early in the actual design phase. | See Section 4.4 |
| Standby Generator | As discussed in Section 4.3.4 (above) the intent is to | Required Standby Generator Power: either 150kW or |

| Item | Description | Recommendation |
|---|---|---|
| | install the required standby generator during original construction. If this is revised during final design a plug in for the use of a mobile standby generator during the initial years of station operation will be included. This will continue as long as the City believes that the provided storage in the wet well is enough to allow City Maintenance Crews to access the station and provide standby power during any extended outage event. Once influent flows reach a point where either City Crews cannot access the station quickly enough or storage time reaches 60 minutes – then a permanent standby generator will be installed. | 350kW. |
| Force Main | | |
| Alignment | Generally, the new force main will exit the pump station site on Mill Road (north side), then proceed east on Mill Road (remaining on the north side of the road) to the intersection with Thomas Street; north on Thomas Street (remaining on the west side) to a location just above Workman Street; at this point the new force main can proceed either west again following an undeveloped road easement to an existing MH connected to the City's gravity collection system on the southern end of Logan Street or continue north to a connection to the existing collection system on 4 th Street. | Plan and Profile Sheets contained in the attached Appendix. |
| Length | | 4,278 feet |
| Diameter | | 10" |
| Gravity (Backbone) Collection System | | |
| Alternative | | |
| 1 | Allows flow collected in Basin 3 to extend south and west to a common collection point on Discovery Road. | Length = 1,690 feet; Diameter = 8" |
| 2 | Extends from the intersection of Discovery Road and 8 th Street to the southwest to an intersection with Alternative 1 on Discovery Road. | Length = 2,200 feet; Diameter = 8" |
| Common Alternative 1,2 | Extends from the common collection point on Discovery Road southwest to a cross over intersection with Mill Road, then southeast down Mill Road to an intersection with Alternative 3 (described below). | Length = 2,520 feet; Diameter = 10" |
| 3 | Extends from an unimproved road easement north from Glen Cove Road to a power line easement; then north and east in the power line easement (paralleling an existing water line) to a connection on Mill Road with Common Alternative 1,2. | Length = 1,870 feet; Diameter = 8" |
| Common Alternative 1,2,3 | Extends east on Mill Road to the new pump station site | Length = 187 feet; Diameter = 12" |
| 4 | Parallels the new force main from the pump station – allows the City to pick up existing lots below (south) of the connection point of the new force main into | Length = 3,500 feet; Diameter = 8" |

| Item | Description | Recommendation |
|-----------------------|--|----------------|
| | the City's gravity collection system. This gravity line would begin on the lower reaches of Thomas Street and proceed south to Mill Road and then east on Mill Road to the connection with Common Alternative 1,2,3 and into the new pump station. | |
| Estimated Cost | | |
| | Based on planning level considerations including a 40% contingency for unknowns at this time. As shown here the estimate has been broken into several categories and a complete copy of the estimate is included in Appendix D: | |
| | Submersible Pump Station w/Force Main (yard piping) | \$2,041,000 |
| | Suction Lift Pump Station w/Force Main (yard piping) | \$2,127,000 |
| | Force Main (outside yard piping) | \$1,102,000 |
| Gravity Lines | | |
| | Alternative 1 | \$383,000 |
| | Alternative 2 | \$492,000 |
| | Alternative 1 & 2 | \$678,000 |
| | Alternative 3 | \$213,000 |
| | Alternative 1, 2 & 3 | \$54,000 |
| | Alternative 4 | \$843,000 |

7.1 Recommendations

The following steps need to be undertaken to initiate and complete final design:

1. A complete survey of the gravity alternatives needs to be completed to better document the existing slopes that will have to be accommodated and what steps (if any) that will be required to eliminate or at least reduce the occurrence of supercritical flow regimes.
2. A survey of the alternative force main route to 4th Street needs to be completed to determine the feasibility of the alternative route and whether the static head requirements change significantly.
3. Soil borings need to be completed for the new pump station site and the alternative pipeline alignments (gravity and force main) to confirm design criteria, trench backfill requirements, etc. Recommend that there be at least two soil borings at the pump station site with one extending at least 25 feet below the invert of the wet well. Borings on the gravity and force main alignment should be spaced at 1,000 foot intervals and be completed to a depth of at least 5 feet below the proposed trench invert. This information will be critical to the final design process.
4. Property acquisition issues will have to be better identified and how they will affect the design addressed.
5. City and Engineer need to work closely together to better clarify the anticipated influent flow to the new pump station site.
6. The City needs to revisit and confirm whether or not the installation of a standby generator should be included in the final design or left as a future project.

7. A more definitive decision needs to be reached regarding the use of submersible or suction lift pumps.
8. The City needs to revisit the Master Plan completed by Gray & Osborn to confirm that there is capacity in the existing collection system downstream of the tie in point for the new force main all the way to the City's Wastewater Treatment Plant.

Appendix A:
City of Port Townsend Mill Road Pump Station
Hydraulic Modeling Review

City of Port Townsend Mill Road Pump Station Hydraulic Modeling Review

PREPARED FOR: Mary Heather Ames
City of Port Townsend

COPY TO:

PREPARED BY: Amie Roshak
DATE: February 23, 2012
PROJECT NUMBER: 425179

This technical memorandum summarizes the review of hydraulic modeling data from the City of Port Townsend's (City's) wastewater collection system as presented in the December 2009 *Southwest Sewer Basin Study (Basin Study)*, by Gray & Osborne, Inc. The report evaluated the City's sewer basins and presented a series of alternatives for future development within and adjacent to the existing City limits. The data presented in the Basin Study will be used to develop a peak hourly flow rate to use as design criteria for the design of the new Mill Road Pump Station. The specific alternative in the Basin Study that was reviewed for the Mill Road Pump Station is Alternative 7. The areas that Alternative 7 represents are summarized below along with the review of the loading rates and peaking factors presented in the Basin Study.

Area of Interest for Mill Road Pump Station: Basin Areas for Alternative 7

Alternative 7 in the Basin Study represents the option for a common lift station (Mill Road Pump Station) to serve Basins 1, 2, and 3. In this alternative, Basin 1 also includes the Local Area of More Intense Rural Development (LAMIRD) south of the City. The analysis presented in the Basin Study included a layout of future gravity sewers that would serve the basins and discharge to the Mill Road Pump Station.

The areas summarized for Basins 1, 2, and 3 in the Basin Study were confirmed, and the basins are shown in Figure 1.

Design Flow Development

This section presents information on the calculation of the projected wastewater flow to be pumped by the Mill Road Pump Station. The projected average and peak day flow is presented as well as the determination of the peak hourly flow.

Wastewater Loading Rate Determination

In the 1999 *City of Port Townsend Wastewater Comprehensive Plan (Comprehensive Plan)* by CH2M HILL, wastewater loading rates were defined based upon seventeen classes of Land Use. This approach also discounted the land dedicated to Right-of-Ways. Development factors for existing and future development density were also taken into account when determining the total amount of developable lands. During the Basin Study, the ultimate wastewater flows developed for each basin in the Comprehensive Plan were divided by the total number of acres in each basin to develop a basin-wide loading rate. This basin-wide loading rate was then applied to the new basins defined in the Basin Plan. The foundation of this approach in the Basin Plan was to apply the calculated basin-wide loading rate to a basin that was assumed to have a similar development pattern as the basin in the Comprehensive Plan. For the basins involved in this study (Basins 1, 2, and 3), the Southwest Basin in the Comprehensive Plan was identified as the similar basin. Figure 2 shows the overlay of the extent of the Southwest Basin from the Comprehensive Plan and Basins 1, 2, and 3 in the Basin Plan, and Table 1 summarizes the calculation of the basin-wide loading rate for the Southwest Basin and Table 2 summarizes the ultimate flows for Basins 1, 2, and 3 using the calculated Southwest Basin basin-wide loading rates shown in Table 1.

FIGURE 1
Mill Road Pump Station (Alternative 7)
Basin Areas




TABLE 1
Basin Flowrate Calculation: Basin-wide Loading Rate and Projection

| | Southwest Basin Projected Ultimate Flows (2047) | | |
|--------------------------|--|--------------------|---|
| | Flow (gpd) | Basin Area (acres) | Calculated Basin-Wide Loading Rate (gpd/acre) |
| Average Dry Weather Flow | 139,988 ¹ | 195 ¹ | 718 |
| Peak Day Flow | 240,521 ¹ | 195 ¹ | 1,233 |

¹Source: CH2M HILL, Inc., City of Port Townsend Wastewater Comprehensive Plan, 1999.

TABLE 2
Calculated Wastewater Loading by Basin

| | Calculated Basin-Wide Loading Rate (gpd/acre) | Basin Area (acres) | Flow (gpd) |
|---------------------------------|---|--------------------|------------|
| Average Dry Weather Flow | | | |
| Basin 1 (with LAMIRD) | 718 | 499 | 358,300 |
| Basin 2 | 718 | 176 | 126,400 |
| Basin 3 | 718 | 143 | 103,700 |
| Total | | | 588,400 |
| Peak Day Flow | | | |
| Basin 1 | 1,233 | 499 | 615,300 |
| Basin 2 | 1,233 | 176 | 217,000 |
| Basin 3 | 1,233 | 143 | 176,300 |
| Total | | | 1,008,600 |

Peaking Factor

In the Basin Study, a peak hour to peak daily flow peaking factor of 1.7 was applied to the Peak Day Flow to determine peak hourly flow for each basin. The Basin Study stated that this factor was adjusted upward from a factor of 1.27 that was applied in the hydraulic modeling for the Comprehensive Plan. In the Comprehensive Plan, a diurnal curve was presented from flow monitoring in a residential area. This curve (Figure 5-2) indicated that the peak flow may be 1.79 times higher at the peak hour than the average. The Comprehensive Plan also notes that this diurnal curve is slightly conservative for non-residential areas.

According to the Department of Ecology, Criteria for Sewage Works Design (Orange Book), the minimum peaking factor that should be used to calculate peak hourly flow is 2.5, and the peak hour factor is based upon population. In addition, for the Orange Book methodology, the peaking factor is to be applied to the average daily flow, not the peak daily flow.

Peak Hourly Flow

A comparison was performed on the two different calculation methods of the peak hourly flow. This is summarized in Table 3. For the Basin Plan flows, the effective peak hour to average day peaking factor was determined to be 2.92. This peaking factor corresponds to a town with a population of approximately 11,000. The Orange Book calculated peaking factor is 2.59, assuming a population of approximately 23,000 for 2046, the year of the projected ultimate flows. See Figure C1.1 from the Orange Book (attached). Cities with smaller populations are assigned a higher peaking factor due to the nature of the variability of flow with smaller populations. According to the City of Port Townsend Comprehensive Plan, the City's population is expected to reach a population of about 14,000 in the year 2024 and may reach 23,000 by 2046

TABLE 3
Calculated Wastewater Loading by Basin (2047)

| | Row | Basin Plan Calculation | Orange Book Calculation |
|---|--------------------------|------------------------|-------------------------|
| Average Dry Weather Flow (gpd) | (1) | 588,400 | 588,400 |
| Peak Day Flow (gpd) | (2) | 1,008,600 | 1,008,600 |
| Calculated Peak Day to Average Day Peaking Factor | (3) = (2)/(1) | 1.71 | NA ¹ |
| Peak Hour to Peak Day Factor | (4) | 1.70 | NA ¹ |
| Calculated Peak Hour to Average Day Factor | (5) = (4) x (3) | 2.91 | 2.59 ² |
| Peak Hour Flow (gpd) | (6) = (1) x (5) | 1,714,620 | 1,524,935 |
| Calculated Peak Hourly Flow (gpm) | (7) = (6) / 1440 min/day | 1,191 | 1,059 |

¹Not applicable for this comparison. Only comparing the Peak Hour to Average Day Factor (Row (5))


²Calculation of Peak Hour to Average Day Factor from the Orange Book = $(18 + \sqrt{23,000}) / (4 + \sqrt{23,000})$, where 23,000 is the population in 2046.

Selection of Peak Hourly (Design) Flow


The peak hourly flow will be used for sizing and design of the Mill Road Pump Station. Based on the comparison of the various calculation methods to determine the peak hourly flow for design of the Mill Road Pump Station, it is recommended that the peak hourly flow of 1,185 gpm be used for the design.

Appendix B:
***Pump Curves for Submersible and Suction Lift
Pumps***

NP 3315 HT 3~ 456
Technical specification



Curve according to: ISO 9906 grade 2 annex 1 or 2



Note: Picture might not correspond to the current configuration.

General

Patented self cleaning semi-open channel impeller, ideal for pumping in waste water applications. Possible to be upgraded with Guide-pin® for even better clogging resistance. Modular based design with high adaptation grade.

Impeller


| | |
|-------------------|----------------|
| Impeller material | Grey cast iron |
| Outlet width | 5 7/8 inch |
| Inlet diameter | 150 mm |
| Impeller diameter | 390 mm |
| Number of blades | 3 |

Motor

| | |
|------------------|-----------------------------|
| Motor # | N3315.180 35-35-4AA-W 130hp |
| Stator v variant | |
| Frequency | 60 Hz |
| Rated v voltage | 460 V |
| Number of poles | 4 |
| Phases | 3~ |
| Rated power | 130 hp |
| Rated current | 156 A |
| Starting current | 705 A |
| Rated speed | 1775 1/min |
| Power factor | |
| 1/1 Load | 0.83 |
| 3/4 Load | 0.80 |
| 1/2 Load | 0.71 |
| Efficiency | |
| 1/1 Load | 93.5 % |
| 3/4 Load | 94.0 % |
| 1/2 Load | 94.5 % |

Configuration

Installation: P - Semi permanent, Wet



NP 3315 HT 3~ 456

Performance curve




Pump

Outlet width 5 7/8 inch
Inlet diameter 150 mm
Impeller diameter 15 3/8"
Number of blades 3

Motor


Motor # N3315.180 35-35-4AA-W 130hp
Stator variant
Frequency 60 Hz
Rated voltage 460 V
Number of poles 4
Phases 3~
Rated power 130 hp
Rated current 156 A
Starting current 705 A
Rated speed 1775 1/min

Power factor
1/1 Load 0.83
3/4 Load 0.80
1/2 Load 0.71
Efficiency
1/1 Load 93.5 %
3/4 Load 94.0 %
1/2 Load 94.5 %



Curve according to: ISO 9906 grade 2 annex 1 or 2


NP 3315 HT 3~ 456
Duty Analysis



| Pumps running /System | Individual pump | | | Total | | | Hyd eff. | Specific energy | NPSH _{re} |
|-----------------------|-----------------|--------|-------------|----------------|--------|-------------|----------|-----------------|--------------------|
| | Flow | Head | Shaft power | Flow | Head | Shaft power | | | |
| 1 | 1170 US g.p.m. | 243 ft | 116 hp | 1170 US g.p.m. | 243 ft | 116 hp | 62% | 1310 kWh/US MG | 11.4 ft |

| | | | | |
|---------|------------|------------|--------------------------|-------------|
| Project | Project ID | Created by | Created on 2012-04-13 | Last update |
|---------|------------|------------|--------------------------|-------------|


NP 3315 HT 3~ 456
VFD Curve



Curve according to: ISO 9906 grade 2 annex 1 or 2


| | | | | |
|---------|------------|------------|------------|-------------|
| Project | Project ID | Created by | Created on | Last update |
| | | | 2012-04-13 | |

NP 3315 HT 3~ 456
VFD Analysis



| Pumps running /System | Individual pump | | | Total | | | | | Specific energy | NPSHre |
|-----------------------|-----------------|----------------|--------|-------------|----------------|--------|-------------|-----------|------------------------|--------|
| | Frequency | Flow | Head | Shaft power | Flow | Head | Shaft power | Hyd. eff. | | |
| 1 | 60 Hz | 1170 US g.p.m. | 243 ft | 116 hp | 1170 US g.p.m. | 243 ft | 116 hp | 62 % | 1310 kWh/US MG 11.4 ft | |
| 1 | 55 Hz | 1080 US g.p.m. | 205 ft | 90.3 hp | 1080 US g.p.m. | 205 ft | 90.3 hp | 62 % | 1100 kWh/US MG 9.96 ft | |
| 1 | 50 Hz | 980 US g.p.m. | 169 ft | 67.8 hp | 980 US g.p.m. | 169 ft | 67.8 hp | 62 % | 908 kWh/US MG 8.55 ft | |
| 1 | 45 Hz | 882 US g.p.m. | 137 ft | 49.4 hp | 882 US g.p.m. | 137 ft | 49.4 hp | 62 % | 738 kWh/US MG 7.22 ft | |
| 1 | 40 Hz | 784 US g.p.m. | 108 ft | 34.7 hp | 784 US g.p.m. | 108 ft | 34.7 hp | 62 % | 589 kWh/US MG 5.98 ft | |

NP 3315 HT 3~ 456
Dimensional drawing



Project

Project ID

Created by

Created on
2012-04-13

Last update

Pump ESP™

Smith & Loveless' Electronic Selection Program



Smith & Loveless Inc.

14040 Santa Fe Trail Drive • Lenexa, Kansas 66215-1284 • Ph: 913-888-5201 • Fax: 913-888-2173 • answers@smithandloveless.com

Location: **Kitsap Co** Project Name: **Future**
 Customer: **Kitsap Co** Engineer: **CH2M-Hill**
 Inquiry #: WW Diam: **12** Type: **Classic** Pumps: **Duplex**

Design Data: Flow: **1200 GPM** **Force Main Data:** Force main length: System Head (Max) C-Factor: Static Head Max: System Head Max: **N/A**
 Sta. piping size: **8"** Force main Dia.: C-Factor: Static Head Min: System Head Min: **N/A**
 Suction Piping Size: **12"** Force Main Vel: **N/A** System Head (Min) System Head Min: **N/A**
 TDH: **229 FT.**

875 RPM Pumps:

| | IMP. DIA. | BHP | EFF. | Suction Piping | | Station Piping | | Max Suction Lift |
|---------|-----------|-----|------|----------------|--------|----------------|--------|------------------|
| | | | | Recom. | Select | Recom. | Select | |
| ○ 4B2B | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 4B2X | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 6B3B | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 8D4D | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 8D4V | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 12D6V | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

Notes:
 1.) Max Suction lift is based on an elevation of 1000' ASL. For each 1000 foot increment, subtract an additional foot.
 Max Suction Lift of pump must equal or exceed Required Suction Lift

1170 RPM Pumps:

| | IMP. DIA. | BHP | EFF. | Suction Piping | | Station Piping | | Max Suction Lift |
|---------|-----------|-----|------|----------------|--------|----------------|--------|------------------|
| | | | | Recom. | Select | Recom. | Select | |
| ○ 4B2B | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 4B2D | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 4B2X | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 4B3B | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 6B3B | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 8D4D | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 8D4V | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 12D6V | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |

1760 RPM Pumps:

| | IMP. DIA. | BHP | EFF. | Suction Piping | | Station Piping | | Max Suction Lift |
|--------|-----------|-------|-------|----------------|--------|----------------|--------|------------------|
| | | | | Recom. | Select | Recom. | Select | |
| ○ 4B2B | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 4B2D | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 4B2X | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 4B3B | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 4D4B | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ○ 6C3B | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| ● 8D4V | 14 5/8" | 121.8 | 57.0% | 8" | 12" | 8" | 8" | 19.4 FT. |

585 RPM Pump:

| | | | | | | | | |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|
| ○ 12D6V | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
|---------|-----|-----|-----|-----|-----|-----|-----|-----|

Only stations with 8" or 12" pumps are available with 8" or larger station and discharge piping.

Representative: ADS Equipment, Inc


Prepared By: Steve Azose

Date: 4/8/2012

Pump Curve





Smith & Loveless Inc.



Appendix C:
Pump Station Force Main Alignment

PORT TOWNSEND MILL ROAD PUMP STATION AND FORCEMAIN PORT TOWNSEND, WASHINGTON



| INDEX OF DRAWINGS | | |
|-------------------|-------------|--|
| SHEET NO. | DRAWING NO. | TITLE |
| GENERAL | | |
| 1 | G-01 | TITLE SHEET, INDEX OF DRAWINGS AND PROJECT LOCATION MAPS |
| CIVIL | | |
| 2 | C-01 | FORCEMAIN ALIGNMENT PLAN AND PROFILE |
| 3 | C-02 | FORCEMAIN ALIGNMENT PLAN AND PROFILE |
| 4 | C-03 | FORCEMAIN ALIGNMENT PLAN AND PROFILE |
| 5 | C-04 | FORCEMAIN ALIGNMENT PLAN AND PROFILE |
| 6 | C-05 | FORCEMAIN ALIGNMENT PLAN AND PROFILE |
| 7 | C-06 | FORCEMAIN ALIGNMENT PLAN AND PROFILE |
| 8 | C-07 | FORCEMAIN ALIGNMENT PLAN AND PROFILE |
| 9 | C-08 | FORCEMAIN ALIGNMENT PLAN AND PROFILE |
| 10 | C-09 | FORCEMAIN ALIGNMENT PLAN AND PROFILE |
| 11 | C-10 | PUMP STATION SITE PLAN |

| NO. | DATE | DSGN | CHK | REVISION | BY | APVD |
|-----|------|------|-----|----------|----|------|
| | | | | | | |



PORT TOWNSEND
MILL ROAD PUMP STATION
AND FORCEMAIN
PORT TOWNSEND, WA

CH2MHILL
GENERAL
TITLE SHEET, INDEX OF DRAWINGS
AND PROJECT LOCATION MAPS

| | |
|-------------------------------------|--------------|
| VERIFY SCALE | |
| BAR IS ONE INCH ON ORIGINAL DRAWING | |
| DATE | OCTOBER 2012 |
| PROJ | 425179 |
| DWG | G-01 |
| SHEET | 1 of 5 |

30% Design - Not For Construction

REUSE OF DOCUMENTS: THIS DOCUMENT, AND THE IDEAS AND DESIGNS INCORPORATED HEREIN, AS AN INSTRUMENT OF PROFESSIONAL SERVICE, IS THE PROPERTY OF CH2MHILL AND IS NOT TO BE USED, IN WHOLE OR IN PART, FOR ANY OTHER PROJECT WITHOUT THE WRITTEN AUTHORIZATION OF CH2MHILL. © CH2M HILL 2008. ALL RIGHTS RESERVED.



PROFILE

1"=20' HORIZ, 1"=5' VERT

CH2MHILL

CIVIL
**FORCEMAIN ALIGNMENT
 PLAN AND PROFILE**


PORT TOWNSEND
 MILL ROAD PUMP STATION
 AND FORCEMAIN
 PORT TOWNSEND, WA

| NO. | DATE | DR | CHK | APVD | BY | APVD |
|------|------|-----------|-----------|----------|----------|------|
| D5GN | | A. ROSHAK | D SUNSERI | J BURNAM | J BURNAM | |


30% Design - Not For Construction

FILENAME: C-001_425179.dgn PLOT DATE: 2012/10/09

| | |
|-------|--------------|
| DATE | OCTOBER 2012 |
| PROJ | 425179 |
| DWG | C-01 |
| SHEET | |



PLAN
1"=20'



PROFILE
1"=20' HORIZ, 1"=5' VERT

30% Design - Not For Construction

FILENAME: C-002_425179.dgn PLOT DATE: 2012/10/09



CH2MHILL

CIVIL
FORCEMAIN ALIGNMENT
PLAN AND PROFILE

PORT TOWNSEND
MILL ROAD PUMP STATION
AND FORCEMAIN
PORT TOWNSEND, WA

| NO. | DATE | REVISION | BY | APVD |
|------|------|----------|----------|----------|
| DSGN | | CHK | J BURNAM | J BURNAM |
| DR | | CHK | J BURNAM | J BURNAM |
| | | CHK | J BURNAM | J BURNAM |
| | | CHK | J BURNAM | J BURNAM |

| | |
|-------|--------------|
| DATE | OCTOBER 2012 |
| PROJ | 425179 |
| DWG | C-02 |
| SHEET | |



| NO. | DATE | REVISION | BY | APVD |
|-----|------|----------|----|------|
| | | | | |
| | | | | |
| | | | | |

CH2MHILL

CIVIL

**FORCEMAIN ALIGNMENT
PLAN AND PROFILE**


PORT TOWNSEND
MILL ROAD PUMP STATION
AND FORCEMAIN

PORT TOWNSEND, WA


| | |
|-------|--------------|
| DATE | OCTOBER 2012 |
| PROJ | 425179 |
| DWG | C-03 |
| SHEET | |

30% Design - Not For Construction

FILENAME: C-003_425179.dgn PLOT DATE: 20121109



PLAN
1"=20'



PROFILE
1"=20' HORIZ, 1"=5' VERT

30% Design - Not For Construction

FILENAME: C-004_425179.dgn PLOT DATE: 2012/10/09





CIVIL
PORT TOWNSEND
MILL ROAD PUMP STATION
AND FORCEMAIN
PLAN AND PROFILE

PORT TOWNSEND
MILL ROAD PUMP STATION
AND FORCEMAIN
PORT TOWNSEND, WA

| NO. | DATE | DR | CHK | APVD | BY | APVD |
|-----|------|-----------|-----------|----------|----------|------|
| 1 | | A. ROSHAK | D SUNSERI | J BURNAM | J BURNAM | |

| | |
|------------|--------------|
| DATE | OCTOBER 2012 |
| PROJ | 425179 |
| DWG | C-04 |
| SHEET | |
| PLOT TIME: | 9:34:54 AM |



| NO. | DATE | REVISION | BY | APVD |
|-----|------|----------|----|------|
| | | | | |
| | | | | |
| | | | | |
| | | | | |


DSGN: A. ROSHAK DR: D. SUNSERI CHK: J. BURNAM APVD: J. BURNAM
 PRELIMINARY

CH2MHILL
 CIVIL
**FORCEMAIN ALIGNMENT
 PLAN AND PROFILE**

PORT TOWNSEND
 MILL ROAD PUMP STATION
 AND FORCEMAIN
 PORT TOWNSEND, WA


VERIFY SCALE
 BAR IS ONE INCH ON
 ORIGINAL DRAWING.
 DATE: OCTOBER 2012
 PROJ: 425179
 DWG: C-06
 SHEET:

30% Design - Not For Construction
 FILENAME: C-005_425179.dgn PLOT DATE: 2012/10/09



PLAN
1"=20'

NOTE:
RIGHT OF WAY CENTERLINE OF THOMAS ST. DETERMINED PER EASTVIEW INDUSTRIAL PLAT FILED UNDER VOL. 6 OF PLATS, PAGE 58.
RIGHT OF WAY WIDTH ALONG THOMAS STREET DETERMINED PER DEED CLAIM DEED FILED UNDER VOL. 140, PAGE 93, RECORDS OF VENTRECON COUNTY, WA.



PROFILE
1"=20' HORIZ, 1"=5' VERT

PROFILE
1"=20' HORIZ, 1"=5' VERT

30% Design - Not For Construction

FILENAME: C-006_425179.dgn PLOT DATE: 2012/10/09

| | |
|-----------|--------------|
| DATE | OCTOBER 2012 |
| PROJ | 425179 |
| DWG | C-06 |
| SHEET | |
| PLOT TIME | 9:55:17 AM |

CH2MHILL


CIVIL

**FORCEMAIN ALIGNMENT
PLAN AND PROFILE**

PORT TOWNSEND
MILL ROAD PUMP STATION
AND FORCEMAIN

PORT TOWNSEND, WA

| NO. | DATE | REVISION | BY | APVD |
|------|-----------|------------|-----------|-----------|
| DSGN | | | | |
| DR | | | | |
| CHK | | | | |
| APVD | | | | |
| | A. ROSHAK | D. SUNSERI | J. BURNAM | J. BURNAM |



MATCH LINE - SEE DWG C-08


PLAN
1"=20'

FOR TOWNSEND
PAPER CORP.

WORKM
30' (80%)

LOT 5
101

| NO. | DATE | REVISION | BY | APVD |
|------|------|-----------|----|------|
| DSGN | | A. ROSHAK | | |
| DR | | D SUNSERI | | |
| CHK | | J BURNAM | | |
| APVD | | J BURNAM | | |



MATCH LINE - SEE DWG C-08

MATCH LINE - SEE DWG C-06

PROFILE
1"=20' HORIZ, 1"=5' VERT

PROFILE
1"=20' HORIZ, 1"=5' VERT



30% Design - Not For Construction
FILENAME: C-007_425179.dgn PLOT DATE: 2012/10/09

CH2MHILL

CIVIL
FORCEMAIN ALIGNMENT
PLAN AND PROFILE

PORT TOWNSEND
MILL ROAD PUMP STATION
AND FORCEMAIN
PORT TOWNSEND, WA

| | |
|--------------|-------------------------------------|
| VERIFY SCALE | BAR IS ONE INCH ON ORIGINAL DRAWING |
| DATE | OCTOBER 2012 |
| PROJ | 425179 |
| DWG | C-07 |
| SHEET | |
| PLOT TIME: | 9:58:29 AM |



PROFILE
1"=20' HORIZ, 1"=5' VERT

PROFILE
1"=20' HORIZ, 1"=5' VERT

30% Design - Not For Construction




FILENAME: C-008_425179.dgn PLOT DATE: 2012/10/09

CH2MHILL

CIVIL
FORCEMAIN ALIGNMENT
PLAN AND PROFILE

PORT TOWNSEND
MILL ROAD PUMP STATION
AND FORCEMAIN
PORT TOWNSEND, WA

| NO. | DATE | DR | CHK | APVD | BY | APVD |
|------|------|-----------|-----------|----------|----------|------|
| DSGN | | A. ROSHAK | D SUNSERI | J BURNAM | J BURNAM | |



30% Design - Not For Construction

FILENAME: C-009_425179.dgn PLOT DATE: 2012/10/09

CH2MHILL

CIVIL
**FORCEMAIN ALIGNMENT
PLAN AND PROFILE**



PORT TOWNSEND
MILL ROAD PUMP STATION
AND FORCEMAIN
PORT TOWNSEND, WA

| | | | | | | |
|-----|------|-----------|-----------|----------|----------|------|
| NO. | DATE | DR | CHK | APVD | BY | APVD |
| | | A. ROSHAK | D SUNSERI | J BURNAM | J BURNAM | |

REUSE OF DOCUMENTS: THIS DOCUMENT, AND THE IDEAS AND DESIGNS INCORPORATED HEREIN, AS AN INSTRUMENT OF PROFESSIONAL SERVICE, IS THE PROPERTY OF CH2M HILL AND IS NOT TO BE USED, IN WHOLE OR IN PART, FOR ANY OTHER PROJECT WITHOUT THE WRITTEN AUTHORIZATION OF CH2M HILL.

© CH2M HILL 2009. ALL RIGHTS RESERVED.

| | |
|------------|--------------|
| DATE | OCTOBER 2012 |
| PROJ | 425179 |
| DWG | C-09 |
| SHEET | |
| PLOT TIME: | 10:16:29 AM |



30% Design - Not For Construction
 FILENAME: C-011_425179.dgn PLOT DATE: 2012/10/09

| | | | | | | | | | |
|---|--|--|--|------------------|--|----------------|--|---------------------|--|
| CH2MHILL CIVIL PUMP STATION SITE PLAN | | PORT TOWNSEND MILL ROAD PUMP STATION AND FORCE MAIN PORT TOWNSEND, WA | | NO. DATE DSGN | | REVISION DR | | BY APVD J BURNAM | |
| | | VERIFY SCALE BAR IS ONE INCH ON ORIGINAL DRAWING. DATE OCTOBER 2012 PROJ 425179 DWG C-10 SHEET | | A. ROSHAK | | D SUNSERI | | J BURNAM | |

REUSE OF DOCUMENTS: THIS DOCUMENT, AND THE IDEAS AND DESIGNS INCORPORATED HEREIN, AS AN INSTRUMENT OF PROFESSIONAL SERVICE, IS THE PROPERTY OF CH2M HILL AND IS NOT TO BE USED, IN WHOLE OR IN PART, FOR ANY OTHER PROJECT WITHOUT THE WRITTEN AUTHORIZATION OF CH2MHILL. ©CH2M HILL 2009. ALL RIGHTS RESERVED.

Appendix D:
Cost Estimate

MEMORANDUM

CH2MHILL

City of Port Townsend

Mill Road Pump Station & Force Main

Construction Cost Estimate

PREPARED FOR: Jack Burnam/SEA

PREPARED BY: Craig Moore/SEA

DATE: July 17, 2012

PROJECT NUMBER: 425179

Purpose

The purpose of this memorandum is to document the cost estimating methodology and assumptions used in preparing the Schematic Design construction cost estimate for the Port Townsend Pump Station and Force Main. The basis of this cost estimate is summarized below:

| | |
|---------------------------------------|-----------------------------------|
| Original Estimate Date: | May 23, 2012 |
| Revision: | July 17, 2012 |
| Construction Cost Index (CCI) Number: | Seattle ENR CCI (April 2012) 9056 |
| Estimate Type: | 15% Estimate (Class 3) |
| Accuracy Level: | +30% to -20% |

The following memorandum provides a description of the cost estimating methodology, overall costs, markups, assumptions, productivity rates, cost basis, and excluded costs.

Summary of Costs

The following is a summary of the estimate costs. The base construction cost shown includes mobilization, bonds, contingency and escalation. It does not include project costs such as design, administrative, legal, or services during construction. See the attached estimate for a breakdown of the costs included in the estimate.

Option Costs

| | Low Range | Estimate Range | High Range |
|--|-------------|----------------|-------------|
| | -20% | Base Cost | +30% |
| Submersible Pump Station & Force Main | \$1,633,000 | \$2,041,000 | \$2,653,000 |
| Suction Lift Pump Station & Force Main | \$1,702,000 | \$2,127,000 | \$2,765,000 |
| Force Main | \$882,000 | \$1,102,000 | \$1,433,000 |
| Gravity Pipe Alt 1 | \$306,000 | \$383,000 | \$498,000 |
| Gravity Pipe Alt 2 | \$394,000 | \$492,000 | \$640,000 |
| Gravity Pipe Common Alt 1 & 2 | \$542,000 | \$678,000 | \$881,000 |
| Gravity Pipe Alt 3 | \$170,000 | \$213,000 | \$277,000 |
| Gravity Pipe Common Alt 1, 2 & 3 | \$43,000 | \$54,000 | \$70,000 |
| Gravity Pipe Alt 4 | \$674,000 | \$843,000 | \$1,096,000 |

Methodology

This cost estimate is considered a Schematic Design Estimate (Class 3) construction cost estimate. It is based upon the 15 percent design drawings and specification dated May 2012, and design information provided by the engineer at the time of the estimate.

Where possible, a quantity takeoff was developed for all elements shown in sufficient detail in the design drawings or described in the report. For an item known to exist but not defined in the project drawings, the cost estimator applied an allowance based on estimator experience and consultation with the project engineer.

The final costs of the project will depend on actual labor and material costs at the time of bid, actual site conditions, productivity, competitive market conditions, final project scope, final schedule and other variable factors. As a result, the final project costs will vary from those presented herein. Because of these factors, funding needs must be carefully reviewed prior to making specific financial decisions or establishing final budgets.

Markups

Table 1 summarizes various markups applied to the cost estimate to develop the overall construction cost. Unit costs include contractor overhead and profit. Mobilization, contingency, sales tax, market factor and escalation are also applied to the bottom line totals.

TABLE 1
Markup Summary

| Markup | Percentage |
|--|------------|
| Contractor Overhead & Profit (In unit costs) | 18% |
| General Conditions | 7% |
| Mobilization/Bonds/Insurance | 5.16% |
| Construction Cost Estimate Contingency | 40% |
| Escalation (Aug 2013) | 3.58% |
| Sales Tax (Port Townsend) | 9% |
| Market Conditions | 0% |

Assumptions

The following assumptions were used to develop the construction cost estimate:

General Assumptions:

1. Labor rates are based on the RS Means National Average Rate and adjusted for local wage rates using the RS Means regional adjustment factor.
2. The estimate currently includes escalation to mid-point of construction to August 2013.
3. Costs assume that the work is done during a regular 40 hour work week and does not include any overtime cost markups.
4. Costs do not include purchase of easements or right-of-way, engineering, administration or owner costs beyond the capital construction costs. The cost estimate is intended to represent the total contractor bid price as shown on the bid price schedule at the time of the bid opening.
5. Site access for the contractor and contractor staging areas are assumed to be adequate for the contractors needs.
6. The estimate is based on aggregates, drain sand, and clay materials being available locally to the contractor.
7. Temporary erosion and sediment control are expected to be minor. No wetland impacts are known at this time.
8. Pipe trenching is based on 5' of cover to the top of the pipe.

9. It is assumed that dewatering for pipe trenching can be controlled with sump pumps in trench.
10. Roadway patching is based on 6" of asphalt over 6" of crushed surface base course.
11. The pump station wet well construction is based on a dropped caisson construction.
12. Due to the pump cooling requirements the submersible pump station wet well is 30" deeper than the suction lift pump station.
13. The pipe alternatives costs with the exception of Alternative 3 are based on the pipeline being placed in the roadway and include ACP demo and patching. Alternative 3 is outside of the roadway and travels cross country.
14. The revision adds a 350 KW emergency generator to the pump station and adds VFDs to the pumps.

Productivity Rates

The following assumptions were used in determining the Productivity Rates:

1. Contractor production rates for installation of standard items are taken from RS Means or are per the RS Means database and are based on 40 work weeks.
2. For equipment installation or non-standard items, production rates are per the cost estimator's best judgment based on experience and consultation with the design engineer.

Cost Basis

Various sources of cost data were used to develop this construction cost estimate. Construction costs were taken from RS Means Construction Cost Data. When applicable, recent bid tab information was used to establish costs for bid items.

Cost Quote

Cost quotes were received on the following items:

- Flygt 160 hp submersible pump from Whitney Equipment Comp Inc, 5/22/12
- Smith & Loveless lift pump from ADS Equipment Inc, 4/8/12

Excluded Costs

Construction costs do not include engineering, construction management, land acquisition (ROW) costs, hazardous materials mitigation, permitting, operations & maintenance costs or the client's financial, legal or administration costs.

**Port Townsend Mill Rd Pump Station, Submersable, Port Townsend, WA
WW Pump Station, Schematic, 15% Design
425179, Rev 1**

| | |
|-----------------------------|--|
| Project name | Port Townsend PS Sub Port Townsend WA |
| Estimator | C Moore/SEA |
| Labor rate table | 2_AA04 (2012) |
| Equipment rate table | 1_EqRates_2011_75% |
| Job size | 1 LS |
| Project | Port Townsend PS |
| Project Number | 425179 |
| Market Segment | Wastewater Pump Stat |
| Business Group | WBG |
| Project Conditions | New |
| Estimate Class 1-5 | 3 |
| Estimate Category | Consult Engineer Est |
| Design Stage | Schematic Design |
| Project Manager | J Burnam |
| Rev No. / Date | 1/7-17-12 |
| Report format | Sorted by 'Facility/Work Pkg/Trade Pkg/WorkActiv/Unit Price' 'Detail' summary Allocate addons Combine items |

Detail Report

Project: Port Townsend PS Sub
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date: 1/7-17-12
Estimate Class: 3

| Fac | Work Pkg | Trade Pkg | Work Activity | Unit Price | Description | Takeoff Quantity | Labor Man Hrs | Labor Amount | Material Amount | Sub Amount | Equip Amount | Other Amount | Total Cost/Unit | Total Amount |
|-----|----------|-----------|---------------|-------------|---|------------------|---------------|--------------|-----------------|---------------|--------------|--------------|-----------------|---------------|
| 06 | | | | | SITEWORK | | | | | | | | | |
| | 31.0 | | | | Site/Civil | | | | | | | | | |
| | | 31-20 | | | Earthworks, Site | | | | | | | | | |
| | | | CJM-005 | | Sitework | | | | | | | | | |
| | | | | 31-15-01-00 | Site Preparation, Clearing and Grubbing | | | | | | | | | |
| | | | | | Clearing, Tree Removal, 6" - 12", Acre | 0.20 acre | 32.0 | - | - | 1,238 | - | - | 6,188.65 /acre | 1,238 |
| | | | | | Finish grading area to be paved with grader, small area | 733.00 sy | 29.3 | 2,020 | - | - | 2,527 | - | 6.20 /sy | 4,546 |
| | | | | | Compact Building Pads, Equipment Pads, and Misc. Out Structures | 733.00 sy | 8.1 | 547 | - | - | 383 | - | 1.27 /sy | 930 |
| | | | | | 31-15-01-00 Site Preparation, Clearing and Grubbing | 1.00 LS | 69.5 | 2,566 | - | 1,238 | 2,910 | - | 6,713.96 /LS | 6,714 |
| | | | | 31-40-02-00 | Site Improvements, Paving, Bituminous Asphalt | | | | | | | | | |
| | | | | | Bituminous Pavement Subgrade Prep | 733.00 sy | 6.6 | - | - | 1,361 | - | - | 1.86 /sy | 1,361 |
| | | | | | Bituminous Pavement Import Aggregate Base | 208.00 tn | 2.7 | 7,981 | - | - | - | - | 38.37 /tn | 7,981 |
| | | | | | Bituminous Asphalt (tn), 4" | 168.00 tn | 1.3 | - | - | 20,794 | - | - | 123.77 /tn | 20,794 |
| | | | | | 31-40-02-00 Site Improvements, Paving, Bituminous Asphalt | 733.00 SY | 10.6 | - | - | 30,136 | - | - | 41.11 /SY | 30,136 |
| | | | | 31-45-01-00 | Fencing, Chain Link | | | | | | | | | |
| | | | | | Security Fence, Chain Link, 8' | 350.00 lf | 45.5 | - | - | 10,830 | - | - | 30.94 /lf | 10,830 |
| | | | | | Fence Security Signage | 8.00 ea | 8.0 | - | - | 1,465 | - | - | 185.66 /ea | 1,465 |
| | | | | | Fence, double swing gates, 8' high, 12' opening | 1.00 opng | 15.0 | 911 | 637 | - | 26 | - | 1,574.77 /opng | 1,575 |
| | | | | | 31-45-01-00 Fencing, Chain Link | 350.00 LF | 68.5 | 911 | 637 | 12,315 | 26 | - | 39.69 /LF | 13,890 |
| | | | | | CJM-005 Sitework | | 148.6 | 3,477 | 637 | 43,689 | 2,937 | - | | 50,740 |
| | | | | | 31-20 Earthworks, Site | 1.00 LS | 148.6 | 3,477 | 637 | 43,689 | 2,937 | - | 50,739.64 /LS | 50,740 |
| | | | | | 31.0 Site/Civil | 1.00 LS | 148.6 | 3,477 | 637 | 43,689 | 2,937 | - | 50,739.64 /LS | 50,740 |
| | | | | | 06 SITEWORK | | 148.6 | 3,477 | 637 | 43,689 | 2,937 | - | | 50,740 |
| 07 | | | | | YARD PIPING | | | | | | | | | |
| | 33.0 | | | | Buried Piping | | | | | | | | | |
| | | 33-00 | | | Yard Piping | | | | | | | | | |
| | | | CJM-004 | | Yard Piping | | | | | | | | | |
| | | | | 33-00-07-10 | Yard Pipe, PVC, 10" | | | | | | | | | |
| | | | | | Trench Box, 8' x 24' x 10' | 0.25 mo | - | - | - | - | 712 | - | 2,846.76 /mo | 712 |
| | | | | | Excav. pipe trench, w/ 1:1 slopes, for 4" - 24" pipe | 41.66 CY | 1.2 | 85 | - | - | 106 | - | 4.58 /CY | 191 |
| | | | | | Backfill / Compact @ pipe zone, for 4" thru 24" pipe | 9.47 cy | 1.3 | 85 | - | - | 55 | - | 14.78 /cy | 140 |
| | | | | | Backfill / Compact above pipe zone, for 4" thru 24" pipe | 33.02 cy | 1.0 | 73 | - | - | 60 | - | 4.02 /cy | 133 |
| | | | | | Pipe zone material | 9.47 cy | - | - | 328 | - | - | - | 34.66 /cy | 328 |
| | | | | | Pipe bedding material | 2.86 cy | - | - | 99 | - | - | - | 34.66 /cy | 99 |
| | | | | | Imported backfill material | 33.02 cy | - | - | 490 | - | - | - | 14.85 /cy | 490 |
| | | | | | Haul spoils, offsite, up to 10 miles | 12.33 cy | - | - | - | 153 | - | - | 12.38 /cy | 153 |
| | | | | | Dump fees, trench spoils | 12.33 cy | - | - | 76 | - | - | - | 6.19 /cy | 76 |
| | | | | | 10" DI, MJ, Ell, 90 | 1.00 ea | 4.2 | 357 | 388 | - | 174 | - | 919.19 /ea | 919 |
| | | | | | 10" DI, MJ, Ell, 45 | 2.00 ea | 8.4 | 714 | 633 | - | 348 | - | 847.71 /ea | 1,695 |
| | | | | | 10" DI, MJ, tee | 1.00 ea | 5.8 | 493 | 633 | - | 240 | - | 1,366.61 /ea | 1,367 |
| | | | | | FURNISH PVC water distribution pipe, C-900, class 150, DR 18, 10" | 45.00 LF | - | - | 847 | - | - | - | 18.83 /LF | 847 |
| | | | | | Install PVC water distribution pipe, excav/bkfill NOT included, 10" | 45.00 LF | 6.8 | 582 | - | - | 283 | - | 19.22 /LF | 865 |
| | | | | | Pipe Marking, ID Tape | 45.00 lf | 0.5 | 41 | 7 | - | - | - | 1.08 /lf | 49 |
| | | | | | 33-00-07-10 Yard Pipe, PVC, 10" | 45.00 LF | 29.1 | 2,431 | 3,503 | 153 | 1,978 | - | 179.20 /LF | 8,064 |
| | | | | 33-00-07-12 | Yard Pipe, PVC, 12" | | | | | | | | | |
| | | | | | Trench Box, 8' x 24' x 10' | 0.25 mo | - | - | - | - | 712 | - | 2,846.80 /mo | 712 |
| | | | | | Excav. pipe trench, w/ 1:1 slopes, for 4" - 24" pipe | 30.50 CY | 0.9 | 62 | - | - | 77 | - | 4.58 /CY | 140 |
| | | | | | Backfill / Compact @ pipe zone, for 4" thru 24" pipe | 7.07 cy | 0.9 | 84 | - | - | 41 | - | 14.78 /cy | 105 |
| | | | | | Backfill / Compact above pipe zone, for 4" thru 24" pipe | 23.89 cy | 0.7 | 53 | - | - | 43 | - | 4.02 /cy | 96 |
| | | | | | Pipe zone material | 7.07 cy | - | - | 245 | - | - | - | 34.66 /cy | 245 |
| | | | | | Pipe bedding material | 2.02 cy | - | - | 70 | - | - | - | 34.66 /cy | 70 |
| | | | | | Imported backfill material | 23.89 cy | - | - | 355 | - | - | - | 14.85 /cy | 355 |
| | | | | | Haul spoils, offsite, up to 10 miles | 9.09 cy | - | - | - | 113 | - | - | 12.38 /cy | 113 |
| | | | | | Dump fees, trench spoils | 9.09 cy | - | - | 56 | - | - | - | 6.19 /cy | 56 |
| | | | | | FURNISH PVC water distribution pipe, C-900, class 150, DR 18, 12" | 30.00 LF | - | - | 797 | - | - | - | 26.56 /LF | 797 |
| | | | | | Install PVC water distribution pipe, excav/bkfill NOT included, 12" | 30.00 LF | 5.0 | 429 | - | - | 209 | - | 21.25 /LF | 637 |
| | | | | | Pipe Marking, ID Tape | 30.00 lf | 0.3 | 28 | 5 | - | - | - | 1.08 /lf | 32 |
| | | | | | 33-00-07-12 Yard Pipe, PVC, 12" | 30.00 LF | 7.9 | 635 | 1,528 | 113 | 1,082 | - | 111.90 /LF | 3,357 |
| | | | | 33-15-01-05 | Yard Structures, Manholes, 60" Dia | | | | | | | | | |
| | | | | | Catchbasins, frs and covs, lt traffic, 24" diam, 300 lb. | 1.00 ea | 2.8 | 184 | 292 | - | 86 | - | 561.74 /ea | 562 |
| | | | | | Manholes, concrete, precast, 5' I.D., 8' deep | 1.00 ea | 16.0 | 1,064 | 2,414 | - | 499 | - | 3,977.17 /ea | 3,977 |



CH2MHILL

Detail Report

Job Size: 1 LS
Duration:

Project: Port Townsend PS Sub
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date: 1/7-17-12
Estimate Class: 3

| Fac | Work Pkg | Trade Pkg | Work Activity | Unit Price | Description | Takeoff Quantity | Labor Man Hrs | Labor Amount | Material Amount | Sub Amount | Equip Amount | Other Amount | Total Cost/Unit | Total Amount |
|-----|----------|-----------|---------------|------------|--|------------------|---------------|--------------|-----------------|--------------|--------------|--------------|-------------------|---------------|
| | | | | | 33-15-01-05 Yard Structures, Manholes, 60" Dia | 1.00 EA | 18.8 | 1,248 | 2,706 | | 585 | | 4,538.91 /EA | 4,539 |
| | | | | | 33-20-01-10 Yard Valves, Gate Valves, 10" | | | | | | | | | |
| | | | | | Install gate valve, Flgd, DIP, 10" | 3.00 ea | 15.9 | 1,352 | - | - | 659 | - | 670.28 /ea | 2,011 |
| | | | | | Gate valve, iron body, dbl disk, Flgd, 150#, HWO, 10" | 3.00 ea | | - | 2,321 | - | - | - | 773.58 /ea | 2,321 |
| | | | | | 33-20-01-10 Yard Valves, Gate Valves, 10" | 3.00 EA | 15.9 | 1,352 | 2,321 | | 659 | | 1,443.86 /EA | 4,332 |
| | | | | | CJM-004 Yard Piping | 45.00 LF | 71.6 | 5,665 | 10,057 | 265 | 4,304 | | 450.92 /LF | 20,291 |
| | | | | | 33-00 Yard Piping | 45.00 LF | 71.6 | 5,665 | 10,057 | 265 | 4,304 | | 450.92 /LF | 20,291 |
| | | | | | Yard Structures | | | | | | | | | |
| | | | | | Meter Vault | | | | | | | | | |
| | | | | | 31-25-01-00 Earthworks, Structural, Excavation | | | | | | | | | |
| | | | | | Structural Excavation, Excavator and Trucks, Small Crew, 6' depth | 24.00 cy | 1.3 | 89 | - | - | 81 | - | 7.09 /cy | 170 |
| | | | | | Grade for slabs / Scarify and Recompact, Dozer and Traxcavator or Loader, Small Crew | 7.00 sy | 0.3 | 23 | - | - | 14 | - | 5.21 /sy | 36 |
| | | | | | Import Aggregate Base - under slab, Dozer and Traxcavator or Loader, Small Crew | 4.00 tn | 0.4 | 26 | 99 | - | 15 | - | 35.18 /tn | 141 |
| | | | | | Import Aggregate Base - along walls, Dozer and Traxcavator or Loader, Small Crew | 18.00 tn | 1.7 | 118 | 446 | - | 70 | - | 35.18 /tn | 633 |
| | | | | | Load Excess for Hauling, Rubber Tire Loader, Cat 930 | 24.00 cy | 0.2 | 15 | - | - | 11 | - | 1.07 /cy | 26 |
| | | | | | Haul / Remove Excess, 17 yd capacity, 5 miles RT | 24.00 cy | 0.7 | 41 | - | - | 43 | - | 3.51 /cy | 84 |
| | | | | | Dump Charges for For Excess, 17 yd tandem, per cy | 24.00 cy | | - | 306 | - | - | - | 12.75 /cy | 306 |
| | | | | | 31-25-01-00 Earthworks, Structural, Excavation | 24.00 CY | 4.6 | 312 | 851 | | 234 | | 58.18 /CY | 1,396 |
| | | | | | 33-40-03-01 Pipeline Structures, Vaults | | | | | | | | | |
| | | | | | Meter Vault, 6'x6' x 10' d | 1.00 ls | | | | 8,751 | | | 8,750.73 /ls | 8,751 |
| | | | | | 33-40-03-01 Pipeline Structures, Vaults | 1.00 EA | | | | 8,751 | | | 8,750.73 /EA | 8,751 |
| | | | | | 40-20-19-10 Flow Meter, 10" | | | | | | | | | |
| | | | | | Install magnetic flow meter, 10" | 1.00 ea | 5.3 | 479 | 5,941 | - | - | - | 6,419.76 /ea | 6,420 |
| | | | | | 40-20-19-10 Flow Meter, 10" | 1.00 EA | 5.3 | 479 | 5,941 | | | | 6,419.76 /EA | 6,420 |
| | | | | | CJM-003 Meter Vault | | 9.9 | 791 | 6,792 | 8,751 | 234 | | | 16,567 |
| | | | | | 33-15 Yard Structures | 1.00 EA | 9.9 | 791 | 6,792 | 8,751 | 234 | | 16,566.88 /EA | 16,567 |
| | | | | | 33.0 Buried Piping | 45.00 LF | 81.5 | 6,456 | 16,849 | 9,016 | 4,538 | | 819.07 /LF | 36,858 |
| | | | | | 07 YARD PIPING | | 81.5 | 6,456 | 16,849 | 9,016 | 4,538 | | | 36,858 |
| | | | | | WASTEWATER - PUMP STATION | | | | | | | | | |
| | | | | | Concrete Work | | | | | | | | | |
| | | | | | Cast-In-Place Concrete Work | | | | | | | | | |
| | | | | | Wet Well Concrete | | | | | | | | | |
| | | | | | 03-10-05-12 Cast-In-Place Concrete, Slabs on Grade, 12" thick | | | | | | | | | |
| | | | | | Concrete pumping, subcontract, all inclusive price | 29.80 cy | | - | - | 478 | - | - | 16.05 /cy | 478 |
| | | | | | Slab on grade edge forms, 7" to 12" | 100.50 sf | 18.1 | 1,490 | 134 | - | - | - | 16.16 /sf | 1,624 |
| | | | | | Reinforcing in place, A615 Gr 60, priced per lbs. | 4,469.44 lb | | - | 2,989 | 1,196 | - | - | 0.94 /lb | 4,185 |
| | | | | | Concrete, ready mix, 4000 psi | 29.80 CY | | - | 4,105 | - | - | - | 137.79 /CY | 4,105 |
| | | | | | Add for concrete waste, 4000 psi | 1.49 cy | | - | 205 | - | - | - | 137.79 /cy | 205 |
| | | | | | Add amount for Environmental Fee - per concrete truck load | 4.00 load | | - | 32 | - | - | - | 8.03 /load | 32 |
| | | | | | Placing concrete, concrete pump | 29.80 cy | 22.3 | 1,473 | - | - | - | - | 49.42 /cy | 1,473 |
| | | | | | Finishing floors, monolithic, trowel finish (machine) | 804.50 sf | 16.1 | 1,224 | 22 | - | - | - | 1.55 /sf | 1,245 |
| | | | | | Curing, membrane spray | 804.50 sf | 1.6 | 106 | 43 | - | - | - | 0.19 /sf | 149 |
| | | | | | Concrete Coating, Chemical Resistant, CRC-3 | 804.50 sf | | - | - | 3,229 | - | - | 4.01 /sf | 3,229 |
| | | | | | 03-10-05-12 Cast-In-Place Concrete, Slabs on Grade, 12" thick | 29.80 CY | 58.1 | 4,292 | 7,531 | 4,903 | | | 561.28 /CY | 16,726 |
| | | | | | 03-10-05-24 Cast-In-Place Concrete, Tremie Slab, 24" thick | | | | | | | | | |
| | | | | | Fine grade, for slab on grade, by hand | 804.50 sf | 5.6 | 371 | 11 | - | - | - | 0.48 /sf | 382 |
| | | | | | Concrete pumping, subcontract, all inclusive price | 59.59 cy | | - | - | 957 | - | - | 16.05 /cy | 957 |
| | | | | | Concrete, ready mix, 4000 psi | 59.59 CY | | - | 8,211 | - | - | - | 137.79 /CY | 8,211 |
| | | | | | Add for concrete waste, 4000 psi | 2.98 cy | | - | 411 | - | - | - | 137.78 /cy | 411 |
| | | | | | Add amount for Environmental Fee - per concrete truck load | 7.00 load | | - | 56 | - | - | - | 8.03 /load | 56 |
| | | | | | Placing concrete, concrete pump | 59.59 cy | 44.7 | 2,945 | - | - | - | - | 49.42 /cy | 2,945 |
| | | | | | 03-10-05-24 Cast-In-Place Concrete, Tremie Slab, 24" thick | 59.59 CY | 50.3 | 3,316 | 8,689 | 957 | | | 217.51 /CY | 12,962 |
| | | | | | 03-10-07-24 Cast-In-Place Concrete, Circular Walls, 24" thick | | | | | | | | | |
| | | | | | Concrete pumping, subcontract, all inclusive price | 189.87 cy | | - | - | 3,048 | - | - | 16.05 /cy | 3,048 |
| | | | | | Forms in place, structural walls, to 8' high, hand set | 5,126.40 sf | 769.0 | 63,326 | 6,858 | - | - | - | 13.69 /sf | 70,184 |
| | | | | | Waterstop, PVC, center bulb, 6" wide | 1,281.60 lf | 102.5 | 8,443 | 3,429 | - | - | - | 9.26 /lf | 11,872 |
| | | | | | Speed Dowels, #6 | 1,272.00 ea | | - | 34,032 | - | - | - | 26.76 /ea | 34,032 |
| | | | | | Reinforcing in place, A615 Gr 60, priced per lbs. | 42,720.00 lb | | - | 28,574 | 11,430 | - | - | 0.94 /lb | 40,003 |



CH2MHILL

Detail Report

Job Size: 1 LS
Duration:

Project: Port Townsend PS Sub
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date: 1/7-17-12
Estimate Class: 3

Table with columns: Fac, Work Pkg, Trade Pkg, Work Activity, Unit Price, Description, Takeoff Quantity, Labor Man Hrs, Labor Amount, Material Amount, Sub Amount, Equip Amount, Other Amount, Total Cost/Unit, Total Amount. Rows include various construction items like concrete, rebar, and electrical work.



Job Size: 1 LS
Duration:

Detail Report

Project: Port Townsend PS Sub
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date: 1/7-17-12
Estimate Class: 3

| Fac | Work Pkg | Trade Pkg | Work Activity | Unit Price | Description | Takeoff Quantity | Labor Man Hrs | Labor Amount | Material Amount | Sub Amount | Equip Amount | Other Amount | Total Cost/Unit | Total Amount | |
|------|----------|-----------|---------------|------------|---|------------------|---------------|----------------|-----------------|----------------|----------------|---------------|-----------------|------------------|---------|
| | | | | | <u>26-00-99-00 Electrical, Other</u> | | | | | | | | | | |
| | | | | | MCC | 1.00 | ls | | | 13,877 | | | 13,877.26 /ls | 13,877 | |
| | | | | | Other Site Electrical & Wiring | 1.00 | ls | | | 20,816 | | | 20,815.89 /ls | 20,816 | |
| | | | | | <u>26-00-99-00 Electrical, Other</u> | 1.00 | LS | 100.0 | 9,349 | 105,467 | 916 | | 171,241.18 /LS | 171,241 | |
| | | | | | <u>26-25-05-10 Electrical Equipment, VFDs - 150 HP</u> | | | | | | | | | | |
| | | | | | VFD 150 HP NEMA-1 | 2.00 | E | 80.0 | 7,479 | 47,183 | 1,055 | | 27,858.30 /E | 55,717 | |
| | | | | | <u>26-25-05-10 Electrical Equipment, VFDs - 150 HP</u> | 2.00 | EA | 80.0 | 7,479 | 47,183 | 1,055 | | 27,858.30 /EA | 55,717 | |
| | | | | | <u>26-30-01-00 Communications Systems</u> | | | | | | | | | | |
| | | | | | I&C Allowance | 1.00 | ls | | | 20,816 | | | 20,815.89 /ls | 20,816 | |
| | | | | | <u>26-30-01-00 Communications Systems</u> | 1.00 | LS | | | 20,816 | | | 20,815.89 /LS | 20,816 | |
| | | | | | <u>CJM-007 Wet Well Electrical</u> | 1.00 | LS | 180.0 | 16,828 | 152,650 | 1,971 | | 247,773.67 /LS | 247,774 | |
| | | | | | 26-00 Electrical | 1.00 | LS | 180.0 | 16,828 | 152,650 | 1,971 | | 247,773.67 /LS | 247,774 | |
| | | | | | <u>26.0 Electrical Work</u> | 1.00 | LS | 180.0 | 16,828 | 152,650 | 1,971 | | 247,773.67 /LS | 247,774 | |
| 31.0 | | | | | Site/Civil | | | | | | | | | | |
| | 31-16 | | | | Earthworks, Sheeting/Shoring | | | | | | | | | | |
| | | CJM-006 | | | <u>Wet Well Site/Excavation</u> | | | | | | | | | | |
| | | | | | <u>31-17-02-00 Earthworks, Caissons</u> | | | | | | | | | | |
| | | | | | Mobilization, caisson equip/crane, set up, large | 1.00 | ea | 237.0 | 17,748 | | 18,426 | | 36,174.35 /ea | 36,174 | |
| | | | | | Caisson Shoe | 107.00 | lf | | | | | 66,218 | 618.86 /lf | 66,218 | |
| | | | | | <u>31-17-02-00 Earthworks, Caissons</u> | 1.00 | LS | 237.0 | 17,748 | | 18,426 | 66,218 | 102,392.70 /LS | 102,393 | |
| | | | | | <u>31-19-01-00 Site Preparation, Dewatering, Sump Pump</u> | | | | | | | | | | |
| | | | | | Dewatering Minor, Generator and Pumps, Mob | 1.00 | ea | 8.0 | | 1,857 | | | 1,856.60 /ea | 1,857 | |
| | | | | | Dewatering Minor, Set-up Generator and Install Pumps | 4.00 | ea | 32.0 | 2,148 | | 464 | | 652.88 /ea | 2,612 | |
| | | | | | Dewatering Minor, Sump Rock, delivered | 5.00 | cy | | | 124 | | | 24.76 /cy | 124 | |
| | | | | | Dewatering Minor, Large Generator and 4 Pumps, Rental, Monthly | 3.00 | mo | | | | 30,861 | | 10,286.96 /mo | 30,861 | |
| | | | | | Dewatering Minor, Generator and Pumps, Operation - Labor to maintain / check pumps/ fuel and lube | 3.00 | mo | 270.0 | 17,059 | | 2,408 | | 6,488.80 /mo | 19,466 | |
| | | | | | Dewatering Minor, Remove Generator and Pumps | 4.00 | ea | 32.0 | 2,148 | | 464 | | 652.88 /ea | 2,612 | |
| | | | | | Dewatering Minor, Generator and Pumps, Demob | 1.00 | ea | 8.0 | | 1,857 | | | 1,856.59 /ea | 1,857 | |
| | | | | | <u>31-19-01-00 Site Preparation, Dewatering, Sump Pump</u> | 3.00 | MO | 350.0 | 21,354 | 124 | 3,713 | 34,196 | 19,795.76 /MO | 59,387 | |
| | | | | | <u>31-25-01-00 Earthworks, Structural, Excavation</u> | | | | | | | | | | |
| | | | | | Structural Excavation, Caisson Crew, 22' depth | 980.00 | cy | 209.1 | 13,700 | | 14,040 | | 28.31 /cy | 27,740 | |
| | | | | | Load Excess for Hauling, Excavator, Cat 330 | 980.00 | cy | 4.9 | 387 | | 699 | | 1.11 /cy | 1,086 | |
| | | | | | Haul / Remove Excess, 17 yd capacity, 10 miles RT | 980.00 | cy | 33.7 | 2,020 | | 2,082 | | 4.19 /cy | 4,102 | |
| | | | | | Dump Charges for For Excess, 17 yd tandem, per cy | 980.00 | cy | | | 6,065 | | | 6.19 /cy | 6,065 | |
| | | | | | <u>31-25-01-00 Earthworks, Structural, Excavation</u> | 980.00 | CY | 247.7 | 16,107 | 6,065 | 16,822 | | 39.79 /CY | 38,993 | |
| | | | | | <u>CJM-006 Wet Well Site/Excavation</u> | | | 834.7 | 55,209 | 6,189 | 3,713 | 69,444 | 66,218 | 200,773 | |
| | | | | | 31-16 Earthworks, Sheeting/Shoring | 1.00 | LS | 834.7 | 55,209 | 6,189 | 3,713 | 69,444 | 66,218 | 200,773.16 /LS | 200,773 |
| | | | | | 31.0 Site/Civil | 1.00 | LS | 834.7 | 55,209 | 6,189 | 3,713 | 69,444 | 66,218 | 200,773.16 /LS | 200,773 |
| 43.0 | | | | | Process Equipment | | | | | | | | | | |
| | 43-05 | | | | Furnish and Install Process Equipment | | | | | | | | | | |
| | | CJM-008 | | | <u>Wet Well Equipment</u> | | | | | | | | | | |
| | | | | | <u>44-05-49-04 Submersable Pumps</u> | | | | | | | | | | |
| | | | | | Submersable Pumps, 160 hp, w/out controls, Flygt | 2.00 | EA | 192.0 | 16,132 | 172,866 | | 2,775 | 95,887.02 /EA | 191,774 | |
| | | | | | Set base elbow / pump assembly, 101 - 250 hp | 2.00 | ea | 128.0 | 10,755 | 278 | | | 5,516.21 /ea | 11,032 | |
| | | | | | Pump Control System | 1.00 | ls | | | 41,632 | | | 41,631.79 /ls | 41,632 | |
| | | | | | <u>44-05-49-04 Submersable Pumps</u> | 2.00 | EA | 320.0 | 26,887 | 173,144 | 41,632 | 2,775 | 122,219.12 /EA | 244,438 | |
| | | | | | <u>CJM-008 Wet Well Equipment</u> | | | 320.0 | 26,887 | 173,144 | 41,632 | 2,775 | 244,438.24 /SF | 244,438 | |
| | | | | | 43-05 Furnish and Install Process Equipment | 1.00 | SF | 320.0 | 26,887 | 173,144 | 41,632 | 2,775 | 244,438.24 /SF | 244,438 | |
| | | | | | 43.0 Process Equipment | 1.00 | SF | 320.0 | 26,887 | 173,144 | 41,632 | 2,775 | 244,438.24 /SF | 244,438 | |
| | | | | | 58 WASTEWATER - PUMP STATION | | | 3,298.3 | 251,511 | 480,402 | 161,389 | 74,190 | 66,218 | 1,033,711 | |



Detail Report

Project: Port Townsend PS Sub
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date: 1/7-17-12
Estimate Class: 3

Estimate Totals

| Description | Amount | Totals | Hours | Rate | % of Total |
|---------------------------------------|------------------|------------------|---------------|----------|------------|
| Labor | 261,444 | | 3,528.495 hrs | | |
| Material | 497,888 | | | | |
| Subcontract | 214,094 | | | | |
| Equipment | 81,665 | | 3,428.594 hrs | | |
| Other | 66,218 | | | | |
| Total Subcontractor OH&P | 1,121,309 | 1,121,309 | | | |
| General Conditions | 64,703 | | | 7.000 % | |
| Total Taxes | 64,703 | 1,186,012 | | | |
| Mobilization/Demobilization | 61,234 | | | 3.000 % | |
| Blder's Risk & Gen Liab Ins -% | 20,411 | | | 1.000 % | |
| Payment & Performance Bond | 23,677 | | | 1.160 % | |
| Total Owner-Provided Equipment | 105,322 | 1,291,334 | | | |
| Contingency - % | 516,533 | | | 40.000 % | |
| Total Contingency | 516,533 | 1,807,867 | | | |
| Escalation on Estimate Total | 64,722 | | | 3.580 % | |
| Construction Total | 64,722 | 1,872,589 | | | |
| Gross Sales Tax | 168,533 | | | 9.000 % | |
| Construction Total (with GST) | 168,533 | 2,041,122 | | | |

Port Townsend Mill Rd Pump Station, Lift Pump, Port Townsend, WA
WW Pump Station, Schematic, 15% Design
425179, Rev 1

| | |
|-----------------------------|--|
| Project name | Port Townsend PS Lift Port Townsend WA |
| Estimator | C Moore/SEA |
| Labor rate table | 2_AA04 (2012) |
| Equipment rate table | 1_EqRates_2011_75% |
| Job size | 1 LS |
| Project | Port Townsend PS |
| Project Number | 425179 |
| Market Segment | Wastewater Pump Stat |
| Business Group | WBG |
| Project Conditions | New |
| Estimate Class 1-5 | 3 |
| Estimate Category | Consult Engineer Est |
| Design Stage | Schematic Design |
| Project Manager | J Burnam |
| Rev No. / Date | 1/7-17-12 |
| Report format | Sorted by 'Facility/Work Pkg/Trade Pkg/WorkActiv/Unit Price' 'Detail' summary Allocate addons Combine items |



Job Size: 1 LS
Duration:

Detail Report

Project: Port Townsend PS Lift
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date: 1/7-17-12
Estimate Class: 3

| Fac | Work Pkg | Trade Pkg | Work Activity | Unit Price | Description | Takeoff Quantity | Labor Man Hrs | Labor Amount | Material Amount | Sub Amount | Equip Amount | Other Amount | Total Cost/Unit | Total Amount |
|-----|----------|-----------|---------------|-------------|---|------------------|---------------|--------------|-----------------|---------------|--------------|--------------|-----------------|---------------|
| 06 | | | | | SITWORK | | | | | | | | | |
| | 31.0 | | | | Site/Civil | | | | | | | | | |
| | | 31-20 | | | Earthworks, Site | | | | | | | | | |
| | | | CJM-005 | | Sitework | | | | | | | | | |
| | | | | 31-15-01-00 | Site Preparation, Clearing and Grubbing | | | | | | | | | |
| | | | | | Clearing, Tree Removal, 6" - 12", Acre | 0.20 acre | 32.0 | - | - | 1,238 | - | - | 6,190.95 /acre | 1,238 |
| | | | | | Finish grading area to be paved with grader, small area | 733.00 sy | 29.3 | 2,020 | - | - | 2,528 | - | 6.20 /sy | 4,548 |
| | | | | | Compact Building Pads, Equipment Pads, and Misc. Out Structures | 733.00 sy | 8.1 | 547 | - | - | 384 | - | 1.27 /sy | 930 |
| | | | | | 31-15-01-00 Site Preparation, Clearing and Grubbing | 1.00 LS | 69.5 | 2,567 | - | 1,238 | 2,911 | - | 6,716.41 /LS | 6,716 |
| | | | | 31-40-02-00 | Site Improvements, Paving, Bituminous Asphalt | | | | | | | | | |
| | | | | | Bituminous Pavement Subgrade Prep | 733.00 sy | 6.6 | - | - | 1,361 | - | - | 1.86 /sy | 1,361 |
| | | | | | Bituminous Pavement Import Aggregate Base | 208.00 tn | 2.7 | - | - | 7,984 | - | - | 38.38 /tn | 7,984 |
| | | | | | Bituminous Asphalt (tn), 4" | 168.00 tn | 1.3 | - | - | 20,802 | - | - | 123.82 /tn | 20,802 |
| | | | | | 31-40-02-00 Site Improvements, Paving, Bituminous Asphalt | 733.00 SY | 10.6 | - | - | 30,147 | - | - | 41.13 /SY | 30,147 |
| | | | | 31-45-01-00 | Fencing, Chain Link | | | | | | | | | |
| | | | | | Security Fence, Chain Link, 8' | 350.00 lf | 45.5 | - | - | 10,834 | - | - | 30.96 /lf | 10,834 |
| | | | | | Fence Security Signage | 8.00 ea | 8.0 | - | - | 1,486 | - | - | 185.73 /ea | 1,486 |
| | | | | | Fence, double swing gates, 8' high, 12' opening | 1.00 opng | 15.0 | 911 | 638 | - | 26 | - | 1,575.33 /opng | 1,575 |
| | | | | | 31-45-01-00 Fencing, Chain Link | 350.00 LF | 68.5 | 911 | 638 | 12,320 | 26 | - | 39.70 /LF | 13,895 |
| | | | | | CJM-005 Sitework | | 148.6 | 3,478 | 638 | 43,705 | 2,938 | | | 50,759 |
| | | | | | 31-20 Earthworks, Site | 1.00 LS | 148.6 | 3,478 | 638 | 43,705 | 2,938 | - | 50,758.59 /LS | 50,759 |
| | | | | | 31.0 Site/Civil | 1.00 LS | 148.6 | 3,478 | 638 | 43,705 | 2,938 | - | 50,758.59 /LS | 50,759 |
| | | | | | 06 SITWORK | | 148.6 | 3,478 | 638 | 43,705 | 2,938 | | | 50,759 |
| 07 | | | | | YARD PIPING | | | | | | | | | |
| | 33.0 | | | | Buried Piping | | | | | | | | | |
| | | 33-00 | | | Yard Piping | | | | | | | | | |
| | | | CJM-004 | | Yard Piping | | | | | | | | | |
| | | | | 33-00-07-10 | Yard Pipe, PVC, 10" | | | | | | | | | |
| | | | | | Trench Box, 8' x 24' x 10' | 0.25 mo | - | - | - | - | 712 | - | 2,847.84 /mo | 712 |
| | | | | | Excav, pipe trench, w/ 1:1 slopes, for 4" - 24" pipe | 41.66 CY | 1.2 | 85 | - | - | 106 | - | 4.58 /CY | 191 |
| | | | | | Backfill / Compact @ pipe zone, for 4" thru 24" pipe | 9.47 cy | 1.3 | 86 | - | - | 55 | - | 14.79 /cy | 140 |
| | | | | | Backfill / Compact above pipe zone, for 4" thru 24" pipe | 33.02 cy | 1.0 | 73 | - | - | 60 | - | 4.02 /cy | 133 |
| | | | | | Pipe zone material | 9.47 cy | - | - | 328 | - | - | - | 34.67 /cy | 328 |
| | | | | | Pipe bedding material | 2.86 cy | - | - | 99 | - | - | - | 34.67 /cy | 99 |
| | | | | | Imported backfill material | 33.02 cy | - | - | 491 | - | - | - | 14.86 /cy | 491 |
| | | | | | Haul spoils, offsite, up to 10 miles | 12.33 cy | - | - | - | 153 | - | - | 12.38 /cy | 153 |
| | | | | | Dump fees, trench spoils | 12.33 cy | - | - | 76 | - | - | - | 6.19 /cy | 76 |
| | | | | | 10" DI, MJ, Ell, 90 | 1.00 ea | 4.2 | 357 | 388 | - | 174 | - | 919.52 /ea | 920 |
| | | | | | 10" DI, MJ, Ell, 45 | 2.00 ea | 8.4 | 714 | 633 | - | 348 | - | 848.02 /ea | 1,696 |
| | | | | | 10" DI, MJ, tee | 1.00 ea | 5.8 | 493 | 633 | - | 240 | - | 1,367.11 /ea | 1,367 |
| | | | | | FURNISH PVC water distribution pipe, C-900, class 150, DR 18, 10" | 45.00 LF | - | - | 847 | - | - | - | 18.83 /LF | 847 |
| | | | | | Install PVC water distribution pipe, excav/bkfill NOT included, 10" | 45.00 LF | 6.8 | 582 | - | - | 284 | - | 19.23 /LF | 865 |
| | | | | | Pipe Marking, ID Tape | 45.00 lf | 0.5 | 41 | 7 | - | - | - | 1.08 /lf | 49 |
| | | | | | 33-00-07-10 Yard Pipe, PVC, 10" | 45.00 LF | 29.1 | 2,432 | 3,504 | 153 | 1,979 | - | 179.26 /LF | 8,067 |
| | | | | 33-00-07-12 | Yard Pipe, PVC, 12" | | | | | | | | | |
| | | | | | Trench Box, 8' x 24' x 10' | 0.25 mo | - | - | - | - | 712 | - | 2,847.84 /mo | 712 |
| | | | | | Excav, pipe trench, w/ 1:1 slopes, for 4" - 24" pipe | 30.50 CY | 0.9 | 62 | - | - | 77 | - | 4.58 /CY | 140 |
| | | | | | Backfill / Compact @ pipe zone, for 4" thru 24" pipe | 7.07 cy | 0.9 | 64 | - | - | 41 | - | 14.79 /cy | 105 |
| | | | | | Backfill / Compact above pipe zone, for 4" thru 24" pipe | 23.89 cy | 0.7 | 53 | - | - | 43 | - | 4.02 /cy | 96 |
| | | | | | Pipe zone material | 7.07 cy | - | - | 245 | - | - | - | 34.67 /cy | 245 |
| | | | | | Pipe bedding material | 2.02 cy | - | - | 70 | - | - | - | 34.67 /cy | 70 |
| | | | | | Imported backfill material | 23.89 cy | - | - | 355 | - | - | - | 14.86 /cy | 355 |
| | | | | | Haul spoils, offsite, up to 10 miles | 9.09 cy | - | - | - | 113 | - | - | 12.38 /cy | 113 |
| | | | | | Dump fees, trench spoils | 9.09 cy | - | - | 56 | - | - | - | 6.19 /cy | 56 |
| | | | | | FURNISH PVC water distribution pipe, C-900, class 150, DR 18, 12" | 30.00 LF | - | - | 797 | - | - | - | 26.57 /LF | 797 |
| | | | | | Install PVC water distribution pipe, excav/bkfill NOT included, 12" | 30.00 LF | 5.0 | 429 | - | - | 209 | - | 21.25 /LF | 638 |
| | | | | | Pipe Marking, ID Tape | 30.00 lf | 0.3 | 28 | 5 | - | - | - | 1.08 /lf | 32 |
| | | | | | 33-00-07-12 Yard Pipe, PVC, 12" | 30.00 LF | 7.9 | 635 | 1,528 | 113 | 1,082 | - | 111.95 /LF | 3,358 |
| | | | | 33-15-01-05 | Yard Structures, Manholes, 60" Dia | | | | | | | | | |
| | | | | | Catchbasins, frs and covs, lt traffic, 24" diam, 300 lb. | 1.00 ea | 2.8 | 184 | 292 | - | 86 | - | 561.94 /ea | 562 |
| | | | | | Manholes, concrete, precast, 5' I.D., 8' deep | 1.00 ea | 16.0 | 1,065 | 2,414 | - | 500 | - | 3,978.63 /ea | 3,979 |

Detail Report

Project: Port Townsend PS Lift
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date: 1/7-17-12
Estimate Class: 3

| Fac | Work Pkg | Trade Pkg | Work Activity | Unit Price | Description | Takeoff Quantity | Labor Man Hrs | Labor Amount | Material Amount | Sub Amount | Equip Amount | Other Amount | Total Cost/Unit | Total Amount |
|-----|----------|-----------|---------------|------------|--|------------------|---------------|--------------|-----------------|--------------|--------------|--------------|-------------------|---------------|
| | | | | | 33-15-01-05 Yard Structures, Manholes, 60" Dia | 1.00 EA | 18.8 | 1,248 | 2,707 | | 586 | | 4,540.57 /EA | 4,541 |
| | | | | | 33-20-01-10 Yard Valves, Gate Valves, 10" | | | | | | | | | |
| | | | | | Install gate valve, Flgd, DIP, 10" | 3.00 ea | 15.9 | 1,352 | - | - | 659 | - | 670.52 /ea | 2,012 |
| | | | | | Gate valve, iron body, dbl disk, Flgd, 150#, HWO, 10" | 3.00 ea | | - | 2,322 | - | - | - | 773.87 /ea | 2,322 |
| | | | | | 33-20-01-10 Yard Valves, Gate Valves, 10" | 3.00 EA | 15.9 | 1,352 | 2,322 | | 659 | | 1,444.39 /EA | 4,333 |
| | | | | | CJM-004 Yard Piping | 45.00 LF | 71.6 | 5,667 | 10,061 | 265 | 4,306 | | 451.09 /LF | 20,299 |
| | | | | | 33-00 Yard Piping | 45.00 LF | 71.6 | 5,667 | 10,061 | 265 | 4,306 | | 451.09 /LF | 20,299 |
| | 33-15 | | | | Yard Structures | | | | | | | | | |
| | | | | | Meter Vault | | | | | | | | | |
| | | | | | 31-25-01-00 Earthworks, Structural, Excavation | | | | | | | | | |
| | | | | | Structural Excavation, Excavator and Trucks, Small Crew, 6' depth | 24.00 cy | 1.3 | 89 | - | - | 81 | - | 7.09 /cy | 170 |
| | | | | | Grade for slabs / Scarify and Recompact, Dozer and Traxcavator or Loader, Small Crew | 7.00 sy | 0.3 | 23 | - | - | 14 | - | 5.21 /sy | 36 |
| | | | | | Import Aggregate Base - under slab, Dozer and Traxcavator or Loader, Small Crew | 4.00 tn | 0.4 | 26 | 99 | - | 15 | - | 35.19 /tn | 141 |
| | | | | | Import Aggregate Base - along walls, Dozer and Traxcavator or Loader, Small Crew | 18.00 tn | 1.7 | 118 | 446 | - | 70 | - | 35.19 /tn | 633 |
| | | | | | Load Excess for Hauling, Rubber Tire Loader, Cat 930 | 24.00 cy | 0.2 | 15 | - | - | 11 | - | 1.07 /cy | 26 |
| | | | | | Haul / Remove Excess, 17 yd capacity, 5 miles RT | 24.00 cy | 0.7 | 41 | - | - | 43 | - | 3.51 /cy | 84 |
| | | | | | Dump Charges for For Excess, 17 yd tandem, per cy | 24.00 cy | | - | 306 | - | - | - | 12.75 /cy | 306 |
| | | | | | 31-25-01-00 Earthworks, Structural, Excavation | 24.00 CY | 4.6 | 312 | 851 | | 234 | | 58.20 /CY | 1,397 |
| | | | | | 33-40-03-01 Pipeline Structures, Vaults | | | | | | | | | |
| | | | | | Meter Vault, 6'x6' x 10' d | 1.00 ls | | | | 8,754 | | | 8,754.02 /ls | 8,754 |
| | | | | | 33-40-03-01 Pipeline Structures, Vaults | 1.00 EA | | | | 8,754 | | | 8,754.02 /EA | 8,754 |
| | | | | | 40-20-19-10 Flow Meter, 10" | | | | | | | | | |
| | | | | | Install magnetic flow meter, 10" | 1.00 ea | 5.3 | 479 | 5,943 | - | - | - | 6,422.15 /ea | 6,422 |
| | | | | | 40-20-19-10 Flow Meter, 10" | 1.00 EA | 5.3 | 479 | 5,943 | | | | 6,422.15 /EA | 6,422 |
| | | | | | CJM-003 Meter Vault | | 9.9 | 791 | 6,794 | 8,754 | 234 | | | 16,573 |
| | | | | | 33-15 Yard Structures | 1.00 EA | 9.9 | 791 | 6,794 | 8,754 | 234 | | 16,573.07 /EA | 16,573 |
| | | | | | 33.0 Buried Piping | 45.00 LF | 81.5 | 6,458 | 16,855 | 9,019 | 4,540 | | 819.38 /LF | 36,872 |
| | | | | | 07 YARD PIPING | | 81.5 | 6,458 | 16,855 | 9,019 | 4,540 | | | 36,872 |
| | | | | | WASTEWATER - PUMP STATION | | | | | | | | | |
| | | | | | Concrete Work | | | | | | | | | |
| | | | | | Cast-In-Place Concrete Work | | | | | | | | | |
| | | | | | Wet Well Concrete | | | | | | | | | |
| | | | | | 03-10-05-12 Cast-In-Place Concrete, Slabs on Grade, 12" thick | | | | | | | | | |
| | | | | | Concrete pumping, subcontract, all inclusive price | 29.80 cy | | - | - | 478 | - | - | 16.06 /cy | 478 |
| | | | | | Slab on grade edge forms, 7" to 12" | 100.50 sf | 18.1 | 1,490 | 134 | - | - | - | 16.17 /sf | 1,625 |
| | | | | | Reinforcing in place, A615 Gr 60, priced per lbs. | 4,469.44 lb | | - | 2,991 | 1,196 | - | - | 0.94 /lb | 4,187 |
| | | | | | Concrete, ready mix, 4000 psi | 29.80 CY | | - | 4,107 | - | - | - | 137.83 /CY | 4,107 |
| | | | | | Add for concrete waste, 4000 psi | 1.49 cy | | - | 205 | - | - | - | 137.84 /cy | 205 |
| | | | | | Add amount for Environmental Fee - per concrete truck load | 4.00 load | | - | 32 | - | - | - | 8.03 /load | 32 |
| | | | | | Placing concrete, concrete pump | 29.80 cy | 22.3 | 1,473 | - | - | - | - | 49.44 /cy | 1,473 |
| | | | | | Finishing floors, monolithic, trowel finish (machine) | 804.50 sf | 16.1 | 1,224 | 22 | - | - | - | 1.55 /sf | 1,246 |
| | | | | | Curing, membrane spray | 804.50 sf | 1.6 | 106 | 43 | - | - | - | 0.19 /sf | 149 |
| | | | | | Concrete Coating, Chemical Resistant, CRC-3 | 804.50 sf | | - | - | 3,230 | - | - | 4.02 /sf | 3,230 |
| | | | | | 03-10-05-12 Cast-In-Place Concrete, Slabs on Grade, 12" thick | 29.80 CY | 58.1 | 4,294 | 7,534 | 4,904 | | | 561.47 /CY | 16,732 |
| | | | | | 03-10-05-24 Cast-In-Place Concrete, Tremie Slab, 24" thick | | | | | | | | | |
| | | | | | Fine grade, for slab on grade, by hand | 804.50 sf | 5.6 | 371 | 11 | - | - | - | 0.48 /sf | 382 |
| | | | | | Concrete pumping, subcontract, all inclusive price | 59.59 cy | | - | - | 957 | - | - | 16.06 /cy | 957 |
| | | | | | Concrete, ready mix, 4000 psi | 59.59 CY | | - | 8,214 | - | - | - | 137.83 /CY | 8,214 |
| | | | | | Add for concrete waste, 4000 psi | 2.98 cy | | - | 411 | - | - | - | 137.84 /cy | 411 |
| | | | | | Add amount for Environmental Fee - per concrete truck load | 7.00 load | | - | 56 | - | - | - | 8.03 /load | 56 |
| | | | | | Placing concrete, concrete pump | 59.59 cy | 44.7 | 2,946 | - | - | - | - | 49.44 /cy | 2,946 |
| | | | | | 03-10-05-24 Cast-In-Place Concrete, Tremie Slab, 24" thick | 59.59 CY | 50.3 | 3,317 | 8,692 | 957 | | | 217.59 /CY | 12,966 |
| | | | | | 03-10-07-24 Cast-In-Place Concrete, Circular Walls, 24" thick | | | | | | | | | |
| | | | | | Concrete pumping, subcontract, all inclusive price | 158.22 cy | | - | - | 2,541 | - | - | 16.06 /cy | 2,541 |
| | | | | | Forms in place, structural walls, to 8' high, hand set | 4,272.00 sf | 640.8 | 52,789 | 5,717 | - | - | - | 13.70 /sf | 58,506 |
| | | | | | Waterstop, PVC, center bulb, 6" wide | 1,068.00 lf | 85.4 | 7,039 | 2,858 | - | - | - | 9.27 /lf | 9,897 |
| | | | | | Speed Dowels, #6 | 1,060.00 ea | | - | 28,370 | - | - | - | 26.76 /ea | 28,370 |
| | | | | | Reinforcing in place, A615 Gr 60, priced per lbs. | 35,600.00 lb | | - | 23,820 | 9,528 | - | - | 0.94 /lb | 33,348 |

Detail Report

Project: Port Townsend PS Lift
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date: 1/7-17-12
Estimate Class: 3

| Fac | Work Pkg | Trade Pkg | Work Activity | Unit Price | Description | Takeoff Quantity | Labor Man Hrs | Labor Amount | Material Amount | Sub Amount | Equip Amount | Other Amount | Total Cost/Unit | Total Amount |
|-----|----------|-----------|---------------|------------|---|------------------|----------------|----------------|-----------------|---------------|--------------|--------------|-----------------|----------------|
| | | | 03-10-07-24 | | Cast-In-Place Concrete, Circular Walls, 24" thick | | | | | | | | | |
| | | | | | Concrete, ready mix, 4000 psi | 158.22 CY | | | 21,808 | | | | 137.83 /CY | 21,808 |
| | | | | | Add for concrete waste, 4000 psi | 7.91 cy | | | 1,090 | | | | 137.83 /cy | 1,090 |
| | | | | | Add amount for Environmental Fee - per concrete truck load | 20.00 load | | | 161 | | | | 8.03 /load | 161 |
| | | | | | Placing concrete, concrete pump, for structural wall >12" - 24" thick | 158.22 cy | 118.7 | 7,822 | | | | | 49.44 /cy | 7,822 |
| | | | | | Patch & plug tieholes | 4,272.00 sf | 64.1 | 4,224 | 114 | | | | 1.02 /sf | 4,338 |
| | | | | | Sack rub | 4,272.00 sf | 170.9 | 11,264 | 172 | | | | 2.68 /sf | 11,436 |
| | | | | | Curing, membrane spray | 4,272.00 sf | 8.5 | 563 | 229 | | | | 0.19 /sf | 792 |
| | | | | | Below grade damproofing, Bituminous Asphalt | 2,136.00 sf | | | 2,857 | | | | 1.34 /sf | 2,857 |
| | | | | | Concrete Coating, Chemical Resistant, CRC-3 | 2,136.00 sf | | | | 8,575 | | | 4.02 /sf | 8,575 |
| | | | 03-10-07-24 | | Cast-In-Place Concrete, Circular Walls, 24" thick | 158.22 CY | 1,088.4 | 83,701 | 87,195 | 20,644 | | | 1,210.59 /CY | 191,540 |
| | | | 03-10-10-18 | | Cast-In-Place Concrete, Elevated Decks, 18" thick | | | | | | | | | |
| | | | | | Concrete pumping, subcontract, all inclusive price | 61.30 cy | | | | 984 | | | 16.06 /cy | 984 |
| | | | | | Forms in place, elevated slab, soffit | 1,018.00 sf | 203.6 | 16,772 | 1,703 | | | | 18.15 /sf | 18,475 |
| | | | | | Forms in place, elevated slab, edge form | 169.50 sf | 42.4 | 3,491 | 284 | | | | 22.27 /sf | 3,774 |
| | | | | | Forms in place, elevated slab, box-out | 36.00 sf | 9.7 | 801 | 60 | | | | 23.92 /sf | 861 |
| | | | | | Forms in place, monolithic beam, bottom | 64.00 sf | 12.8 | 1,054 | 128 | | | | 16.48 /sf | 1,183 |
| | | | | | Forms in place, monolithic beam, sides | 256.00 sf | 38.4 | 3,163 | 428 | | | | 14.03 /sf | 3,592 |
| | | | | | Slab shoring | 20,360.00 cf | 142.5 | 11,741 | 1,362 | | | | 0.64 /cf | 13,103 |
| | | | | | Add labor for setting embedded frames | 24.00 lf | 24.0 | 1,977 | | | | | 82.38 /lf | 1,977 |
| | | | | | Reinforcing in place, A615 Gr 60, priced per lbs. | 13,910.19 lb | | | 9,307 | 3,723 | | | 0.94 /lb | 13,030 |
| | | | | | Concrete, ready mix, 4000 psi | 61.30 CY | | | 8,449 | | | | 137.83 /CY | 8,449 |
| | | | | | Add for concrete waste, 4000 psi | 3.07 cy | | | 422 | | | | 137.83 /cy | 422 |
| | | | | | Add amount for Environmental Fee - per concrete truck load | 7.00 load | | | 56 | | | | 8.03 /load | 56 |
| | | | | | Placing concrete, concrete pump, for elevated slab over 12" thick | 61.30 cy | 27.6 | 1,818 | | | | | 29.66 /cy | 1,818 |
| | | | | | Finishing floors, monolithic, trowel finish (machine) | 1,018.00 sf | 20.4 | 1,549 | 27 | | | | 1.55 /sf | 1,576 |
| | | | | | Curing, membrane spray | 1,018.00 sf | 2.0 | 134 | 54 | | | | 0.19 /sf | 189 |
| | | | | | Concrete Coating, Chemical Resistant, CRC-2 | 1,018.00 sf | | | | 4,087 | | | 4.02 /sf | 4,087 |
| | | | 03-10-10-18 | | Cast-In-Place Concrete, Elevated Decks, 18" thick | 61.30 CY | 523.4 | 42,501 | 22,282 | 8,794 | | | 1,200.28 /CY | 73,577 |
| | | | | | CJM-002 Wet Well Concrete | | 1,720.3 | 133,813 | 125,703 | 35,299 | | | | 294,815 |
| | | | | | Wet Well Generator & Elect Pad | | | | | | | | | |
| | | | 03-10-05-12 | | Cast-In-Place Concrete, Slabs on Grade, 12" thick | | | | | | | | | |
| | | | | | Fine grade, for slab on grade, by hand | 186.00 sf | 1.3 | 86 | 2 | | | | 0.48 /sf | 88 |
| | | | | | Fill, gravel subbase, under building slab on grade | 3.45 cy | 1.7 | 114 | 115 | | | | 66.41 /cy | 229 |
| | | | | | Slab on grade edge forms, 7" to 12" | 82.00 sf | 14.8 | 1,216 | 110 | | | | 16.17 /sf | 1,326 |
| | | | | | Reinforcing in place, A615 Gr 60, priced per lbs. | 1,140.00 lb | | | 763 | 305 | | | 0.94 /lb | 1,068 |
| | | | | | Concrete, ready mix, 4000 psi | 6.89 CY | | | 950 | | | | 137.83 /CY | 950 |
| | | | | | Add for concrete waste, 4000 psi | 0.35 cy | | | 48 | | | | 137.88 /cy | 48 |
| | | | | | Add amount for Environmental Fee - per concrete truck load | 2.00 load | | | 16 | | | | 8.03 /load | 16 |
| | | | | | Placing concrete, direct chute | 3.56 cy | 1.8 | 117 | | | | | 32.96 /cy | 117 |
| | | | | | Finishing floors, monolithic, float finish | 96.00 sf | 1.9 | 146 | 1 | | | | 1.54 /sf | 147 |
| | | | | | Curing, water | 186.00 sf | 0.6 | 41 | 12 | | | | 0.29 /sf | 53 |
| | | | 03-10-05-12 | | Cast-In-Place Concrete, Slabs on Grade, 12" thick | 6.89 CY | 22.1 | 1,719 | 2,017 | 305 | | | 586.60 /CY | 4,042 |
| | | | | | CJM-009 Wet Well Generator & Elect Pad | | 22.1 | 1,719 | 2,017 | 305 | | | | 4,042 |
| | | | | | 03-10 Cast-In-Place Concrete Work | 315.80 CY | 1,742.4 | 135,532 | 127,720 | 35,604 | | | 946.35 /CY | 298,857 |
| | | | | | 03.0 Concrete Work | 315.80 CY | 1,742.4 | 135,532 | 127,720 | 35,604 | | | 946.35 /CY | 298,857 |
| | | | | | Architectural | | | | | | | | | |
| | | | | | Openings | | | | | | | | | |
| | | | | | Wet Well Concrete | | | | | | | | | |
| | | | 08-00-99-00 | | Openings, Other | | | | | | | | | |
| | | | | | Floor, incl, alum, 300 psf L.L., dbl leaf, 5' x 5' opening, 235# | 1.00 opng | 3.6 | 364 | 3,312 | | | | 3,675.69 /opng | 3,676 |
| | | | | | 08-00-99-00 Openings, Other | 1.00 EA | 3.6 | 364 | 3,312 | | | | 3,675.69 /EA | 3,676 |
| | | | | | CJM-002 Wet Well Concrete | | 3.6 | 364 | 3,312 | | | | | 3,676 |
| | | | | | 08-00 Openings | 1.00 SF | 3.6 | 364 | 3,312 | | | | 3,675.69 /SF | 3,676 |
| | | | | | 04.0 Architectural | 1.00 SF | 3.6 | 364 | 3,312 | | | | 3,675.69 /SF | 3,676 |
| | | | | | Electrical Work | | | | | | | | | |
| | | | | | Electrical | | | | | | | | | |
| | | | | | Wet Well Electrical | | | | | | | | | |
| | | | 26-00-99-00 | | Electrical, Other | | | | | | | | | |
| | | | | | Emergency Generator 350 KW, incl battery, muffler, ATS & day tank | 1.00 E | 100.0 | 9,352 | 105,503 | | 916 | | 115,770.67 /E | 115,771 |
| | | | | | Power to Site | 1.00 ls | | | | 20,823 | | | 20,822.88 /ls | 20,823 |

Detail Report

Project: Port Townsend PS Lift
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date: 1/7-17-12
Estimate Class: 3

| Fac | Work Pkg | Trade Pkg | Work Activity | Unit Price | Description | Takeoff Quantity | Labor Man Hrs | Labor Amount | Material Amount | Sub Amount | Equip Amount | Other Amount | Total Cost/Unit | Total Amount | |
|------|----------|-----------|---------------|------------|---|------------------|---------------|----------------|-----------------|----------------|----------------|---------------|-----------------------|------------------|---------|
| | | | | | 26-00-99-00 Electrical, Other | | | | | | | | | | |
| | | | | | MCC | 1.00 | 1s | | | 13,882 | | | 13,881.90 /ls | 13,882 | |
| | | | | | Other Site Electrical & Wiring | 1.00 | 1s | | | 20,823 | | | 20,822.87 /ls | 20,823 | |
| | | | | | 26-00-99-00 Electrical, Other | 1.00 | LS | 100.0 | 9,352 | 105,503 | 55,528 | 916 | 171,298.32 /LS | 171,298 | |
| | | | | | 26-25-05-10 Electrical Equipment, VFDs - 150 HP | | | | | | | | | | |
| | | | | | VFD 150 HP NEMA-1 | 2.00 | E | 80.0 | 7,482 | 47,199 | | 1,055 | 27,867.54 /E | 55,735 | |
| | | | | | 26-25-05-10 Electrical Equipment, VFDs - 150 HP | 2.00 | EA | 80.0 | 7,482 | 47,199 | | 1,055 | 27,867.54 /EA | 55,735 | |
| | | | | | 26-30-01-00 Communications Systems | | | | | | | | | | |
| | | | | | I&C Allowance | 1.00 | 1s | | | 20,823 | | | 20,822.87 /ls | 20,823 | |
| | | | | | 26-30-01-00 Communications Systems | 1.00 | LS | | | 20,823 | | | 20,822.87 /LS | 20,823 | |
| | | | | | CJM-007 Wet Well Electrical | 1.00 | LS | 180.0 | 16,834 | 152,701 | 76,351 | 1,971 | 247,856.26 /LS | 247,856 | |
| | | | | | 26-00 Electrical | 1.00 | LS | 180.0 | 16,834 | 152,701 | 76,351 | 1,971 | 247,856.26 /LS | 247,856 | |
| | | | | | 26.0 Electrical Work | 1.00 | LS | 180.0 | 16,834 | 152,701 | 76,351 | 1,971 | 247,856.26 /LS | 247,856 | |
| 31.0 | | | | | Site/Civil | | | | | | | | | | |
| | 31-16 | | | | Earthworks, Sheeting/Shoring | | | | | | | | | | |
| | | | | | Wet Well Site/Excavation | | | | | | | | | | |
| | | | | | 31-17-02-00 Earthworks, Caissons | | | | | | | | | | |
| | | | | | Mobilization, caisson equip/crane, set up, large | 1.00 | ea | 237.0 | 17,754 | | | 18,433 | 36,187.43 /ea | 36,187 | |
| | | | | | Caisson Shoe | 107.00 | lf | | | | | 66,243 | 619.10 /lf | 66,243 | |
| | | | | | 31-17-02-00 Earthworks, Caissons | 1.00 | LS | 237.0 | 17,754 | | | 18,433 | 102,430.65 /LS | 102,431 | |
| | | | | | 31-19-01-00 Site Preparation, Dewatering, Sump Pump | | | | | | | | | | |
| | | | | | Dewatering Minor, Generator and Pumps, Mob | 1.00 | ea | 8.0 | | 1,857 | | | 1,857.29 /ea | 1,857 | |
| | | | | | Dewatering Minor, Set-up Generator and Install Pumps | 4.00 | ea | 32.0 | 2,149 | | | 464 | 653.11 /ea | 2,612 | |
| | | | | | Dewatering Minor, Sump Rock, delivered | 5.00 | cy | | | 124 | | | 24.76 /cy | 124 | |
| | | | | | Dewatering Minor, Large Generator and 4 Pumps, Rental, Monthly | 3.00 | mo | | | | 30,872 | | 10,290.82 /mo | 30,872 | |
| | | | | | Dewatering Minor, Generator and Pumps, Operation - Labor to maintain / check pumps/ fuel and lube | 3.00 | mo | 270.0 | 17,065 | | 2,408 | | 6,491.08 /mo | 19,473 | |
| | | | | | Dewatering Minor, Remove Generator and Pumps | 4.00 | ea | 32.0 | 2,149 | | | 464 | 653.11 /ea | 2,612 | |
| | | | | | Dewatering Minor, Generator and Pumps, Demob | 1.00 | ea | 8.0 | | 1,857 | | | 1,857.28 /ea | 1,857 | |
| | | | | | 31-19-01-00 Site Preparation, Dewatering, Sump Pump | 3.00 | MO | 350.0 | 21,362 | 124 | 3,715 | 34,209 | 19,802.99 /MO | 59,409 | |
| | | | | | 31-25-01-00 Earthworks, Structural, Excavation | | | | | | | | | | |
| | | | | | Structural Excavation, Caisson Crew, 22' depth | 830.00 | cy | 177.1 | 11,607 | | | 11,896 | 28.32 /cy | 23,502 | |
| | | | | | Load Excess for Hauling, Excavator, Cat 330 | 830.00 | cy | 4.2 | 328 | | | | 1.11 /cy | 920 | |
| | | | | | Haul / Remove Excess, 17 yd capacity, 10 miles RT | 830.00 | cy | 28.6 | 1,712 | | | | 4.19 /cy | 3,476 | |
| | | | | | Dump Charges for For Excess, 17 yd tandem, per cy | 830.00 | cy | | | 5,138 | | | 6.19 /cy | 5,138 | |
| | | | | | 31-25-01-00 Earthworks, Structural, Excavation | 830.00 | CY | 209.8 | 13,646 | 5,138 | | 14,252 | 39.80 /CY | 33,937 | |
| | | | | | CJM-006 Wet Well Site/Excavation | | | 796.8 | 52,762 | 5,262 | 3,715 | 66,894 | 66,243 | 194,877 | |
| | | | | | 31-16 Earthworks, Sheeting/Shoring | 1.00 | LS | 796.8 | 52,762 | 5,262 | 3,715 | 66,894 | 66,243 | 194,876.51 /LS | 194,877 |
| | | | | | 31.0 Site/Civil | 1.00 | LS | 796.8 | 52,762 | 5,262 | 3,715 | 66,894 | 66,243 | 194,876.51 /LS | 194,877 |
| 43.0 | | | | | Process Equipment | | | | | | | | | | |
| | 43-05 | | | | Furnish and Install Process Equipment | | | | | | | | | | |
| | | | | | Wet Well Equipment | | | | | | | | | | |
| | | | | | 44-05-49-04 Suction Lift Pump | | | | | | | | | | |
| | | | | | Suction Lift Pump, 150 hp, w/ controls, Smith&Loveless | 2.00 | EA | 192.0 | 16,137 | 305,680 | | 2,776 | 162,157.86 /EA | 324,316 | |
| | | | | | Set base elbow / pump assembly, 101 - 250 hp | 2.00 | ea | 128.0 | 10,758 | 278 | | | 5,517.94 /ea | 11,036 | |
| | | | | | 44-05-49-04 Suction Lift Pump | 2.00 | EA | 320.0 | 26,896 | 305,680 | | 2,776 | 167,675.80 /EA | 335,352 | |
| | | | | | CJM-008 Wet Well Equipment | | | 320.0 | 26,896 | 305,680 | | 2,776 | | 335,352 | |
| | | | | | 43-05 Furnish and Install Process Equipment | 1.00 | SF | 320.0 | 26,896 | 305,680 | | 2,776 | 335,351.60 /SF | 335,352 | |
| | | | | | 43.0 Process Equipment | 1.00 | SF | 320.0 | 26,896 | 305,680 | | 2,776 | 335,351.60 /SF | 335,352 | |
| | | | | | 58 WASTEWATER - PUMP STATION | | | 3,042.7 | 232,387 | 594,675 | 115,669 | 71,642 | 66,243 | 1,080,617 | |



Detail Report

Project: Port Townsend PS Lift
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date: 1/7-17-12
Estimate Class: 3

Estimate Totals

| Description | Amount | Totals | Hours | Rate | % of Total |
|---------------------------------------|------------------|------------------|---------------|----------|------------|
| Labor | 242,323 | | 3,272.903 hrs | | |
| Material | 612,168 | | | | |
| Subcontract | 168,394 | | | | |
| Equipment | 79,119 | | 3,390.684 hrs | | |
| Other | 66,243 | | | | |
| Total Subcontractor OH&P | 1,168,247 | 1,168,247 | | | |
| General Conditions | 67,411 | | | 7.000 % | |
| Total Taxes | 67,411 | 1,235,658 | | | |
| Mobilization/Demobilization | 63,797 | | | 3.000 % | |
| Blder's Risk & Gen Liab Ins -% | 21,266 | | | 1.000 % | |
| Payment & Performance Bond | 24,668 | | | 1.160 % | |
| Total Owner-Provided Equipment | 109,731 | 1,345,389 | | | |
| Contingency - % | 538,156 | | | 40.000 % | |
| Total Contingency | 538,156 | 1,883,545 | | | |
| Escalation on Estimate Total | 67,431 | | | 3.580 % | |
| Construction Total | 67,431 | 1,950,976 | | | |
| Gross Sales Tax | 175,588 | | | 9.000 % | |
| Construction Total (with GST) | 175,588 | 2,126,564 | | | |

**Port Townsend Mill Rd Pump Station, Force Main, Port Townsend, WA
WW Pump Station, Schematic, 15% Design
425179, Rev 0**

| | |
|-----------------------------|--|
| Project name | Port Townsend FM Port Townsend WA |
| Estimator | C Moore/SEA |
| Labor rate table | 2_AA04 (2012) |
| Equipment rate table | 1_EqRates_2011_75% |
| Job size | 1 LS |
| Project | Port Townsend PS |
| Project Number | 425179 |
| Market Segment | Wastewater Pump Stat |
| Business Group | WBG |
| Project Conditions | New |
| Estimate Class 1-5 | 3 |
| Estimate Category | Consult Engineer Est |
| Design Stage | Schematic Design |
| Project Manager | J Burnam |
| Report format | Sorted by 'Facility/Work Pkg/Trade Pkg/WorkActiv/Unit Price' 'Detail' summary Allocate addons Combine items |



Detail Report

Job Size: 1 LS
Duration:

Project: Port Townsend FM
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date:
Estimate Class: 3

| Fac | Work Pkg | Trade Pkg | Work Activity | Unit Price | Description | Takeoff Quantity | Labor Man Hrs | Labor Amount | Material Amount | Sub Amount | Equip Amount | Other Amount | Total Cost/Unit | Total Amount |
|-----|----------|-----------|---------------|------------|---|------------------|---------------|----------------|-----------------|----------------|----------------|---------------|-------------------|----------------|
| 92 | | | | | OFFSITE - PIPELINES | | | | | | | | | |
| | 33.0 | | | | Buried Piping | | | | | | | | | |
| | | 33-35 | | | Pipelines | | | | | | | | | |
| | | | CJM-001 | | 10 dia Force Main | | | | | | | | | |
| | | | 02-01-01-01 | | General Site Demolition, Asphalt Pavement | | | | | | | | | |
| | | | | | Asphalt Demolition and Loading | 482.00 | 18.5 | 1,240 | - | - | 659 | - | 4.11 /cy | 1,900 |
| | | | 02-01-01-01 | | General Site Demolition, Asphalt Pavement | 34,224.00 | 18.5 | 1,240 | - | - | 659 | - | 0.06 /SF | 1,900 |
| | | | 31-19-01-00 | | Site Preparation, Dewatering, Sump Pump | | | | | | | | | |
| | | | | | Dewatering Minor, Generator and Pumps, Mob | 1.00 | 8.0 | - | - | 1,825 | - | - | 1,825.12 /ea | 1,825 |
| | | | | | Dewatering Minor, Large Generator and 1 Pumps, Rental, Monthly | 1.00 | mo | - | - | - | 6,124 | - | 6,124.48 /mo | 6,124 |
| | | | | | 31-19-01-00 Site Preparation, Dewatering, Sump Pump | 1.00 | MO | 8.0 | - | 1,825 | 6,124 | - | 7,949.60 /MO | 7,950 |
| | | | 31-40-02-00 | | Site Improvements, Paving, Bituminous Asphalt | | | | | | | | | |
| | | | | | Bituminous Pavement Subgrade Prep | 3,803.00 | 34.2 | - | - | 6,941 | - | - | 1.83 /sy | 6,941 |
| | | | | | Bituminous Pavement Import Aggregate Base, 6" | 1,109.00 | tn | 14.4 | - | 41,830 | - | - | 37.72 /tn | 41,830 |
| | | | | | Bituminous Asphalt (tn), 6" | 1,300.00 | tn | 10.4 | - | 181,903 | - | - | 139.93 /tn | 181,903 |
| | | | | | Pavement Marking, 4" Pavement striping | 4,278.00 | lf | 8.6 | - | 7,808 | - | - | 1.83 /lf | 7,808 |
| | | | | | 31-40-02-00 Site Improvements, Paving, Bituminous Asphalt | 3,803.00 | SY | 67.6 | - | 238,482 | - | - | 62.71 /SY | 238,482 |
| | | | 33-00-07-10 | | Yard Pipe, PVC, 10" | | | | | | | | | |
| | | | | | Traffic Control, Labor per Day | 25.00 | day | 400.0 | 24,329 | - | - | - | 973.17 /day | 24,329 |
| | | | | | Trench Box, 8' x 24' x 10' | 1.00 | mo | - | - | - | 2,799 | - | 2,798.51 /mo | 2,799 |
| | | | | | Excav. pipe trench, w/ 1:1 slopes, for 4" - 24" pipe | 3,960.38 | CY | 114.9 | 7,955 | - | 9,874 | - | 4.50 /CY | 17,828 |
| | | | | | Backfill / Compact @ pipe zone, for 4" thru 24" pipe | 900.55 | cy | 119.8 | 8,001 | - | 5,096 | - | 14.54 /cy | 13,097 |
| | | | | | Backfill / Compact above pipe zone, for 4" thru 24" pipe | 3,139.10 | cy | 91.0 | 6,807 | - | 5,610 | - | 3.96 /cy | 12,417 |
| | | | | | Pipe zone material | 900.55 | cy | - | 30,681 | - | - | - | 34.07 /cy | 30,681 |
| | | | | | Pipe bedding material | 272.71 | cy | - | 9,291 | - | - | - | 34.07 /cy | 9,291 |
| | | | | | Imported backfill material | 3,139.10 | cy | - | 45,834 | - | - | - | 14.60 /cy | 45,834 |
| | | | | | Haul spoils, offsite, up to 10 miles | 1,173.26 | cy | - | - | 14,276 | - | - | 12.17 /cy | 14,276 |
| | | | | | Dump fees, trench spoils | 1,173.26 | ls | - | 7,138 | - | - | - | 6.08 /ls | 7,138 |
| | | | | | 10" DI, MJ, Ell, 90' | 1.00 | ea | 4.2 | 352 | 381 | - | 171 | 904.06 /ea | 904 |
| | | | | | 10" DI, MJ, Ell, 45' | 1.00 | ea | 4.2 | 352 | 311 | - | 171 | 833.80 /ea | 834 |
| | | | | | 10" DI, MJ, Ell, 22 1/2' | 8.00 | ea | 33.6 | 2,812 | 2,570 | - | 1,369 | 843.83 /ea | 6,751 |
| | | | | | FURNISH PVC water distribution pipe, C-900, class 150, DR 18, 10" | 4,278.00 | LF | - | - | 79,172 | - | - | 18.51 /LF | 79,172 |
| | | | | | Install PVC water distribution pipe, excav/bkfill NOT included, 10" | 4,278.00 | LF | 650.3 | 54,423 | - | - | 26,489 | 18.91 /LF | 80,912 |
| | | | | | Pipe Marking, ID Tape | 4,278.00 | lf | 42.8 | 3,869 | 677 | - | - | 1.06 /lf | 4,546 |
| | | | 33-00-07-10 | | 33-00-07-10 Yard Pipe, PVC, 10" | 4,278.00 | LF | 1,460.7 | 108,899 | 176,054 | 14,276 | 51,578 | 82.00 /LF | 350,807 |
| | | | | | Yard Valves, Other | | | | | | | | | |
| | | | | | Air Release Valve | 1.00 | ea | - | - | 6,084 | - | - | 6,083.72 /ea | 6,084 |
| | | | | | 33-20-07-01 Yard Valves, Other | 1.00 | EA | - | - | 6,084 | - | - | 6,083.72 /EA | 6,084 |
| | | | | | CJM-001 10 dia Force Main | 4,278.00 | LF | 1,554.8 | 110,140 | 176,054 | 260,667 | 58,362 | 141.47 /LF | 605,222 |
| | | | | | 33-35 Pipelines | 4,278.00 | LF | 1,554.8 | 110,140 | 176,054 | 260,667 | 58,362 | 141.47 /LF | 605,222 |
| | | | | | 33.0 Buried Piping | 4,278.00 | LF | 1,554.8 | 110,140 | 176,054 | 260,667 | 58,362 | 141.47 /LF | 605,222 |
| | | | | | 92 OFFSITE - PIPELINES | | | 1,554.8 | 110,140 | 176,054 | 260,667 | 58,362 | | 605,222 |



CH2MHILL

Job Size: 1 LS
Duration:

Detail Report

Project: Port Townsend FM
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date:
Estimate Class: 3

Estimate Totals

| Description | Amount | Totals | Hours | Rate | % of Total |
|---------------------------------------|----------------|------------------|---------------|----------|------------|
| Labor | 110,140 | | 1,554.774 hrs | | |
| Material | 176,054 | | | | |
| Subcontract | 260,667 | | | | |
| Equipment | 58,362 | | 1,548.992 hrs | | |
| Other | | | | | |
| Total Subcontractor OH&P | 605,223 | 605,223 | | | |
| General Conditions | 34,923 | | | 7.000 % | |
| Total Taxes | 34,923 | 640,146 | | | |
| Mobilization/Demobilization | 33,051 | | | 3.000 % | |
| Blder's Risk & Gen Liab Ins -% | 11,017 | | | 1.000 % | |
| Payment & Performance Bond | 12,780 | | | 1.160 % | |
| Total Owner-Provided Equipment | 56,848 | 696,994 | | | |
| Contingency - % | 278,797 | | | 40.000 % | |
| Total Contingency | 278,797 | 975,791 | | | |
| Escalation on Estimate Total | 34,933 | | | 3.580 % | |
| Construction Total | 34,933 | 1,010,724 | | | |
| Gross Sales Tax | 90,965 | | | 9.000 % | |
| Construction Total (with GST) | 90,965 | 1,101,689 | | | |

Port Townsend Mill Rd Pump Station, Alt 1, Port Townsend, WA
WW Pump Station, Schematic, 15% Design
425179, Rev 0

| | |
|----------------------|--|
| Project name | Port Townsend Alt 1 Port Townsend WA |
| Estimator | C Moore/SEA |
| Labor rate table | 2_AA04 (2012) |
| Equipment rate table | 1_EqRates_2011_75% |
| Job size | 1 LS |
| Project | Port Townsend PS |
| Project Number | 425179 |
| Market Segment | Wastewater Pump Stat |
| Business Group | WBG |
| Project Conditions | New |
| Estimate Class 1-5 | 3 |
| Estimate Category | Consult Engineer Est |
| Design Stage | Schematic Design |
| Project Manager | J Burnam |
| Report format | Sorted by 'Facility/Work Pkg/Trade Pkg/WorkActiv/Unit Price' 'Detail' summary Allocate addons Combine items |



Detail Report

Job Size: 1 LS
Duration:

Project: Port Townsend Alt 1
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date:
Estimate Class: 3

| Fac | Work Pkg | Trade Pkg | Work Activity | Unit Price | Description | Takeoff Quantity | Labor Man Hrs | Labor Amount | Material Amount | Sub Amount | Equip Amount | Other Amount | Total Cost/Unit | Total Amount |
|-----|----------|-----------|---------------|------------|--|------------------|---------------|---------------|-----------------|---------------|---------------|--------------|-----------------|----------------|
| 92 | | | | | OFFSITE - PIPELINES | | | | | | | | | |
| | 33.0 | | | | Buried Piping | | | | | | | | | |
| | | 33-35 | | | Pipelines | | | | | | | | | |
| | | | CJM-010 | | Gravity Pipe | | | | | | | | | |
| | | | 02-01-01-01 | | General Site Demolition, Asphalt Pavement | | | | | | | | | |
| | | | | | Asphalt Demolition and Loading | 183.00 cy | 7.3 | 491 | - | - | 261 | - | 4.11 /cy | 752 |
| | | | 02-01-01-01 | | General Site Demolition, Asphalt Pavement | 13,520.00 SF | 7.3 | 491 | - | - | 261 | - | 0.06 /SF | 752 |
| | | | 31-19-01-00 | | Site Preparation, Dewatering, Sump Pump | | | | | | | | | |
| | | | | | Dewatering Minor, Large Generator and 1 Pumps, Rental, Monthly | 0.25 mo | | | | | 1,531 | | 6,124.32 /mo | 1,531 |
| | | | 31-19-01-00 | | Site Preparation, Dewatering, Sump Pump | 0.25 MO | | | | | 1,531 | | 6,124.32 /MO | 1,531 |
| | | | 31-40-02-00 | | Site Improvements, Paving, Bituminous Asphalt | | | | | | | | | |
| | | | | | Bituminous Pavement Subgrade Prep | 1,502.00 sy | 13.5 | | | | | | 1.83 /sy | 2,741 |
| | | | | | Bituminous Pavement Import Aggregate Base, 6" | 438.00 tn | 5.7 | | | 16,521 | | | 37.72 /tn | 16,521 |
| | | | | | Bituminous Asphalt (tn), 6" | 514.00 tn | 4.1 | | | 71,920 | | | 139.92 /tn | 71,920 |
| | | | | | Pavement Marking, 4" Pavement striping | 1,690.00 lf | 3.4 | | | 3,084 | | | 1.83 /lf | 3,084 |
| | | | 31-40-02-00 | | Site Improvements, Paving, Bituminous Asphalt | 1,502.00 SY | 26.7 | | | 94,266 | | | 62.76 /SY | 94,266 |
| | | | 31-45-01-00 | | Fencing, Chain Link | | | | | | | | | |
| | | | | | Traffic Control, Labor per Day | 10.00 day | 160.0 | 9,731 | | | | | 973.15 /day | 9,731 |
| | | | | | Trench Box, 8' x 24' x 10' | 0.25 mo | | | | | | | 2,798.44 /mo | 700 |
| | | | | | Excav. pipe trench, w/ 1:1 slopes, for 4" - 24" pipe | 1,422.68 CY | 41.3 | 2,858 | | | 700 | | 4.50 /CY | 6,404 |
| | | | | | Backfill / Compact @ pipe zone, for 4" thru 24" pipe | 313.99 cy | 41.8 | 2,790 | | | 3,547 | | 14.54 /cy | 4,566 |
| | | | | | Backfill / Compact above pipe zone, for 4" thru 24" pipe | 1,143.27 cy | 33.2 | 2,479 | | | 2,043 | | 3.96 /cy | 4,522 |
| | | | | | Pipe zone material | 313.99 cy | | | 10,697 | | | | 34.07 /cy | 10,697 |
| | | | | | Pipe bedding material | 101.73 cy | | | 3,466 | | | | 34.07 /cy | 3,466 |
| | | | | | Imported backfill material | 1,143.27 cy | | | 16,692 | | | | 14.60 /cy | 16,692 |
| | | | | | Haul spoils, offsite, up to 10 miles | 415.72 cy | | | | 5,058 | | | 12.17 /cy | 5,058 |
| | | | | | Dump fees, trench spoils | 415.72 ls | | | | 2,529 | | | 6.08 /ls | 2,529 |
| | | | | | FURNISH PVC water distribution pipe, C-900, class 150, DR 18, 8" | 1,690.00 LF | | | 20,830 | | | | 12.33 /LF | 20,830 |
| | | | | | Install PVC water distribution pipe, excav/bkfill NOT included, 8" | 1,690.00 LF | 216.3 | 18,104 | | | | | 15.93 /LF | 26,916 |
| | | | | | Pipe Marking, ID Tape | 1,690.00 lf | 16.9 | 1,528 | | 267 | | | 1.06 /lf | 1,796 |
| | | | 31-45-01-00 | | Fencing, Chain Link | 1,690.00 LF | 509.4 | 37,491 | 54,481 | 5,058 | 16,878 | | 67.40 /LF | 113,908 |
| | | | | | CJM-010 Gravity Pipe | | | 543.4 | 37,982 | 54,481 | 99,324 | | | 210,457 |
| | | | 33-35 | | Pipelines | 1,690.00 LF | 543.4 | 37,982 | 54,481 | 99,324 | 18,670 | | 124.53 /LF | 210,457 |
| | | | 33.0 | | Buried Piping | 1,690.00 LF | 543.4 | 37,982 | 54,481 | 99,324 | 18,670 | | 124.53 /LF | 210,457 |
| | | | | | 92 OFFSITE - PIPELINES | | 543.4 | 37,982 | 54,481 | 99,324 | 18,670 | | | 210,457 |



Detail Report

Job Size: 1 LS
Duration:

Project: Port Townsend Alt 1
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date:
Estimate Class: 3

Estimate Totals

| Description | Amount | Totals | Hours | Rate | % of Total |
|---------------------------------------|----------------|----------------|-------------|----------|------------|
| Labor | 37,982 | | 543.417 hrs | | |
| Material | 54,481 | | | | |
| Subcontract | 99,324 | | | | |
| Equipment | 18,670 | | 466.883 hrs | | |
| Other | | | | | |
| Total Subcontractor OH&P | 210,457 | 210,457 | | | |
| General Conditions | 12,144 | | | 7.000 % | |
| Total Taxes | 12,144 | 222,601 | | | |
| Mobilization/Demobilization | 11,493 | | | 3.000 % | |
| Blder's Risk & Gen Liab Ins -% | 3,831 | | | 1.000 % | |
| Payment & Performance Bond | 4,444 | | | 1.160 % | |
| Total Owner-Provided Equipment | 19,768 | 242,369 | | | |
| Contingency - % | 96,948 | | | 40.000 % | |
| Total Contingency | 96,948 | 339,317 | | | |
| Escalation on Estimate Total | 12,148 | | | 3.580 % | |
| Construction Total | 12,148 | 351,465 | | | |
| Gross Sales Tax | 31,632 | | | 9.000 % | |
| Construction Total (with GST) | 31,632 | 383,097 | | | |

**Port Townsend Mill Rd Pump Station, Alt 2, Port Townsend, WA
WW Pump Station, Schematic, 15% Design
425179, Rev 0**

| | |
|-----------------------------|--|
| Project name | Port Townsend Alt 2 Port Townsend WA |
| Estimator | C Moore/SEA |
| Labor rate table | 2_AA04 (2012) |
| Equipment rate table | 1_EqRates_2011_75% |
| Job size | 1 LS |
| Project | Port Townsend PS |
| Project Number | 425179 |
| Market Segment | Wastewater Pump Stat |
| Business Group | WBG |
| Project Conditions | New |
| Estimate Class 1-5 | 3 |
| Estimate Category | Consult Engineer Est |
| Design Stage | Schematic Design |
| Project Manager | J Burnam |
| Report format | Sorted by 'Facility/Work Pkg/Trade Pkg/WorkActiv/Unit Price' 'Detail' summary Allocate addons Combine items |



Detail Report

Job Size: 1 LS
Duration:

Project: Port Townsend Alt 2
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date:
Estimate Class: 3

| Fac | Work Pkg | Trade Pkg | Work Activity | Unit Price | Description | Takeoff Quantity | Labor Man Hrs | Labor Amount | Material Amount | Sub Amount | Equip Amount | Other Amount | Total Cost/Unit | Total Amount |
|-----|----------|-----------|---------------|------------|--|------------------|---------------|---------------|-----------------|----------------|---------------|--------------|-----------------|----------------|
| 92 | | | | | OFFSITE - PIPELINES | | | | | | | | | |
| | 33.0 | | | | Buried Piping | | | | | | | | | |
| | | 33-35 | | | Pipelines | | | | | | | | | |
| | | | CJM-010 | | Gravity Pipe | | | | | | | | | |
| | | | 02-01-01-01 | | General Site Demolition, Asphalt Pavement | | | | | | | | | |
| | | | | | Asphalt Demolition and Loading | 238.00 cy | 9.5 | 639 | - | - | 340 | - | 4.11 /cy | 978 |
| | | | 02-01-01-01 | | General Site Demolition, Asphalt Pavement | 17,600.00 SF | 9.5 | 639 | - | - | 340 | - | 0.06 /SF | 978 |
| | | | 31-19-01-00 | | Site Preparation, Dewatering, Sump Pump | | | | | | | | | |
| | | | | | Dewatering Minor, Large Generator and 1 Pumps, Rental, Monthly | 0.25 mo | | | | | 1,531 | | 6,123.52 /mo | 1,531 |
| | | | 31-19-01-00 | | Site Preparation, Dewatering, Sump Pump | 0.25 MO | | | | | 1,531 | | 6,123.52 /MO | 1,531 |
| | | | 31-40-02-00 | | Site Improvements, Paving, Bituminous Asphalt | | | | | | | | | |
| | | | | | Bituminous Pavement Subgrade Prep | 1,956.00 sy | 17.6 | | | 3,569 | | | 1.83 /sy | 3,569 |
| | | | | | Bituminous Pavement Import Aggregate Base, 6" | 570.00 tn | 7.4 | | | 21,496 | | | 37.71 /tn | 21,496 |
| | | | | | Bituminous Asphalt (tn), 6" | 669.00 tn | 5.4 | | | 93,595 | | | 139.90 /tn | 93,595 |
| | | | | | Pavement Marking, 4" Pavement striping | 2,200.00 lf | 4.4 | | | 4,015 | | | 1.83 /lf | 4,015 |
| | | | 31-40-02-00 | | Site Improvements, Paving, Bituminous Asphalt | 1,956.00 SY | 34.8 | | | 122,675 | | | 62.72 /SY | 122,675 |
| | | | 33-00-07-08 | | Yard Pipe, PVC, 8" | | | | | | | | | |
| | | | | | Traffic Control, Labor per Day | 10.00 day | 160.0 | 9,730 | | | | | 973.02 /day | 9,730 |
| | | | | | Trench Box, 8' x 24' x 10' | 0.25 mo | | | | | 700 | | 2,798.04 /mo | 700 |
| | | | | | Excav. pipe trench, w/ 1:1 slopes, for 4" - 24" pipe | 1,852.01 CY | 53.7 | 3,719 | | | 4,616 | | 4.50 /CY | 8,336 |
| | | | | | Backfill / Compact @ pipe zone, for 4" thru 24" pipe | 408.74 cy | 54.4 | 3,631 | | | 2,312 | | 14.54 /cy | 5,943 |
| | | | | | Backfill / Compact above pipe zone, for 4" thru 24" pipe | 1,488.28 cy | 43.2 | 3,227 | | | 2,659 | | 3.96 /cy | 5,886 |
| | | | | | Pipe zone material | 408.74 cy | | | 13,923 | | | | 34.06 /cy | 13,923 |
| | | | | | Pipe bedding material | 132.43 cy | | | 4,511 | | | | 34.06 /cy | 4,511 |
| | | | | | Imported backfill material | 1,488.28 cy | | | 21,727 | | | | 14.60 /cy | 21,727 |
| | | | | | Haul spoils, offsite, up to 10 miles | 541.17 cy | | | | 6,584 | | | 12.17 /cy | 6,584 |
| | | | | | Dump fees, trench spoils | 541.17 ls | | | 3,292 | | | | 6.08 /ls | 3,292 |
| | | | | | FURNISH PVC water distribution pipe, C-900, class 150, DR 18, 8" | 2,200.00 LF | | | 27,112 | | | | 12.32 /LF | 27,112 |
| | | | | | Install PVC water distribution pipe, excav/bkfill NOT included, 8" | 2,200.00 LF | 281.6 | 23,565 | | | | | 15.93 /LF | 35,034 |
| | | | | | Pipe Marking, ID Tape | 2,200.00 lf | 22.0 | 1,989 | | | 11,470 | | 1.06 /lf | 2,337 |
| | | | 33-00-07-08 | | Yard Pipe, PVC, 8" | 2,200.00 LF | 614.8 | 45,862 | 70,912 | 6,584 | 21,757 | | 65.96 /LF | 145,115 |
| | | | CJM-010 | | Gravity Pipe | | 659.1 | 46,500 | 70,912 | 129,258 | 23,628 | | | 270,299 |
| | | | 33-35 | | Pipelines | 2,200.00 LF | 659.1 | 46,500 | 70,912 | 129,258 | 23,628 | | 122.86 /LF | 270,299 |
| | | | 33.0 | | Buried Piping | 2,200.00 LF | 659.1 | 46,500 | 70,912 | 129,258 | 23,628 | | 122.86 /LF | 270,299 |
| | | | | | 92 OFFSITE - PIPELINES | | 659.1 | 46,500 | 70,912 | 129,258 | 23,628 | | | 270,299 |

Detail Report

Project: Port Townsend Alt 2
 Project No.: 425179
 Design Stage: Schematic Design

Estimator: C Moore/SEA
 Revision / Date:
 Estimate Class: 3

Estimate Totals

| Description | Amount | Totals | Hours | Rate | % of Total |
|---------------------------------------|----------------|----------------|-------------|----------|------------|
| Labor | 46,500 | | 659.117 hrs | | |
| Material | 70,912 | | | | |
| Subcontract | 129,258 | | | | |
| Equipment | 23,628 | | 568.540 hrs | | |
| Other | | | | | |
| Total Subcontractor OH&P | 270,298 | 270,298 | | | |
| General Conditions | 15,597 | | | 7.000 % | |
| Total Taxes | 15,597 | 285,895 | | | |
| Mobilization/Demobilization | 14,761 | | | 3.000 % | |
| Blder's Risk & Gen Liab Ins -% | 4,920 | | | 1.000 % | |
| Payment & Performance Bond | 5,708 | | | 1.160 % | |
| Total Owner-Provided Equipment | 25,389 | 311,284 | | | |
| Contingency - % | 124,514 | | | 40.000 % | |
| Total Contingency | 124,514 | 435,798 | | | |
| Escalation on Estimate Total | 15,602 | | | 3.580 % | |
| Construction Total | 15,602 | 451,400 | | | |
| Gross Sales Tax | 40,626 | | | 9.000 % | |
| Construction Total (with GST) | 40,626 | 492,026 | | | |

Port Townsend Mill Rd Pump Station, Com Alt 1&2, Port Townsend, WA
WW Pump Station, Schematic, 15% Design
425179, Rev 0

| | |
|-----------------------------|--|
| Project name | Port Townsend Com 1&2 Port Townsend WA |
| Estimator | C Moore/SEA |
| Labor rate table | 2_AA04 (2012) |
| Equipment rate table | 1_EqRates_2011_75% |
| Job size | 1 LS |
| Project | Port Townsend PS |
| Project Number | 425179 |
| Market Segment | Wastewater Pump Stat |
| Business Group | WBG |
| Project Conditions | New |
| Estimate Class 1-5 | 3 |
| Estimate Category | Consult Engineer Est |
| Design Stage | Schematic Design |
| Project Manager | J Burnam |
| Report format | Sorted by 'Facility/Work Pkg/Trade Pkg/WorkActiv/Unit Price' 'Detail' summary Allocate addons Combine items |

Detail Report

Project: Port Townsend Com 1&2
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date:
Estimate Class: 3

| Fac | Work Pkg | Trade Pkg | Work Activity | Unit Price | Description | Takeoff Quantity | Labor Man Hrs | Labor Amount | Material Amount | Sub Amount | Equip Amount | Other Amount | Total Cost/Unit | Total Amount |
|-----|----------|-----------|---------------|------------|---|------------------|---------------|---------------|-----------------|----------------|---------------|--------------|-----------------|----------------|
| 92 | | | | | OFFSITE - PIPELINES | | | | | | | | | |
| | 33.0 | | | | Buried Piping | | | | | | | | | |
| | | 33-35 | | | Pipelines | | | | | | | | | |
| | | | CJM-010 | | Gravity Pipe | | | | | | | | | |
| | | | 02-01-01-01 | | General Site Demolition, Asphalt Pavement | | | | | | | | | |
| | | | | | Asphalt Demolition and Loading | 272.00 | 10.9 | 730 | - | - | 388 | - | 4.11 /cy | 1,118 |
| | | | 02-01-01-01 | | General Site Demolition, Asphalt Pavement | 20,160.00 | 10.9 | 730 | - | - | 388 | - | 0.06 /SF | 1,118 |
| | | | 31-19-01-00 | | Site Preparation, Dewatering, Sump Pump | | | | | | | | | |
| | | | | | Dewatering Minor, Large Generator and 1 Pumps, Rental, Monthly | 0.50 | | | | | 3,063 | | 6,125.12 /mo | 3,063 |
| | | | 31-19-01-00 | | Site Preparation, Dewatering, Sump Pump | 0.50 | | | | | 3,063 | | 6,125.12 /MO | 3,063 |
| | | | 31-40-02-00 | | Site Improvements, Paving, Bituminous Asphalt | | | | | | | | | |
| | | | | | Bituminous Pavement Subgrade Prep | 2,240.00 | 20.2 | | | 4,089 | | | 1.83 /sy | 4,089 |
| | | | | | Bituminous Pavement Import Aggregate Base, 6" | 653.00 | 8.5 | | | 24,633 | | | 37.72 /tn | 24,633 |
| | | | | | Bituminous Asphalt (tn), 6" | 766.00 | 6.1 | | | 107,194 | | | 139.94 /tn | 107,194 |
| | | | | | Pavement Marking, 4" Pavement striping | 2,520.00 | 5.0 | | | | | | 1.83 /lf | 4,600 |
| | | | 31-40-02-00 | | Site Improvements, Paving, Bituminous Asphalt | 2,240.00 | 39.8 | | | | | | 62.73 /SY | 140,516 |
| | | | 33-00-07-10 | | Yard Pipe, PVC, 10" | | | | | 140,516 | | | | 140,516 |
| | | | | | Traffic Control, Labor per Day | 15.00 | 240.0 | 14,599 | | | | | 973.26 /day | 14,599 |
| | | | | | Trench Box, 8' x 24' x 10' | 0.50 | | | | | 1,399 | | 2,798.82 /mo | 1,399 |
| | | | | | Excav, pipe trench, w/ 1:1 slopes, for 4" - 24" pipe | 2,332.90 | 67.7 | 4,686 | | | 5,817 | | 4.50 /CY | 10,503 |
| | | | | | Backfill / Compact @ pipe zone, for 4" thru 24" pipe | 530.48 | 70.6 | 4,714 | | | 3,002 | | 14.55 /cy | 7,716 |
| | | | | | Backfill / Compact above pipe zone, for 4" thru 24" pipe | 1,849.12 | 53.6 | 4,010 | | | 3,305 | | 3.96 /cy | 7,315 |
| | | | | | Pipe zone material | 530.48 | | | 18,075 | | | | 34.07 /cy | 18,075 |
| | | | | | Pipe bedding material | 160.64 | | | 5,473 | | | | 34.07 /cy | 5,473 |
| | | | | | Imported backfill material | 1,849.12 | | | 27,002 | | | | 14.60 /cy | 27,002 |
| | | | | | Haul spoils, offsite, up to 10 miles | 691.12 | | | | 8,410 | | | 12.17 /cy | 8,410 |
| | | | | | Dump fees, trench spoils | 691.12 | | | 4,205 | | | | 6.08 /ts | 4,205 |
| | | | | | FURNISH PVC water distribution pipe, C-900, class 150, DR 18, 10" | 2,520.00 | | | 46,642 | | | | 18.51 /LF | 46,642 |
| | | | | | Install PVC water distribution pipe, excav/bkfill NOT included, 10" | 2,520.00 | 383.0 | 32,062 | | | | | 18.92 /LF | 47,667 |
| | | | | | Pipe Marking, ID Tape | 2,520.00 | 25.2 | 2,279 | 399 | | 15,605 | | 1.06 /lf | 2,678 |
| | | | 33-00-07-10 | | Yard Pipe, PVC, 10" | 2,520.00 | 840.1 | 62,350 | 101,795 | 8,410 | 29,128 | | 80.03 /LF | 201,693 |
| | | | 33-15-01-05 | | Yard Structures, Manholes, 60" Dia | | | | | | | | | |
| | | | | | Catchbasins, frs and covs, lt traffic, 24" diam, 300 lb. | 4.00 | 11.0 | 723 | 1,149 | | 339 | | 552.50 /ea | 2,210 |
| | | | | | Manholes, concrete, precast, 5' I.D., 8' deep | 4.00 | 64.0 | 4,191 | 9,492 | | 1,964 | | 3,911.52 /ea | 15,646 |
| | | | | | Manholes, conc, precast, 5' I.D., for DS over 8', add | 16.00 | 32.0 | 2,085 | 3,505 | | 982 | | 411.36 /vlf | 6,582 |
| | | | | | Drop Structure Piping | 4.00 | | | 1,460 | | | | 365.06 /ea | 1,460 |
| | | | 33-15-01-05 | | Yard Structures, Manholes, 60" Dia | 4.00 | 107.0 | 7,009 | 15,605 | | 3,284 | | 6,474.53 /EA | 25,898 |
| | | | | | CJM-010 Gravity Pipe | | 997.8 | 70,089 | 117,400 | 148,926 | 35,863 | | | 372,278 |
| | | | 33-35 | | Pipelines | 2,520.00 | 997.8 | 70,089 | 117,400 | 148,926 | 35,863 | | 147.73 /LF | 372,278 |
| | | | 33.0 | | Buried Piping | 2,520.00 | 997.8 | 70,089 | 117,400 | 148,926 | 35,863 | | 147.73 /LF | 372,278 |
| | | | | | 92 OFFSITE - PIPELINES | | 997.8 | 70,089 | 117,400 | 148,926 | 35,863 | | | 372,278 |



CH2MHILL

Job Size: 1 LS
Duration:

Detail Report

Project: Port Townsend Com 1&2
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date:
Estimate Class: 3

Estimate Totals

| Description | Amount | Totals | Hours | Rate | % of Total |
|---------------------------------------|----------------|----------------|-------------|----------|------------|
| Labor | 70,089 | | 997.805 hrs | | |
| Material | 117,400 | | | | |
| Subcontract | 148,926 | | | | |
| Equipment | 35,863 | | 948.431 hrs | | |
| Other | | | | | |
| Total Subcontractor OH&P | 372,278 | 372,278 | | | |
| General Conditions | 21,482 | | | 7.000 % | |
| Total Taxes | 21,482 | 393,760 | | | |
| Mobilization/Demobilization | 20,330 | | | 3.000 % | |
| Blder's Risk & Gen Liab Ins -% | 6,777 | | | 1.000 % | |
| Payment & Performance Bond | 7,861 | | | 1.160 % | |
| Total Owner-Provided Equipment | 34,968 | 428,728 | | | |
| Contingency - % | 171,491 | | | 40.000 % | |
| Total Contingency | 171,491 | 600,219 | | | |
| Escalation on Estimate Total | 21,488 | | | 3.580 % | |
| Construction Total | 21,488 | 621,707 | | | |
| Gross Sales Tax | 55,954 | | | 9.000 % | |
| Construction Total (with GST) | 55,954 | 677,661 | | | |

Port Townsend Mill Rd Pump Station, Alt 3, Port Townsend, WA
WW Pump Station, Schematic, 15% Design
425179, Rev 0

| | |
|-----------------------------|---|
| Project name | Port Townsend Alt 3 Port Townsend WA |
| Estimator | C Moore/SEA |
| Labor rate table | 2_AA04 (2012) |
| Equipment rate table | 1_EqRates_2011_75% |
| Job size | 1 LS |
| Project | Port Townsend PS |
| Project Number | 425179 |
| Market Segment | Wastewater Pump Stat |
| Business Group | WBG |
| Project Conditions | New |
| Estimate Class 1-5 | 3 |
| Estimate Category | Consult Engineer Est |
| Design Stage | Schematic Design |
| Project Manager | J Burnam |
| Report format | Sorted by 'Facility/Work Pkg/Trade Pkg/WorkActiv/Unit Price' 'Detail' summary Allocate add-ons Combine items |



Job Size: 1 LS
Duration:

Detail Report

Project: Port Townsend Alt 3
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date:
Estimate Class: 3

| Fac | Work Pkg | Trade Pkg | Work Activity | Unit Price | Description | Takeoff Quantity | Labor Man Hrs | Labor Amount | Material Amount | Sub Amount | Equip Amount | Other Amount | Total Cost/Unit | Total Amount |
|-----|----------|-----------|---------------|-------------|--|--------------------|---------------|---------------|-----------------|--------------|---------------|--------------|------------------|----------------|
| 92 | | | | | OFFSITE - PIPELINES | | | | | | | | | |
| | 33.0 | | | | Buried Piping | | | | | | | | | |
| | | 33-35 | | | Pipelines | | | | | | | | | |
| | | | CJM-001 | | 10 dia Force Main | | | | | | | | | |
| | | | | 31-19-01-00 | Site Preparation, Dewatering, Sump Pump | | | | | | | | | |
| | | | | | Dewatering Minor, Large Generator and 1 Pumps, Rental, Monthly | 0.25 mo | | | | | 1,533 | | 6,132.84 /mo | 1,533 |
| | | | | | 31-19-01-00 Site Preparation, Dewatering, Sump Pump | 0.25 MO | | | | | 1,533 | | 6,132.84 /MO | 1,533 |
| | | | | 33-00-07-10 | Yard Pipe, PVC, 10" | | | | | | | | | |
| | | | | | Trench Box, 8' x 24' x 10' | 0.25 mo | | | | | 701 | | 2,802.32 /mo | 701 |
| | | | | | Excav. pipe trench, w/ 1:1 slopes, for 4" - 24" pipe | 1,574.21 CY | 45.7 | 3,166 | | | 3,930 | | 4.51 /CY | 7,096 |
| | | | | | Backfill / Compact @ pipe zone, for 4" thru 24" pipe | 347.43 cy | 46.2 | 3,091 | | | 1,969 | | 14.56 /cy | 5,059 |
| | | | | | Backfill / Compact above pipe zone, for 4" thru 24" pipe | 1,265.03 cy | 36.7 | 2,747 | | | 2,264 | | 3.96 /cy | 5,010 |
| | | | | | Pipe zone material | 347.43 cy | | | 11,853 | | | | 34.12 /cy | 11,853 |
| | | | | | Pipe bedding material | 112.57 cy | | | 3,840 | | | | 34.12 /cy | 3,840 |
| | | | | | Imported backfill material | 1,265.03 cy | | | 18,496 | | | | 14.62 /cy | 18,496 |
| | | | | | Haul spoils, offsite, up to 10 miles | 460.00 cy | | | | 5,605 | | | 12.18 /cy | 5,605 |
| | | | | | Dump fees, trench spoils | 460.00 ls | | | 2,802 | | | | 6.09 /ls | 2,802 |
| | | | | | FURNISH PVC water distribution pipe, C-900, class 150, DR 18, 8" | 1,870.00 LF | | | 23,080 | | | | 12.34 /LF | 23,080 |
| | | | | | Install PVC water distribution pipe, excav/bkfill NOT included, 8" | 1,870.00 LF | 239.4 | 20,058 | | | 9,764 | | 15.95 /LF | 29,822 |
| | | | | | Pipe Marking, ID Tape | 1,870.00 lf | 18.7 | 1,693 | 296 | | | | 1.06 /lf | 1,989 |
| | | | | | 33-00-07-10 Yard Pipe, PVC, 10" | 1,870.00 LF | 386.6 | 30,755 | 60,367 | 5,605 | 18,627 | | 61.69 /LF | 115,354 |
| | | | | | CJM-001 10 dia Force Main | 1,870.00 LF | 386.6 | 30,755 | 60,367 | 5,605 | 20,160 | | 62.51 /LF | 116,887 |
| | | | | | 33-35 Pipelines | 1,870.00 LF | 386.6 | 30,755 | 60,367 | 5,605 | 20,160 | | 62.51 /LF | 116,887 |
| | | | | | 33.0 Buried Piping | 1,870.00 LF | 386.6 | 30,755 | 60,367 | 5,605 | 20,160 | | 62.51 /LF | 116,887 |
| | | | | | 92 OFFSITE - PIPELINES | | 386.6 | 30,755 | 60,367 | 5,605 | 20,160 | | | 116,887 |

Detail Report

Project: Port Townsend Alt 3
 Project No.: 425179
 Design Stage: Schematic Design

Estimator: C Moore/SEA
 Revision / Date:
 Estimate Class: 3

Estimate Totals

| Description | Amount | Totals | Hours | Rate | % of Total |
|---------------------------------------|----------------|----------------|-------------|----------|------------|
| Labor | 30,755 | | 386.606 hrs | | |
| Material | 60,367 | | | | |
| Subcontract | 5,605 | | | | |
| Equipment | 20,160 | | 497.904 hrs | | |
| Other | | | | | |
| Total Subcontractor OH&P | 116,887 | 116,887 | | | |
| General Conditions | 6,745 | | | 7.000 % | |
| Total Taxes | 6,745 | 123,632 | | | |
| Mobilization/Demobilization | 6,383 | | | 3.000 % | |
| Blder's Risk & Gen Liab Ins -% | 2,128 | | | 1.000 % | |
| Payment & Performance Bond | 2,468 | | | 1.160 % | |
| Total Owner-Provided Equipment | 10,979 | 134,611 | | | |
| Contingency - % | 53,844 | | | 40.000 % | |
| Total Contingency | 53,844 | 188,455 | | | |
| Escalation on Estimate Total | 6,747 | | | 3.580 % | |
| Construction Total | 6,747 | 195,202 | | | |
| Gross Sales Tax | 17,568 | | | 9.000 % | |
| Construction Total (with GST) | 17,568 | 212,770 | | | |

Port Townsend Mill Rd Pump Station, Com Alt 1,2&3, Port Townsend, WA
WW Pump Station, Schematic, 15% Design
425179, Rev 0

| | |
|----------------------|---|
| Project name | Port Townsend Com 1,2&3 Port Townsend WA |
| Estimator | C Moore/SEA |
| Labor rate table | 2_AA04 (2012) |
| Equipment rate table | 1_EqRates_2011_75% |
| Job size | 1 LS |
| Project | Port Townsend PS |
| Project Number | 425179 |
| Market Segment | Wastewater Pump Stat |
| Business Group | WBG |
| Project Conditions | New |
| Estimate Class 1-5 | 3 |
| Estimate Category | Consult Engineer Est |
| Design Stage | Schematic Design |
| Project Manager | J Burnam |
| Report format | Sorted by 'Facility/Work Pkg/Trade Pkg/WorkActiv/Unit Price' 'Detail' summary Allocate add-ons Combine items |



CH2MHILL

Detail Report

Job Size: 1 LS
Duration:

Project: Port Townsend Com 1,2&3
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date:
Estimate Class: 3

| Fac | Work Pkg | Trade Pkg | Work Activity | Unit Price | Description | Takeoff Quantity | Labor Man Hrs | Labor Amount | Material Amount | Sub Amount | Equip Amount | Other Amount | Total Cost/Unit | Total Amount |
|-----|----------|-----------|---------------|------------|---|------------------|---------------|--------------|-----------------|---------------|--------------|--------------|-----------------|---------------|
| 92 | | | | | OFFSITE - PIPELINES | | | | | | | | | |
| | 33.0 | | | | Buried Piping | | | | | | | | | |
| | | 33-35 | | | Pipelines | | | | | | | | | |
| | | | CJM-010 | | Gravity Pipe | | | | | | | | | |
| | | | 02-01-01-01 | | General Site Demolition, Asphalt Pavement | | | | | | | | | |
| | | | | | Asphalt Demolition and Loading | 20.00 cy | 0.8 | 54 | - | - | 29 | - | 4.11 /cy | 82 |
| | | | 02-01-01-01 | | General Site Demolition, Asphalt Pavement | 1,496.00 SF | 0.8 | 54 | - | - | 29 | - | 0.06 /SF | 82 |
| | | | 31-19-01-00 | | Site Preparation, Dewatering, Sump Pump | | | | | | | | | |
| | | | | | Dewatering Minor, Large Generator and 1 Pumps, Rental, Monthly | 0.10 mo | | | | | 613 | | 6,126.10 /mo | 613 |
| | | | 31-19-01-00 | | Site Preparation, Dewatering, Sump Pump | 0.10 MO | | | | | 613 | | 6,126.10 /MO | 613 |
| | | | 31-40-02-00 | | Site Improvements, Paving, Bituminous Asphalt | | | | | | | | | |
| | | | | | Bituminous Pavement Subgrade Prep | 166.00 sy | 1.5 | | | 303 | | | 1.83 /sy | 303 |
| | | | | | Bituminous Pavement Import Aggregate Base, 6" | 49.00 tn | 0.6 | | | 1,849 | | | 37.73 /tn | 1,849 |
| | | | | | Bituminous Asphalt (tn), 6" | 57.00 tn | 0.5 | | | 7,978 | | | 139.97 /tn | 7,978 |
| | | | | | Pavement Marking, 4" Pavement striping | 187.00 lf | 0.4 | | | 341 | | | 1.83 /lf | 341 |
| | | | 31-40-02-00 | | Site Improvements, Paving, Bituminous Asphalt | 166.00 SY | 3.0 | | | 10,471 | | | 63.08 /SY | 10,471 |
| | | | 33-00-07-12 | | Yard Pipe, PVC, 12" | | | | | | | | | |
| | | | | | Traffic Control, Labor per Day | 2.00 day | 32.0 | 1,947 | | | | | 973.42 /day | 1,947 |
| | | | | | Trench Box, 8' x 24' x 10' | 0.10 mo | | | | | 280 | | 2,799.30 /mo | 280 |
| | | | | | Excav, pipe trench, w/ 1:1 slopes, for 4" - 24" pipe | 190.11 CY | 5.5 | 382 | | | 474 | | 4.50 /CY | 856 |
| | | | | | Backfill / Compact @ pipe zone, for 4" thru 24" pipe | 44.08 cy | 5.9 | 392 | | | 249 | | 14.55 /cy | 641 |
| | | | | | Backfill / Compact above pipe zone, for 4" thru 24" pipe | 148.94 cy | 4.3 | 323 | | | 266 | | 3.96 /cy | 589 |
| | | | | | Pipe zone material | 44.08 cy | | | 1,502 | | | | 34.08 /cy | 1,502 |
| | | | | | Pipe bedding material | 12.58 cy | | | 429 | | | | 34.08 /cy | 429 |
| | | | | | Imported backfill material | 148.94 cy | | | 2,175 | | | | 14.61 /cy | 2,175 |
| | | | | | Haul spoils, offsite, up to 10 miles | 56.66 cy | | | | 690 | | | 12.17 /cy | 690 |
| | | | | | Dump fees, trench spoils | 56.66 ls | | | 345 | | | | 6.09 /ls | 345 |
| | | | | | FURNISH PVC water distribution pipe, C-900, class 150, DR 18, 12" | 187.00 LF | | | 4,884 | | | | 26.12 /LF | 4,884 |
| | | | | | Install PVC water distribution pipe, excav/bkfill NOT included, 12" | 187.00 LF | 31.4 | 2,630 | | | 1,280 | | 20.91 /LF | 3,910 |
| | | | | | Pipe Marking, ID Tape | 187.00 lf | 1.9 | 169 | | 30 | | | 1.06 /lf | 199 |
| | | | 33-00-07-12 | | Yard Pipe, PVC, 12" | 187.00 LF | 81.0 | 5,843 | 9,365 | 690 | 2,550 | | 98.65 /LF | 18,447 |
| | | | CJM-010 | | Gravity Pipe | | 84.7 | 5,897 | 9,365 | 11,161 | 3,191 | | | 29,613 |
| | | | 33-35 | | Pipelines | 187.00 LF | 84.7 | 5,897 | 9,365 | 11,161 | 3,191 | | 158.36 /LF | 29,613 |
| | | | 33.0 | | Buried Piping | 187.00 LF | 84.7 | 5,897 | 9,365 | 11,161 | 3,191 | | 158.36 /LF | 29,613 |
| | | | | | 92 OFFSITE - PIPELINES | | 84.7 | 5,897 | 9,365 | 11,161 | 3,191 | | | 29,613 |



Job Size: 1 LS
Duration:

Detail Report

Project: Port Townsend Com 1,2&3
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date:
Estimate Class: 3

Estimate Totals

| Description | Amount | Totals | Hours | Rate | % of Total |
|---------------------------------------|---------------|---------------|------------|----------|------------|
| Labor | 5,897 | | 84.742 hrs | | |
| Material | 9,365 | | | | |
| Subcontract | 11,161 | | | | |
| Equipment | 3,191 | | 99.590 hrs | | |
| Other | | | | | |
| Total Subcontractor OH&P | 29,614 | 29,614 | | | |
| General Conditions | 1,709 | | | 7.000 % | |
| Total Taxes | 1,709 | 31,323 | | | |
| Mobilization/Demobilization | 1,617 | | | 3.000 % | |
| Blder's Risk & Gen Liab Ins -% | 539 | | | 1.000 % | |
| Payment & Performance Bond | 625 | | | 1.160 % | |
| Total Owner-Provided Equipment | 2,781 | 34,104 | | | |
| Contingency - % | 13,641 | | | 40.000 % | |
| Total Contingency | 13,641 | 47,745 | | | |
| Escalation on Estimate Total | 1,709 | | | 3.580 % | |
| Construction Total | 1,709 | 49,454 | | | |
| Gross Sales Tax | 4,451 | | | 9.000 % | |
| Construction Total (with GST) | 4,451 | 53,905 | | | |

Port Townsend Mill Rd Pump Station, Alt 4, Port Townsend, WA
WW Pump Station, Schematic, 15% Design
425179, Rev 0

| | |
|----------------------|--|
| Project name | Port Townsend Alt 4 Port Townsend WA |
| Estimator | C Moore/SEA |
| Labor rate table | 2_AA04 (2012) |
| Equipment rate table | 1_EqRates_2011_75% |
| Job size | 1 LS |
| Project | Port Townsend PS |
| Project Number | 425179 |
| Market Segment | Wastewater Pump Stat |
| Business Group | WBG |
| Project Conditions | New |
| Estimate Class 1-5 | 3 |
| Estimate Category | Consult Engineer Est |
| Design Stage | Schematic Design |
| Project Manager | J Burnam |
| Report format | Sorted by 'Facility/Work Pkg/Trade Pkg/WorkActiv/Unit Price' 'Detail' summary Allocate addons Combine items |

Detail Report

Project: Port Townsend Alt 4
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date:
Estimate Class: 3

| Fac | Work Pkg | Trade Pkg | Work Activity | Unit Price | Description | Takeoff Quantity | Labor Man Hrs | Labor Amount | Material Amount | Sub Amount | Equip Amount | Other Amount | Total Cost/Unit | Total Amount |
|-----|----------|-----------|---------------|------------|--|------------------|---------------|----------------|-----------------|----------------|----------------|---------------|-----------------|----------------|
| 92 | | | | | OFFSITE - PIPELINES | | | | | | | | | |
| | 33.0 | | | | Buried Piping | | | | | | | | | |
| | | 33-35 | | | Pipelines | | | | | | | | | |
| | | | CJM-010 | | Gravity Pipe | | | | | | | | | |
| | | | 02-01-01-01 | | General Site Demolition, Asphalt Pavement | | | | | | | | | |
| | | | | | Asphalt Demolition and Loading | 378.00 | 15.1 | 1,015 | - | - | 539 | - | 4.11 /cy | 1,554 |
| | | | 02-01-01-01 | | General Site Demolition, Asphalt Pavement | 28,000.00 | 15.1 | 1,015 | - | - | 539 | - | 0.06 /SF | 1,554 |
| | | | 31-19-01-00 | | Site Preparation, Dewatering, Sump Pump | | | | | | | | | |
| | | | | | Dewatering Minor, Large Generator and 1 Pumps, Rental, Monthly | 0.75 | mo | - | - | - | 4,593 | - | 6,124.64 /mo | 4,593 |
| | | | 31-19-01-00 | | Site Preparation, Dewatering, Sump Pump | 0.75 | MO | - | - | - | 4,593 | - | 6,124.64 /MO | 4,593 |
| | | | 31-40-02-00 | | Site Improvements, Paving, Bituminous Asphalt | | | | | | | | | |
| | | | | | Bituminous Pavement Subgrade Prep | 3,111.00 | 28.0 | - | - | 5,678 | - | - | 1.83 /sy | 5,678 |
| | | | | | Bituminous Pavement Import Aggregate Base, 6" | 907.00 | 11.8 | - | - | 34,212 | - | - | 37.72 /tn | 34,212 |
| | | | | | Bituminous Asphalt (tn), 6" | 1,064.00 | 8.5 | - | - | 148,885 | - | - | 139.93 /tn | 148,885 |
| | | | | | Pavement Marking, 4" Pavement striping | 3,500.00 | 7.0 | - | - | 6,388 | - | - | 1.83 /lf | 6,388 |
| | | | 31-40-02-00 | | Site Improvements, Paving, Bituminous Asphalt | 3,111.00 | 55.3 | - | - | 195,163 | - | - | 62.73 /SY | 195,163 |
| | | | 33-00-07-08 | | Yard Pipe, PVC, 8" | | | | | | | | | |
| | | | | | Traffic Control, Labor per Day | 20.00 | day | 320.0 | 19,464 | - | - | - | 973.19 /day | 19,464 |
| | | | | | Trench Box, 8' x 24' x 10' | 0.75 | mo | - | - | - | 2,099 | - | 2,798.59 /mo | 2,099 |
| | | | | | Excav. pipe trench, w/ 1:1 slopes, for 4" - 24" pipe | 2,946.37 | CY | 85.4 | 5,918 | - | 7,346 | - | 4.50 /CY | 13,264 |
| | | | | | Backfill / Compact @ pipe zone, for 4" thru 24" pipe | 650.27 | cy | 86.5 | 5,778 | - | 3,680 | - | 14.54 /cy | 9,457 |
| | | | | | Backfill / Compact above pipe zone, for 4" thru 24" pipe | 2,367.71 | cy | 68.7 | 5,134 | - | 4,231 | - | 3.96 /cy | 9,366 |
| | | | | | Pipe zone material | 650.27 | cy | - | 22,155 | - | - | - | 34.07 /cy | 22,155 |
| | | | | | Pipe bedding material | 210.69 | cy | - | 7,178 | - | - | - | 34.07 /cy | 7,178 |
| | | | | | Imported backfill material | 2,367.71 | cy | - | 34,572 | - | - | - | 14.60 /cy | 34,572 |
| | | | | | Haul spoils, offsite, up to 10 miles | 860.96 | cy | - | - | 10,476 | - | - | 12.17 /cy | 10,476 |
| | | | | | Dump fees, trench spoils | 860.96 | ls | - | 5,238 | - | - | - | 6.08 /ls | 5,238 |
| | | | | | FURNISH PVC water distribution pipe, C-900, class 150, DR 18, 8" | 3,500.00 | LF | - | 43,141 | - | - | - | 12.33 /LF | 43,141 |
| | | | | | Install PVC water distribution pipe, excav/bkfill NOT included, 8" | 3,500.00 | LF | 448.0 | 37,496 | - | - | 18,250 | 15.93 /LF | 55,747 |
| | | | | | Pipe Marking, ID Tape | 3,500.00 | lf | 35.0 | 3,165 | 554 | - | - | 1.06 /lf | 3,719 |
| | | | 33-00-07-08 | | Yard Pipe, PVC, 8" | 3,500.00 | LF | 1,043.6 | 76,956 | 112,837 | 10,476 | 35,606 | 67.39 /LF | 235,874 |
| | | | 33-15-01-05 | | Yard Structures, Manholes, 60" Dia | | | | | | | | | |
| | | | | | Catchbasins, frs and covs, lt traffic, 24" diam, 300 lb. | 4.00 | ea | 11.0 | 723 | 1,149 | - | 339 | 552.45 /ea | 2,210 |
| | | | | | Manholes, concrete, precast, 5' I.D., 8' deep | 4.00 | ea | 64.0 | 4,190 | 9,491 | - | 1,964 | 3,911.22 /ea | 15,645 |
| | | | | | Manholes, conc, precast, 5' I.D., for DS over 8', add | 16.00 | vlf | 32.0 | 2,095 | 3,504 | - | 982 | 411.33 /vlf | 6,581 |
| | | | | | Drop Structure Piping | 4.00 | ea | - | 1,460 | - | - | - | 365.03 /ea | 1,460 |
| | | | 33-15-01-05 | | Yard Structures, Manholes, 60" Dia | 4.00 | EA | 107.0 | 7,008 | 15,604 | 3,284 | - | 6,474.03 /EA | 25,896 |
| | | | | | CJM-010 Gravity Pipe | | | | | | | | | |
| | | | | | 33-35 Pipelines | 4,278.00 | LF | 1,221.1 | 84,979 | 128,441 | 205,639 | 44,023 | 108.25 /LF | 463,081 |
| | | | | | 33.0 Buried Piping | 4,278.00 | LF | 1,221.1 | 84,979 | 128,441 | 205,639 | 44,023 | 108.25 /LF | 463,081 |
| | | | | | 92 OFFSITE - PIPELINES | | | 1,221.1 | 84,979 | 128,441 | 205,639 | 44,023 | | 463,081 |



CH2MHILL

Job Size: 1 LS
Duration:

Detail Report

Project: Port Townsend Alt 4
Project No.: 425179
Design Stage: Schematic Design

Estimator: C Moore/SEA
Revision / Date:
Estimate Class: 3

Estimate Totals

| Description | Amount | Totals | Hours | Rate | % of Total |
|---------------------------------------|----------------|----------------|---------------|----------|------------|
| Labor | 84,979 | | 1,221.052 hrs | | |
| Material | 128,441 | | | | |
| Subcontract | 205,639 | | | | |
| Equipment | 44,023 | | 1,194.695 hrs | | |
| Other | | | | | |
| Total Subcontractor OH&P | 463,082 | 463,082 | | | |
| General Conditions | 26,721 | | | 7.000 % | |
| Total Taxes | 26,721 | 489,803 | | | |
| Mobilization/Demobilization | 25,288 | | | 3.000 % | |
| Blder's Risk & Gen Liab Ins -% | 8,429 | | | 1.000 % | |
| Payment & Performance Bond | 9,778 | | | 1.160 % | |
| Total Owner-Provided Equipment | 43,495 | 533,298 | | | |
| Contingency - % | 213,319 | | | 40.000 % | |
| Total Contingency | 213,319 | 746,617 | | | |
| Escalation on Estimate Total | 26,729 | | | 3.580 % | |
| Construction Total | 26,729 | 773,346 | | | |
| Gross Sales Tax | 69,601 | | | 9.000 % | |
| Construction Total (with GST) | 69,601 | 842,947 | | | |

Appendix E:
Calculations

Gravity Line Evaluation for Critical Depth and Supercritical Flow

Port Townsend - Mill Road Pump Station and Force Main Predesign

Critical Depths

From Brater and King, 6th Edition

Table 8-10 (page 8-61)

Equation: $Q = K'_c d^{5/2}$ Solving for $K'_c = Q/d^{5/2}$

Where: Q = flow in cfs
 K'c = Table Value
 d = Pipe Diameter

Normal Depth

From Brater and King, 6th Edition

Table 7-14 (page 7-04)

Equation: $Q = (K'/n)d^{8/3}s^{1/2}$ Solving for $K' = Qn/(d^{8/3}s^{1/2})$ Maximum Slope on Mill Road = 12.00% = 0.120 ft/ft

Where: Q = flow in cfs
 K' = Table Value
 d = Pipe Diameter
 s = Slope ft/ft
 n = Manning's Friction Factor = 0.013
 Maximum Slope on Thomas Street = 11.00% = 0.11 ft/ft

Flow (gpm) divided by 448.80 = Flow cfs

Critical Depth Calculations

Pipe Diameter = 8 inches = 0.67 ft

| Flow (gpm) | Flow (cfs) | K'c | D/d | D (ft) | D (inches) |
|------------|------------|--------|--------|--------|------------|
| 200.00 | 0.45 | 1.2280 | 0.4676 | 0.31 | 3.74 |
| 400.00 | 0.89 | 2.4560 | 0.6714 | 0.45 | 5.37 |
| 600.00 | 1.34 | 3.6841 | 0.8182 | 0.55 | 6.55 |
| 800.00 | 1.78 | 4.9121 | 0.9122 | 0.61 | 7.30 |
| 1,000.00 | 2.23 | 6.1401 | 0.9689 | 0.65 | 7.75 |

Pipe Diameter = 10 inches = 0.83 ft

| Flow (gpm) | Flow (cfs) | K'c | D/d | D (ft) | D (inches) |
|------------|------------|--------|--------|--------|------------|
| 200.00 | 0.45 | 0.7030 | 0.3500 | 0.23 | 2.80 |
| 400.00 | 0.89 | 1.4059 | 0.5019 | 0.33 | 4.02 |
| 600.00 | 1.34 | 2.1089 | 0.6204 | 0.41 | 4.96 |
| 800.00 | 1.78 | 2.8118 | 0.7191 | 0.48 | 5.75 |
| 1,000.00 | 2.23 | 3.5148 | 0.8010 | 0.53 | 6.41 |

Pipe Diameter = 12 inches = 1.00 ft

| Flow (gpm) | Flow (cfs) | K'c | D/d | D (ft) | D (inches) |
|------------|------------|--------|--------|--------|------------|
| 200.00 | 0.45 | 0.4456 | 0.2763 | 0.18 | 2.21 |
| 400.00 | 0.89 | 0.8913 | 0.3957 | 0.26 | 3.17 |
| 600.00 | 1.34 | 1.3369 | 0.4888 | 0.33 | 3.91 |
| 800.00 | 1.78 | 1.7825 | 0.5684 | 0.38 | 4.55 |
| 1,000.00 | 2.23 | 2.2282 | 0.6384 | 0.43 | 5.11 |

Normal Depth Calculations - Mill Road

Pipe Diameter = 8 inches = 0.67 ft

| Flow (gpm) | Flow (cfs) | K' | D/d | D (ft) | D (inches) |
|------------|------------|--------|--------|--------|------------|
| 200.00 | 0.45 | 0.0493 | 0.2200 | 0.15 | 1.76 |
| 400.00 | 0.89 | 0.0986 | 0.3133 | 0.21 | 2.51 |
| 600.00 | 1.34 | 0.1479 | 0.3884 | 0.26 | 3.11 |
| 800.00 | 1.78 | 0.1972 | 0.4557 | 0.30 | 3.65 |
| 1,000.00 | 2.23 | 0.2465 | 0.5194 | 0.35 | 4.16 |

Pipe Diameter = 10 inches = 0.83 ft

| Flow (gpm) | Flow (cfs) | K' | D/d | D (ft) | D (inches) |
|------------|------------|--------|--------|--------|------------|
| 200.00 | 0.45 | 0.0272 | 0.1644 | 0.11 | 1.32 |
| 400.00 | 0.89 | 0.0544 | 0.2315 | 0.15 | 1.85 |
| 600.00 | 1.34 | 0.0816 | 0.2841 | 0.19 | 2.27 |
| 800.00 | 1.78 | 0.1088 | 0.3300 | 0.22 | 2.64 |
| 1,000.00 | 2.23 | 0.1360 | 0.3712 | 0.25 | 2.97 |

Pipe Diameter = 12 inches = 1.00 ft

| Flow (gpm) | Flow (cfs) | K' | D/d | D (ft) | D (inches) |
|------------|------------|--------|--------|--------|------------|
| 200.00 | 0.45 | 0.0167 | 0.1300 | 0.09 | 1.04 |
| 400.00 | 0.89 | 0.0334 | 0.1818 | 0.12 | 1.45 |
| 600.00 | 1.34 | 0.0502 | 0.2222 | 0.15 | 1.78 |
| 800.00 | 1.78 | 0.0669 | 0.2515 | 0.17 | 2.01 |
| 1,000.00 | 2.23 | 0.0836 | 0.2877 | 0.19 | 2.30 |

In all cases, at 12% slope, normal depth is less than critical depth - flow is in supercritical mode.

Highlighted columns represent a calculated value from the Tables identified above.

Port Townsend - Mill Road Pump Station and Force Main Preliminary Design

Peak Flow at Ultimate Buildout = 1185 gpm = 2.64 cfs

Goal - Maintain flows between 2.0 to 7.0 fps

Based on the following use a 10 inch force main in the 30 percent design.

Potential Force Main Diameters

| | | | |
|-------------|----------|--------|----------------------|
| 6 inches = | 0.5 feet | Area = | 0.20 ft ² |
| 8 inches = | 0.7 feet | Area = | 0.35 ft ² |
| 10 inches = | 0.8 feet | Area = | 0.55 ft ² |

Flow Velocity (fps) = Q/A

| Pumped Flow (gpm) | Pumped Flow (cfs) | Force Main Velocity 6 inch | Force Main Velocity 8 inch | Force Main Velocity 10 inch |
|-------------------|-------------------|----------------------------|----------------------------|-----------------------------|
| 200 | 0.45 | 2.27 | | |
| 400 | 0.89 | 4.54 | | |
| 500 | 1.11 | 5.67 | | |
| 600 | 1.34 | 6.81 | | |
| 800 | 1.78 | 9.08 | | |
| 1000 | 2.23 | 11.35 | | |
| 1185 | 2.64 | 13.45 | | |
| 200 | 0.45 | | 1.28 | |
| 400 | 0.89 | | 2.55 | |
| 500 | 1.11 | | 3.19 | |
| 600 | 1.34 | | 3.83 | |
| 800 | 1.78 | | 5.11 | |
| 1000 | 2.23 | | 6.38 | |
| 1185 | 2.64 | | 7.56 | |
| 200 | 0.45 | | | 0.82 |
| 400 | 0.89 | | | 1.63 |
| 500 | 1.11 | | | 2.04 |
| 600 | 1.34 | | | 2.45 |
| 800 | 1.78 | | | 3.27 |
| 1000 | 2.23 | | | 4.09 |
| 1185 | 2.64 | | | 4.84 |

Highlighted areas represent those that meet the stated criteria of maintaining velocities between 2.0 and 7.0 fps. The intent is to install the physical facilities such that ultimate buildout flows can be accommodated - realizing that mechanical equipment (say pumps) can be changed relatively simply over time without requiring the expenditure of significant costs to adapt to varying influent flow conditions.

Find pumps that can be modified to deliver between 500 gpm and 1200 gpm. Possibly through impeller changes.

Want to install the 10" force main. Installing either of the smaller mains to keep velocities higher would just mean that they would have to be replaced once the influent flows and the pumped flows got to the higher velocity range. By installing the 10 inch line pumped velocities don't vary too much and it will help to keep headlosses low.

Force Main Headloss Calculations

Headloss = S*Length

Slope = $(3.03/D^{1.16})(V/C)^{1.85}$

Force Main Length = 4,278 ft
 Force Main Diameter 10 inches = 0.83 ft
 Force Main Area 0.55 ft²

Assume Force Main Material is DIP C = 130

Assumed Additional Losses to account for bends/angles in the Force Main, Pump Station Piping, etc. = 15.00% percent of calculated losses

Elevation of Forcemain at Pump Station = 19 ft (4 ft below ground surface)

Elevation of Forcemain at Discharge MH = 208 ft

| Flow (gpm) | Flow (cfs) | Force Main Diameter (ft) | Velocity (fps) | Slope ft/ft | Headloss (S*L) (ft) | Additional Losses | Total HL (ft) | Static Head Suction Lift | TDH Suction Lift | Static Head Submer. | TDH Submer. |
|------------|------------|--------------------------|----------------|-------------|---------------------|-------------------|---------------|--------------------------|------------------|---------------------|-------------|
| 0 | 0.00 | 0.83 | 0.00 | 0 | 0.00 | 0.00 | 0.00 | 189 | 189.00 | 200.98 | 200.98 |
| 200 | 0.45 | 0.83 | 0.82 | 0.000316 | 1.35 | 0.20 | 1.56 | 189 | 190.56 | 200.98 | 202.53 |
| 400 | 0.89 | 0.83 | 1.63 | 0.00114 | 4.88 | 0.73 | 5.61 | 189 | 194.61 | 200.98 | 206.59 |
| 600 | 1.34 | 0.83 | 2.45 | 0.002415 | 10.33 | 1.55 | 11.88 | 189 | 200.88 | 200.98 | 212.86 |
| 800 | 1.78 | 0.83 | 3.27 | 0.004111 | 17.59 | 2.64 | 20.23 | 189 | 209.23 | 200.98 | 221.20 |
| 1000 | 2.23 | 0.83 | 4.09 | 0.006212 | 26.58 | 3.99 | 30.56 | 189 | 219.56 | 200.98 | 231.54 |
| 1185 | 2.64 | 0.83 | 4.84 | 0.008504 | 36.38 | 5.46 | 41.84 | 189 | 230.84 | 200.98 | 242.81 |
| 1200 | 2.67 | 0.83 | 4.90 | 0.008704 | 37.24 | 5.59 | 42.82 | 189 | 231.82 | 200.98 | 243.80 |
| 1400 | 3.12 | 0.83 | 5.72 | 0.011577 | 49.53 | 7.43 | 56.95 | 189 | 245.95 | 200.98 | 257.93 |
| 1600 | 3.57 | 0.83 | 6.54 | 0.014821 | 63.40 | 9.51 | 72.91 | 189 | 261.91 | 200.98 | 273.89 |
| 1800 | 4.01 | 0.83 | 7.35 | 0.018429 | 78.84 | 11.83 | 90.67 | 189 | 279.67 | 200.98 | 291.64 |


Pump Curves

Smith & Loveless
8D4F Suction Pump

| Flow (gpm) | Head (ft) | Head (2 P's) (ft) |
|------------|-----------|-------------------|
| 0 | 239 | 239 |
| 200 | 237 | 238 |
| 400 | 236 | 237 |
| 600 | 235 | 236.5 |
| 800 | 233 | 236 |
| 1000 | 231 | 235.4 |
| 1185 | 228 | 234.8 |
| 1200 | 227 | 234.2 |
| 1400 | 224 | 233.6 |
| 1600 | 221 | 233 |

Flygt MP 3315 HT

| Flow (gpm) | Head (ft) | Head (2 P's) (ft) |
|------------|-----------|-------------------|
| 0 | 298 | 298 |
| 200 | 288 | 293 |
| 400 | 279 | 288 |
| 600 | 270 | 283.5 |
| 800 | 260 | 279 |
| 1000 | 251 | 275.2 |
| 1185 | 242 | 271.4 |
| 1200 | 240 | 267.6 |
| 1400 | 231 | 263.8 |
| 1600 | 223 | 260 |



Port Townsend - Mill Road Pump Station and Force Main Preliminary Design

Active Storage Volume

Eqn. $T = V/I + V/(Q-I)$ Where: T = allowable minimum cycle time between starts (time to fill plus time to empty) (minutes)
V = the active volume between LWL and HWL (fixed) (gallons)
I = inflow rate (gpm)
Q = pump rate (gpm)

Note: Worse case cycle time occurs when influent flow is 1/2 of pumping capacity.

Assumptions:

- 1 Duplex Pump Station - each pump capable of accommodating peak flow; operating in a lag/lead fashion to balance operating hours
- 2 Lag pump automatically called to operate if lead pump fails or cannot match influent flow
- 3 Want pumps to go through full on-off-on cycle no more than "X" time per hour. For a duplex station operating in lag/lead this allows for "2X" starts per hour. However active storage volume is based on a single pump to remain conservative.

Known variables: T = 6 cycles per hour = 10 minutes For an individual pump
 I = 1185 gpm At buildout
 Q = 1185 gpm

Solving above equation for V: $V = TQ/4$

Required Active Storage Volume = 2962.5 gallons (say) 3000 gallons


Check - cycle time when $I = Q/2$: T = 10.12658 minutes

Graphing Cycle Time Curve:

Inflow Rate Vs. Percent (%) of Pump Capacity

| Inflow Rate (gpm) | Percent of Pump Capacity | Pump Capacity (gpm) | Cycle Time (T) (min) |
|-------------------|--------------------------|---------------------|----------------------|
| 1 | 0.00 | 1185 | 3002.534 |
| 100 | 0.08 | 1185 | 32.76498 |
| 200 | 0.17 | 1185 | 18.04569 |
| 300 | 0.25 | 1185 | 13.38983 |
| 400 | 0.34 | 1185 | 11.32166 |
| 500 | 0.42 | 1185 | 10.37956 |
| 592.5 | 0.50 | 1185 | 10.12658 |
| 700 | 0.59 | 1185 | 10.47128 |
| 800 | 0.68 | 1185 | 11.54221 |
| 900 | 0.76 | 1185 | 13.85965 |
| 1000 | 0.84 | 1185 | 19.21622 |
| 1100 | 0.93 | 1185 | 38.02139 |
| 1185 | 1.00 | 1185 | #DIV/0! |

Do not plot lowest and highest Inf. flow rates as they approach infinity.



Port Townsend - Mill Road Pump Station and Force Main Preliminary Design

Wet Well Sizing

Assumptions:

- 1 Desire is to design and install the physical facilities of the wet well for complete buildout of the area; but retain the capability to use the facilities during the interim before complete buildout occurs.
- 2 Used "X" feet as an active storage depth to allow for adjustments in depth for lower influent flows during the early years of the station.
- 3 Utilized a circular wet well, easier to clean, maintain than a rectangular one.

Circular Wet Well Sizing:

Circle Area: $\text{Pi}(D^2)/4$
 Assumed Active Storage Volume Depth = 0.50 feet
 7.48 gal/ft³
 Required Wet Well Diameter -

Active Volume = 3000 gallons = 401.0695 ft³
 Diameter = Volume Pi Diameter
 ft³ ft

Say **32.00** ft Use **45 foot diameter to allow for 1 hours storage at peak (ultimate buildout) flow**

Area = 804.2496 ft² 1,590.44 ft²

Active Storage Volume available using larger diameter Caisson = 5,948.23 gallons

Standby Storage Capacity -

Required if Station experiences complete loss of power or both pumps fail.


| Storage Time @ Peak Inf. (min) | Peak Influent Flow (gpm) | Volume Required (gallons) | Volume Required (ft ³) | Depth in Wet Well (ft) |
|--------------------------------|--------------------------|---------------------------|------------------------------------|------------------------|
| 30 | 1,185 | 35,550 | 4,753 | 2.99 |
| 60 | 1,185 | 71,100 | 9,505 | 5.98 |
| 90 | 1,185 | 106,650 | 14,258 | 8.96 |
| 120 | 1,185 | 142,200 | 19,011 | 11.95 |
| 240 | 1,185 | 284,400 | 38,021 | 23.91 |

Note: depth indicated is for distance below invert of influent sewer only and does not include active storage volumes. Nor does it include depth from sewer invert to ground surface.

Potential Storage above High, High Alarm at different flow rates.

Assumption: Set storage to be equal to 30 minutes at buildout peak flows.


| Influent Flow (gpm) | Storage Volume (ft ³) | Storage Time (min) | Storage Time (hours) |
|---------------------|-----------------------------------|--------------------|----------------------|
| 200 | 71,100 | 355.5 | 5.93 |
| 400 | 71,100 | 177.8 | 2.96 |
| 600 | 71,100 | 118.5 | 1.98 |
| 800 | 71,100 | 88.9 | 1.48 |
| 1000 | 71,100 | 71.1 | 1.19 |
| 1185 | 71,100 | 60.0 | 1.00 |



Mill Road Pump Station Preliminary Design
Wet Well Sizing

Note: Layout for Suction Lift Pumps only differs by elimination of most of Dead Storage.

Figure 1
Generic Pump Layout



| | | | |
|----------------------------|---|-------------|--|
| | Assumed Suction Pump Volute Elevation = | 24.50 | 1.5 Assumed elevation of suction pump volute above GS. |
| Actual Pump Station Depth: | Surface Elevation = | 23.00 ft | |
| | Influent Sewer Elevation = | 14.50 ft | |
| | Standby Storage Elevations = | 14.50 ft to | 8.52 ft = 5.98 ft |
| | High, high water alarm Elev = | 8.52 ft | |
| | Lag Pump on Elevation = | 8.02 ft | 0.50 ft = Active Storage Volume |
| | High water alarm Elev = | 8.02 ft | |
| | Lead Pump On Elev = | 7.52 ft | |
| | Pump Off Elev = | 7.02 ft | |
| | Bottom of Dead Storage Elev = | 5.02 ft | |

Using submersible pumps the station wet well would be - 17.98 ft deep

If suction lift pumps were used the difference between pump off and surface elevation (assuming that the suction lift pumps were on top of the wet well and the volute was elevated 1.5 feet above the top of slab, cannot exceed 17.5 feet maximum. To make that work the top slab would have to be lowered by:

-0.02 ft